

PUBLIC NOTICE

Loss Prevention Certification Board (LPCB) warns of Counterfeit Fire Detection and Alarm Panel

Watford UK 13 May 2016.

The following is a notification from LPCB to distributors, contractors, fire departments, regulatory agencies and authorities having jurisdiction that counterfeit copies of the Computationics (trading as C-TEC) CFP range of fire detection and alarm panels have been identified in the Iranian marketplace.

The overall appearance of the counterfeit panels is very similar to the authentic LPCB approved C-TEC Panels and bear the C-TEC logo and LPCB certification mark. These counterfeit products **have not** been evaluated by LPCB to EN 54-2 and EN54-4 and it is unknown whether the Panels comply with any safety requirements. It has been identified by C-TEC that a number of incorrect component substitutions have been made which could cause an electrical and/or fire hazard.

Name of LPCB approved C-TEC Product:

- CFP702-2
- CFP702-4
- CFP704-4
- CFP708-2
- CFP708-4

If you have any doubt about the authenticity of the Panel, please contact:-

sales@C-tec.co.uk
01942 322744.