

Certificate of Product Approval

Certificate Number: 1093a

Issue: 06

Sentura Group Ltd. (including Fire Depot and Firechief Global)

Sentura House
3 Lands End Way
Oakham
Rutland
LE15 6RB
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

FIRECHIEF FM, XTR, POWERPLUS & ECOSPRAY Portable Fire Extinguishers

(Refer to attached appendix for details)

Standards

EN 3-7:2004+A1:2007

Portable fire extinguishers. Characteristics, performance requirements and test methods

EN 3-8:2006

Portable fire extinguishers. Additional requirements to EN 3-7 for the construction, resistance to pressure and mechanical tests for extinguishers with a maximum allowable pressure equal to or lower than 30 bar

EN 3-9:2006

Portable fire extinguishers. Additional requirements to EN 3-7 for pressure resistance of CO₂ extinguishers

This certificate and appendix is maintained and held in force through regular surveillance activities

S.A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

14 October 2021

Date of Issue

29 June 2012

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1093a Sentura Group Ltd. (including Fire Depot and Firechief Global)

Issue: 06

FIRECHIEF FM, XTR, POWERPLUS & ECOSPRAY Extinguishers to EN 3 Parts 7, 8 & 9

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
FXCD2S	CO ₂	2 kg	34B	1093a/31
FXCD5S	CO ₂	5 kg	70B	1093a/33
FXF2	Foam (SP)	2 litre	8A/55B	1093a/15
FXF3	Foam (SP)	3 litre	13A/89B	1093a/16
FXF6	Foam (SP)	6 litre	21A/144B	1093a/17
FXF9	Foam (SP)	9 litre	27A/233B	1093a/19
FMP1	ABC Powder (SP)	1 kg	8A/34B	1093a/01
PPP1	ABC Powder (SP)	1 kg	8A/55B	1093a/04
FXP2	ABC Powder (SP)	2 kg	13A/89B	1093a/06
FXP3	ABC Powder (SP)	3 kg	21A/113B	1093a/07
FXP4	ABC Powder (SP)	4 kg	27A/144B	1093a/08
FXP6	ABC Powder (SP)	6 kg	43A/233B	1093a/09
FXP9	ABC Powder (SP)	9 kg	55A/233B	1093a/11
FXP12	ABC Powder (SP)	12 kg	55A/233B	1093a/12

This certificate and appendix is maintained and held in force through regular surveillance activities

S. A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

14 October 2021

Date of Issue

29 June 2012

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1093a Sentura Group Ltd. (including Fire Depot and Firechief Global)

Issue: 06

FIRECHIEF FM, XTR, POWERPLUS & ECOSPRAY Extinguishers to EN 3 Parts 7, 8 & 9

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
FXW6	Water (SP)	6 litre	13A	1093a/24
FXW9	Water (SP)	9 litre	21A	1093a/25
ESW3	Water Additive (SP)	3 litre	13A	1093a/28
ESW6	Water Additive (SP)	6 litre	27A	1093a/29
FXWC2	Wet Chemical (SP)	2 litre	8A/34B/25F	1093a/21
FXWC3	Wet Chemical (SP)	3 litre	13A/70B/40F	1093a/22
FXWC6	Wet Chemical (SP)	6 litre	21A/113B/75F	1093a/23

This certificate and appendix is maintained and held in force through regular surveillance activities

S. A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

14 October 2021

Date of Issue

29 June 2012

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre