

## Certificate of Product Approval

Certificate Number: 1093e

Issue: 02

### Sentura Group Ltd. (including Fire Depot and Firechief Global)

Sentura House  
3 Lands End Way  
Oakham  
Rutland  
LE15 6RB  
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

**FIRECHIEF REELMAX Fire Hose Reels**  
(Refer to attached appendix for details)

#### Standards

**EN 671-1:2012**  
Fixed firefighting systems. Hose systems. Hose reels with semi-rigid hose

This certificate and appendix is maintained and held in force through regular surveillance activities

*S.A. Colwell*

Signed for BRE Global Ltd.

Sarah Colwell  
Verifier

9 August 2021  
Date of Issue

23 November 2018  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1093e Sentura Group Ltd. (including Fire Depot and Firechief Global)

Issue: 02

### FIRECHIEF REELMAX Fire Hose Reels to EN 671-1:2012

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
RMSM19-B	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/01
RMSM25-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/02
RMSA19-B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/03
RMSA25-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/04
RMFM19-B	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/05
RMFM25-B	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/06
RMFA19-B	Automatic, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/07
RMFA25-B	Automatic, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/08

This certificate and appendix is maintained and held in force through regular surveillance activities

*S. A. Colwell*

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

9 August 2021

Date of Issue

23 November 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**