

Certificate of Product Approval

Certificate Number: 1329Bk

Issue: 01

Ceasefire Industries U.K. Limited

3 Waterhouse Square
138-142 Holborn
London
EC1N 2SW
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Direct Low Pressure (DLP) Application Fixed Fire Suppression Systems

(refer to attached appendix for details)

Standards

LPS 1666: Issue 1.0

Requirements and test procedures for the LPCB approval of direct low pressure (DLP) application fixed fire suppression systems.

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

8 June 2021

Date of Issue

8 June 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1329Bk Ceasefire Industries U.K. Limited

Issue: 01

Ceasefire Industries U.K. Ltd FK-5-1-12 Direct Low Pressure (DLP) Application Fixed Fire Suppression Systems

Product Name	Container Size	Description	Detector Tube	Ventilation (Enclosed or Open Vents)	Air Flow (Forced / Natural)	LPCB Ref. No.
CF-000792A	2 kg	2 kg FK-5-1-12 DLP system	P/N:TI-000010A 6mm o/d	Enclosed & open options ⁴	Forced & natural ⁵	1329Bk/01
CF-000792B	3 kg	3 kg FK-5-1-12 DLP system	P/N:TI-000010A 6mm o/d	Enclosed & open options ⁴	Forced & natural ⁵	1329Bk/02
CF-000792C	4 kg	4 kg FK-5-1-12 DLP system	P/N:TI-000010A 6mm o/d	Enclosed & open options ⁴	Forced & natural ⁵	1329Bk/03

Notes:

- Ceasefire Industries U.K. Ltd FK-5-1-12 DLP Systems shall be configured, installed, serviced and maintained in accordance with Ceasefire Industries U.K. Ltd System Manual CQRS/DIR/FK/MAN/02 Version.00 Rev.00 – 03/12/2019.
- These systems are intended solely to provide enhanced local fire protection. They are not intended for use as whole room or building fire protection systems.
- The systems use a single method for detection and delivery of the extinguishing agent to the activation point.
 - System operation pressure: 15 bar @ 20°C.
 - System operation temperature range: -20°C to +60°C.
- The above systems may have air vents at low and/or high level (refer note 1).
- The above systems may have forced ventilation (refer note 1).

This certificate and appendix is maintained and held in force through regular surveillance activities

S.A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

8 June 2021

Date of Issue

8 June 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

