

Certificate of Product Approval

Certificate Number: 1572f

Issue: 01

Eagle Automation Systems Ltd

Unit 5 New House Farm
Vicarage Lane
North Weald
Essex
CM16 6AP



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product

1491-212-SF
full height turnstile

Standard

LPS 1175: Issue 8
Requirements and testing procedures for the LPCB certification and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Chris Hunr
Verifier

11 November 2019
Date of Issue

11 November 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1572f Eagle Automation Systems Ltd

Issue: 01

Full Height Turnstile

Product Name	Type	Number of Rotor Arms	Walkway Width (m)	Nominal Overall Unit Height (m)	Nominal Overall Unit Width (m)	Nominal Overall Unit Depth (m)	Security Rating	LPCB Ref. No.
1491-212-SF	Double full height turnstile	Four	0.535	2.153	2.0	1.33	B3 (SR2)	1572f/01

Notes:

1. The nominal height, width and depth dimensions are of the entire unit. They include the enclosure above the rotor that contains the drive and control mechanism but exclude those of the foundations.
2. The turnstile incorporates two rotors, each with four rotor arms.
3. The turnstile is to be mounted within barriers that offer compatible resistance to forced entry. The turnstile may be mounted centrally or such that the barrier is flush with the front or rear face of the turnstile.
4. The turnstile is configured as 'fail secure'. The resistance of the access control system to "non-mechanical" attack is not covered as it is outside the scope of LPS 1175: Issue 8. Likewise, the approval does not cover possible effects of any susceptibilities relating to the functionality and performance of any access control equipment that may be used to operate the turnstiles. This is because the scope of access control devices and system configurations that may be used with these locking systems is "infinite". It is therefore recommended that specifiers and installers satisfy themselves that the components used are either resistant to mechanical and other forms of tampering / abuse, or that they are suitably protected from such tampering / abuse and are resistant to any environmental conditions / interference that may cause the locking system to disengage.
5. The turnstile is approved when installed and maintained in accordance with the instructions contained on the document titled '1491-200 O&M Manual' Issue 1.1.

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Chris Hunr
Verifier

11 November 2019
Date of Issue

11 November 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


