

## Certificate of Product Approval

Certificate Number: 450ag

Issue: 01

### Technocover Limited (Incorporating TechnoRail & Strataform)

Henfaes Lane  
Welshpool  
Powys  
SY21 7BE



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product

**UltraSecure WCC/DV2**  
wall mounted security cabinet

#### Standard

**LPS 1175: Issue 8**  
Requirements and testing procedures for the LPCB certification and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Paul Dillon  
Verifier

26 January 2021  
Date of Issue

26 January 2021  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 450ag

Issue: 01

Technocover Limited (Incorporating TechnoRail & Strataform)

### Wall Mounted Security Cabinet

Product Name	Type	Nominal Cabinet Height (mm)	Nominal Cabinet Width (mm)	Nominal Cabinet Depth (mm)	Security Rating	LPCB Ref. No.
UltraSecure WCC/DV2	Wall-mounted security cabinet	806	810	330	B3 (SR2)	450ag/01

### Compatible Padlocks

Padlock		Cylinder		'Plus' Rating
Manufacturer	Model	Manufacturer	Model	
Abloy	PL340/25	Abloy	Disclock Pro	+
			High Profile	+
			Novel	+
			Protec	+
			Protec2	+
			Sentry	+
Abloy	PL350/25	Abloy	Disclock Pro	+
			High Profile	+
			Novel	+
			Protec	+
			Protec2	+
			Sentry	+

#### Notes:

1. The UltraSecure WCC/DV2 cabinet achieves the security rating noted for the creation of an aperture through which to pass the 125 mm diameter test block.
2. The compatible Abloy padlocks are approved for use when bearing an alpha-numeric code denoting the date of manufacture as December 2013 or later. Alternatively, the V01 version of the equivalent padlock may be used without undermining the security rating.
3. Certification does not cover the use of padlocks other than those listed above. Utilisation of unlisted padlocks may affect the level of security offered by the product.
4. A 'Plus' rating demonstrates that the cylinder meets the requirements defined in Annex A of BS 3621:2007 or manipulation resistance class '1' defined in LPS 1242: Issue 2.
5. The 'user friendliness' of employing the padlocks listed has not been assessed as this is beyond the scope of LPS 1175: Issue 8.
6. The UltraSecure WCC/DV2 cabinet is approved when installed on to brickwork and blockwork substrates in accordance with the instructions contained in the document titled 'Fitting Instructions Watercress Panel Wall Mounted Cabinet' (Revision D, dated 06/01/15). The approval does not cover the cabinet when mounted to alternative substrates or via intermediate substrates such as render or plasterboard.

This certificate and appendix is maintained and held in force through regular surveillance activities

*P. Dillon*

Signed for BRE Global Ltd.

Paul Dillon  
Verifier

26 January 2021  
Date of Issue

26 January 2021  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**