

Certificate of Product Approval

Certificate Number: 450z

Issue: 01

Technocover Limited (Incorporating TechnoRail & Strataform)

Henfaes Lane
Welshpool
Powys
SY21 7BE



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product

UltraSecure Padlockable Door
hinged security doorsets

Standard

LPS 1175: Issue 8
Requirements and testing procedures for the LPCB certification and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Paul Dillon
Verifier

26 January 2021
Date of Issue

26 January 2021
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 450z

Issue: 01

Technocover Limited (Incorporating TechnoRail & Strataform)

Hinged Security Doorsets

Product Name	Model	Type	Minimum Structural Opening Height (m)	Maximum Structural Opening Height (m)	Minimum Structural Opening Width (m)	Maximum Structural Opening Width (m)	Security Rating	LPCB Ref. No.
Ultrasecure Padlockable Door	DS1/DV4	Single leaf outward opening padlockable hinged security doorset	1.21	2.42	0.515	1.215	D10 (SR4)	450z/01
	DS2/DV4	Double leaf outward opening padlockable hinged security doorset	1.21	2.42	1.215	2.315		

Compatible Padlocks

Padlock Reference	Padlock		Cylinder	
	Manufacturer	Model	Manufacturer	Model
a	Abloy	PL350/25	Abloy	High Profile
b	Abloy	PL350/25	Abloy	Exec
c	Abloy	PL350/25	Abloy	Disklock Pro
d	Abloy	PL350/25	Abloy	Protec
e	Abloy	PL350/25	Abloy	Sentry
f	Abloy	PLLW350/25	Abloy	Cliq
g	Abloy	PLLW639/25	Abloy	Cliq
h	Kaba	K15 – C5	Kaba	K20

Options

Option
Upper louvre vent (200 mm by 220 mm)
Lower louvre vent (200 mm by 220 mm)
Sentinel 'SR4' vision panel (visible area 190 mm by 290 mm)

Notes:

1. This approval covers double leaf doorsets with leaves of equal width.
2. The passive leaf of the DS2/DV4 padlockable doorset incorporates two HSTB barrel bolts.
3. The DS2/DV4 outward opening padlockable hinged security doorset achieves Security Rating D10 (SR4) in the minimum and optimum locked conditions. The minimum locked condition exists when only one barrel bolt is engaged on the passive leaf.

This certificate and appendix is maintained and held in force through regular surveillance activities

P. Dillon

Signed for BRE Global Ltd.

Paul Dillon
Verifier

26 January 2021
Date of Issue

26 January 2021
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 450z Technocover Limited (Incorporating TechnoRail & Strataform)

Issue: 01

4. The resistance of the access control locks and mechatronic cylinders to “non-mechanical” attack is not covered by this approval as they were outside the scope of LPS 1175:Issue 8. Likewise, the approval does not cover possible effects of any susceptibilities relating to the functionality and performance of any access control equipment that may be used to operate these locking systems / cylinders. This is because the scope of access control devices and system configurations that may be used with these locking systems is “infinite”. It is therefore recommended that specifiers satisfy themselves that the components used are either resistant to mechanical and other forms of tampering/abuse, or that they are suitably protected from such tampering/abuse and are resistant to any environmental conditions/interference that may cause the locking system to disengage.
5. Please refer to the manufacturer for more details on the position of the vision panel/louvre vents within the door leaf.
6. Certification does not cover the use of padlocks other than those listed above. Utilisation of unlisted padlocks may affect the level of security offered by the doorset.
7. The Abloy padlocks were only compatible when bearing an alpha-numeric code denoting the date of manufacture as December 2013 or later, or when incorporating the ‘V01’ modifications.

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Paul Dillon
Verifier

26 January 2021
Date of Issue

26 January 2021
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

