

## Certificate of Product Approval

Certificate Number: 682e

Issue: 05

### VENTCROFT LIMITED

Faraday Road  
Astmoor Industrial Estate  
Runcorn  
Cheshire  
WA7 1PE  
UNITED KINGDOM



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
NoBurn XPS

#### Standard(s) (see Appendix for details)

BS 6387:2013 (Category CWZ)  
EN 60754-1:2014  
EN 61034-2:2005+A1:2013  
EN 50200:2015 (Class PH30)  
EN 60332-3-24:2009  
EN 60332-3-25:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Karen Coull  
Certification Scheme Manager

17 July 2019  
Date of Issue

16 January 2015  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB® is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 682e VENTCROFT LIMITED

Issue: 05

Product name					LPCB Ref. No.
NoBurn XPS					682e/01
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction (excluding drain wire and earth)	BS 6387	EN 60754-1	EN 61034-2	EN 50200
1.0 <sup>(1)</sup>	2,3 & 4	C,W,Z	<0.5% HCl	>60%	PH30
1.5 <sup>(1)</sup>	2,3 & 4	C,W,Z	<0.5% HCl	>60%	PH30
2.5 <sup>(1)</sup>	2,3 & 4	C,W,Z	<0.5% HCl	>60%	PH30
4.0 <sup>(2)</sup>	2,3 & 4	C,W,Z	<0.5% HCl	>60%	PH30

### Uo/U 300/500V

#### Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. Where the cable diameter is greater than 12mm the cable is additionally approved to EN 60332-3-24.
4. Where the cable diameter is equal to or less than 12mm the cable is additionally approved to EN 60332-3-25.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd.

Karen Coull  
Certification Scheme Manager

17 July 2019  
Date of Issue

16 January 2015  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.


