

Certificate of Product Approval

Certificate Number: 700e

Issue: 02



JORIS IDE N V

Hille 174
B-8750
Zwevezele
Belgium

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) as detailed below:

Products

Sandwich Panels/Roof Panels
JI Vulcasteel Roof 1000

Standards

LPS 1208: Issue 2.2
LPCB fire resistance requirements for elements of construction used to provide compartmentation.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Chris White
Certification Scheme Manager

17 December 2021
Date of Issue

10 December 2018
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of BRE (the Building Research Establishment Ltd.)



Appendix to Certificate No: 700e JORIS IDE N V

Issue: 02

Product Name	Specification Thickness (mm)	Maximum Unsupported Span (m)	Fire Resistance (min) Integrity / Insulation	Load Bearing Capacity Under Test Conditions (kN/m ³)	Grade	Core Material and Nominal Density (kg/m ³)	LPCB Ref. No.
Jl Vulcasteel roof 1000	80	2095	125/80	0.8	FR60	Mineral wool ≥100	700e/01
Jl Vulcasteel roof 1000	100	2110	140/135	0.8	FR120	Mineral wool ≥100	700e/02
Jl Vulcasteel roof 1000	120	2090	122/122	0.8	FR120	Mineral wool ≥100	700e/03

Notes:

1. LPCB Ref No. 700e/01, 700e/02 and 700e/03 – refer to model specification LPCB U5-2-10 Rev 7 for full details.

Approved Manufacturers

The following companies manufacture the product listed on this certificate. These companies are audited by the LPCB to ensure the product certification requirements are met.

Joris IDE NV (LPCB Ref No: 1455)
Isometal division
Z.I Baraque Fraiture
Route de la Roche
6960 Manhay
Belgium

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd..

Chris White
Certification Scheme Manager

17 December 2021
Date of Issue

10 December 2018
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of BRE (the Building Research Establishment Ltd.)


