

## Certificate of Product Approval

Certificate Number: 913d

Issue: 07

### H S Jackson & Son (Fencing) Limited t/a Jacksons Fencing

Stowting Common  
Ashford  
Kent  
TN25 6BN



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product

**UHS Extreme Mesh SR3**  
**UHS Heavy Mesh SR3**  
security gates

#### Standard

**LPS 1175: Issue 7**  
Requirements and testing procedures for the LPCB approval and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Paul Dillon  
Verifier

2 June 2020  
Date of Issue

18 January 2016  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 913d

Issue: 07

H S Jackson & Son (Fencing) Limited t/a Jacksons Fencing

### Security Gates

Product Name	Type	Height (m)	Minimum Width (m)	Maximum Width (m)	Compatible Locking Systems		Security Rating	LPCB Ref. No.
					Active Leaf	Passive Leaf		
UHS Extreme Mesh SR3	Single leaf inward opening security gate	2.4	0.870	3.0	1	N/A	3	913d/11
	Single leaf outward opening security gate		0.923	1.523				
	Single leaf inward opening padlockable security gate		0.863	3.0	2			
	Single leaf outward opening padlockable security gate		0.916	1.523				
UHS Heavy Mesh SR3	Single leaf inward opening security gate	2.4	0.870	3.0	1	N/A	3	913d/12
	Single leaf outward opening security gate		0.923	1.523				
	Single leaf inward opening padlockable security gate		0.863	3.0	2			
	Single leaf outward opening padlockable security gate		0.916	1.523				

### Compatible Locking Devices

Compatible Locking Device	Manufacturer	Model	Type	Compatible Operating Devices		Compatible Cylinders / Padlocks
				External Face	Internal Face	
1	Locinox	LAKQ U2 lock with SHKL QF keep	Shrouded turn handle key lock	Key and lever handle	Key and lever handle	EVVA A5 DZ27-7KD Euro-profile double cylinder (key:key)
2	H S Jackson & Son (Fencing) Limited	Padlockable slide latch	Sliding bar	Padlock and sliding bar	Padlock and sliding bar	Squire SS50S padlock with Squire 6 pin cylinder

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Paul Dillon  
Verifier

2 June 2020  
Date of Issue

18 January 2016  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




## Appendix to Certificate No: 913d

Issue: 07

### H S Jackson & Son (Fencing) Limited t/a Jacksons Fencing

#### Notes

1. The gates are compatible with the equivalent height fencing systems covered by the scope listed on LPCB certificate 913c (Issue 10).
2. The height of the free-standing barrier is 2.4 metres to comply with the minimum height requirements of a Security Rating 3 classification within LPS 1175: Issue 7. The height of the gate leaf within the free-standing barrier is 2.1 metres.
3. The gates shall be mounted onto flat topography and are available in configurations to suit either surface mounting onto hard surfaces or embedding within concrete foundations placed in the ground. Furthermore, the local ground onto/into which the gate is installed shall offer compatible strength.
4. The gap between the bottom of the gate leaf and the ground must not exceed 50 mm ( $\pm 10$  mm).

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Paul Dillon  
Verifier

2 June 2020  
Date of Issue

18 January 2016  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

