

LPCB Red Book



1 Part: 2 Manual fire extinguishing equipment

bre

Introduction

BRE Global Ltd, based in the UK near London, is an independent third party organisation offering certification of fire, security and sustainability products and services to an international market. LPCB is the certification brand used for fire and security products and services. The LPCB mark is accepted worldwide. We have representative offices in China, India and Dubai. We are owned by the BRE Trust, a not-for-profit organisation.

LPCB listings can be accessed, free of charge, at www.redbooklive.com. BRE Global additionally carries out:

- Fire Investigation
- Fire Risk Assessment
- Fire Safety Engineering
- Research
- Training

LPCB Listings

Listings are given in sections which list related groups of products and services such as suppression, security and so on. Each section also summarises the technical basis for the certification of each product or service. The Red Book listings should always be used in conjunction with rules, regulations and design specifications required by the relevant Authority having jurisdiction.

Listings comprise:

- Fire detection and alarm products, systems, and cables
- Manual fire extinguishing equipment
- Automatic sprinkler, water spray and deluge systems
- Fixed fire fighting products and systems
- Watermist systems
- Related installers
- Passive fire protection products
- Security protection products
- Fire doors and shutters
- Smoke and fire ventilation systems
- SABRE
- Management Systems
- Construction products

Listings are given in the name of the manufacturer or service provider, in alphabetical order. They can be downloaded free of charge from our website at www.redbooklive.com

Updates

Certification of products and services are updated regularly. To ensure that you are using the most up to date information please refer to www.redbooklive.com.

What is Third Party Certification?

A frequent concern of stakeholders is in knowing whether a product will perform in accordance with the stated specifications. These concerns can involve such product attributes as safety, health or environmental impacts, durability, compatibility, suitability for intended purposes or for stated conditions, and other similar considerations. These issues can all be addressed through product certification.

Third party certification is a conformity assessment process, carried out by a body that is independent of both supplier and customer organisations. It provides confirmation that products and services have met and will continue to meet the requirements of specified standards and other normative documents.

FOR SPECIFIERS AND REGULATORS:

LPCB third party product certification schemes are quality assurance schemes and comprise initial type testing and technical evaluation, assessment and surveillance of the manufacturer's quality system and factory production procedures, regular audit testing, labelling and listing.

Similarly, LPCB schemes for suppliers of services (installers) are also quality assurance schemes comprising a technical assessment of an installer's capability, assessment and surveillance of the installer's quality system and production procedures, regular inspection of completed installations and listing.

Benefits of Third Party Certification

For specifiers, regulators, insurers, manufacturers and installers, the benefits of an LPCB approval are:

For specifiers and regulators:

- Risk reduction - specifying LPCB approved products and services demonstrates due-diligence and best endeavour and mitigates against possible accusations of negligence.
- Avoidance of costly mistakes - you can trust LPCB approved products and services to conform each and every time.
- Time - using Red Book Live to search for and assess products and services can save you time.

For manufacturers and installers:

- Increased global sales - LPCB approval is recognised and specified widely throughout the world. In some territories LPCB approval is a mandatory requirement.
- Added value of the product or service - LPCB approved products and services are recognised as providing added value given their ability to conform each and every time.
- Reduced liability - LPCB approved products and services demonstrate due-diligence which can reduce liability for both you and your customers.

What does LPCB Certification offer?

LPCB certification is carried out against Loss Prevention Standards (LPS's). These LPS's include reference to BS, EN or ISO standards as appropriate. LPCB certification are level 5 schemes as detailed in ISO/ IEC 17067 with the added requirement to have a quality system certificated to ISO 9001.

The technical requirements of LPCB schemes are given in the Loss Prevention Standards (LPSs). These documents are drafted by LPCB technical experts in conjunction with appropriate external experts. They are then peer reviewed by representatives from trade bodies, regulators, insurers, specifiers, manufacturers and other suppliers. Finally these documents are approved for use by the BRE Global Governing Body; the Body that oversees all of the certification activities of BRE Global.

Product schemes comprise:

- Initial type testing and evaluation of product.
- Approval and surveillance of the manufacturer's (or supplier's) quality management system to ISO 9001
- Assessment and surveillance of the manufacturer's (or supplier) factory production control system (FPC).
- Periodic audit testing of the product from either the factory or marketplace.
- Labelling or marking as appropriate.
- Listing on Red Book Live

Installer schemes comprise:

- Technical assessment of the installation contractor's capability.
- Approval and surveillance of the contractor's quality management system to ISO 9001 or assessment against the requirements of the relevant Loss Prevention Standard where ISO 9001

FOR SPECIFIERS AND REGULATORS:

- is not appropriate.
- Regular surveillance inspections of on-going installations.
- The issue of Certificates of Conformity by the installer to demonstrate compliance for each installation.
- Listing in the Red Book.

The LPCB Mark - the Mark you can trust

After certification of a product or service the manufacturer or service provider may place the LPCB certification mark, as shown below, on the product, packaging and literature etc.

Where LPCB holds accreditation through the United Kingdom Accreditation Service (UKAS), the certified company may include the UKAS symbol (the Crown and Tick) alongside the LPCB mark for certain applications e.g. promotional literature or material and stationery, as shown below.

(Full details of LPCB accreditation can be found on the UKAS website at www.ukas.com)

Where for reasons of space or cost the use of the above full mark is not practical, then the following simplified mark may be applied directly to the product (for some schemes only). The LPCB scheme rules define how and where the marks can be used.

Part 2

*Manual fire extinguishing
equipment*

MANUAL FIRE EXTINGUISHING EQUIPMENT

INTRODUCTION

Listings in this section include:

Products

- Portable fire extinguishers
- Fire hose reels
- Fire blankets
- Wet landing valves
- Dry landing valves
- Inlet breechings
- Semi rigid hoses
- Lay-flat hoses
- Boxes for dry riser inlets
- Pillar fire hydrants
- Gate valves
- Fire hose couplings and ancillary equipment
- Mobile fire extinguishers
- Hand-held branchpipes

Products are approved in accordance with various standards. The details of these standards are given at the front of each section relevant to the product.

TABLE OF CONTENTS

Boxes for dry riser inlets	2
Dry landing valves	3
Fire blankets	4
Fire hose couplings and ancillary equipment	8
Fire hose reels	11
Gate valves	34
Hand-held Branchpipes	35
Inlet breechings	39
Layflat hoses	43
Mobile fire extinguishers	44
Pillar fire hydrants	51
Portable fire extinguishers	55
Semi rigid hoses	67
Wet landing valves	69

BOXES FOR DRY RISER INLETS

A Dry Riser is an un-charged system of pipe-work and valves installed within a building which enables the Fire Service to pump water to the upper floors of a building when a fire occurs. A dry riser box or cabinet provides protection to dry riser inlets from accidental damage, dirt, dust, vandalism, and rubbish deposits and helps to ensure that the equipment inside stays in the best condition to ensure that a supply of water can be maintained in any fire incident. Regular inspection and maintenance of the box and equipment inside is required.

Dry riser box for riser inlets are tested to BS 5041-5

This section lists products approved in accordance with:

BS 5041-5 - *Boxes for dry riser inlets.*

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463j to BS 5041-5

Boxes for Dry Riser Inlets

Product Name	Model	Size WxH (mm)	LPCB Ref. No.
4" x 2 way	NF-2WDRIC-SM	595 x 395	463j/01
6" x 4 Way	NF-4WDRIC-SM	595 x 595	463j/01
4" x 2 way	NF-2WDRIC-SMA	395 x 595	463j/01
4" x 2 way	NF-2WDRIC-RT	595 x 395	463j/01
6" x 4 Way	NF-4WDRIC-RT	595 x 595	463j/01
4" x 2 way	NF-2WDRIC-RTA	395 x 595	463j/01

DRY LANDING VALVES

A Dry Riser inlet is permanently connected to an uncharged water pipe system that is installed within protected service riser shaft within the building, often this is the protected escape staircase enclosures.

Dry landing valves are located at discharge points, typically on the upper floors of a taller building, Layflat hoses are coupled into the valve to supply water to the location of the fire. The valve is normally located within an easily accessible, protective, and approved box or cabinet to prevent damage, dust, and rubbish collection.

The system components must be regularly maintained to prevent leaks, corrosion, and loss of adequate pressure. Landing valves that are used as part of a dry riser system are tested to BS 5041-2.

This section lists products approved in accordance with:

BS 5041-2 - *Fire hydrant systems equipment. Specification for landing valves for dry risers.*

FIRE BLANKETS

Fire blankets can be used to suppress or extinguish small fires in kitchens, laboratories and workshops and are a useful means of protection. They should be located in the vicinity of the fire hazard on which they are intended to be used and in a position where they can be safely accessed. Fire blankets are suitable for kitchens and laboratory areas where fires tend to be smaller and contained, e.g. cooking oils. Fire blankets that are large enough are considered suitable to be used for smothering persons whose clothes are on fire.

EN 1869 specifies requirements for fire blankets that are not reusable and that are intended for use by one person. The standard applies to fire blankets primarily intended for extinguishing cooking oil type fires. The standard specifies several tests that a fire blanket must successfully undergo, which include: fire tests, a removal and unfolding test and an electrical resistance test.

The materials used in the manufacture of a fire blanket must be heat resisting and non-flammable yet flexible enough to maintain a seal with the vessel on fire so that the oxygen supply is removed. The heat resistance of the fire blanket must also be maintained whilst the heat source is turned off and the heat is allowed to lower with the vessel remaining in-situ until the vessel is safe to be removed.

It is recommended that the blanket has been regularly inspected as part of any risk assessment or safety inspections. A fire blanket notice should be placed near the blanket giving basic guidance on how to use the blanket in an emergency.

Always follow manufacturers use, installation and servicing instructions and replace after use.

This section lists products approved in accordance with:

EN 1869 *Fire blankets*

Aikah Pump Assembly LLC

Ras Al Khor Industrial Area 2, P.O.Box 5804, Dubai, United Arab Emirates

Tel: +971-43478005

E-mail: aikah@emirates.net.ae • Website: www.aikah.com

Certificate No: 1434Fa to EN 1869:2019

'AMNA' Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
AM 1.2m x 1.2m	AM-1212F AM-1212R	Red rectangular woven fabric Red rectangular hard PVC	1434Fa/01
AM 1.2m x 1.8m	AM-1218F AM-1218R	Red rectangular woven fabric Red rectangular hard PVC	1434Fa/02
AM 1.5m x 1.8m	AM-1518F	Red rectangular woven fabric	1434Fa/03

Al Tahadi Security And Safety Equipment Trading

PO Box 45668, Ind. Area 11, Sharjah, United Arab Emirates

Tel: +971 5 0868 4543

E-mail: Sharqawi61@yahoo.com • Website: www.tahadi-fire.com

Certificate No: 1434Da to EN 1869:2019

Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
OM-08 1.2m X 1.2m	OM-08.B1 OM-08.B2	Red rectangular hard PVC Red rectangular woven fabric	1434Da/01
OM-08 1.5m x 1.8m	OM-08.B3	Red rectangular woven fabric	1434Da/03

Bristol Fire Engineering LLC

Al Quoz Industrial Area 3, P.O.Box 74582, Dubai, United Arab Emirates

Tel: +971 4 347 2426

E-mail: sami@bristol-fire.com • Website: www.bristol-fire.com

Certificate No: 1434Ca to EN 1869:2019

FIRE BLANKETS

'BRISTOL' FGC Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
FGC 1.2m x 1.2m	FGC12	Red rectangular hard PVC	1434Ca/01
FGC 1.2m x 1.8m	FGC18	Red rectangular hard PVC	1434Ca/02
FGC 1.5m x 1.8m	FGC28	Red rectangular woven fabric	1434Ca/03

Changshu Jiangnan Glass Fiber Co., Ltd.

No. 19 Xiangyang Road, Haiyu Town, Changshu, Jiangsu, 215519, China

Tel: +86-512-52560588 / +86-512-52561146

E-mail: zhi6739@jn-fiber.cn / zhang1146@jn-fiber.cn • Website: www.jn-grt.com

Certificate No: 1434a to EN 1869:2019

'JIANGNAN' CS08 Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
CS08 1.2m x 1.2m	CS08-1212F CS08-1212R	Red rectangular woven fabric Red rectangular hard PVC	1434a/01
CS08 1.2m x 1.8m	CS08-1218F CS08-1218R	Red rectangular woven fabric Red rectangular hard PVC	1434a/02
CS08 1.5m x 1.8m	CS08-1518F	Red rectangular woven fabric	1434a/03

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 1434Ha to EN 1869:2019

'FIREX' Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
FB 1.2m x 1.2m	FB4	Red rectangular hard PVC	1434Ha/01
FB 1.2m x 1.8m	FB6	Red rectangular hard PVC	1434Ha/02

Eversafe Extinguisher Sdn Bhd

Lot 878, Jalan Subang 9, Taman Perindustrian Subang, Subang Jaya, Selangor Darul Ehsan, 47500, Malaysia

Tel: +603 8024 9898

E-mail: info@eversafe.net • Website: www.eversafe.net

Certificate No: 1434Ba to EN 1869:2019

Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
FB8 1.2m x 1.2m	FB8-22R	Red rectangular hard PVC	1434Ba/01
FB8 1.2m x 1.8m	FB8-28R	Red rectangular hard PVC	1434Ba/02
FB8 1.5m x 1.8m	FB8-58F	Red rectangular woven fabric	1434Ba/03

Fire Inspection Services Pty Ltd

35 The Grove, Coburg, Victoria, 3058, Australia

Tel: +61 411 103 846

E-mail: projects@sfpmena.com

Certificate No: 1434Ja to EN 1869:2019

'FIS MENA' Fire Blankets

Product Name	Type (Size)	Model	Container	LPCB Ref. No.
FIS MENA Fire Blankets	FIS 1.2m x 1.2m	FIS1212-1, FIS1212-2	Red rectangular woven fabric, Red rectangular hard PVC	1434Ja/01
FIS MENA Fire Blankets	FIS 1.2m x 1.8m	FIS1218-1, FIS1218-2	Red rectangular woven fabric, Red rectangular hard PVC	1434Ja/02
FIS MENA Fire Blankets	FIS 1.5m x 1.8m	FIS1518	Red rectangular woven fabric	1434Ja/03

30 Apr 2025

Page 5 of 76

FIRE BLANKETS

Jactone Products Limited

Springvale Business Park, Springvale Avenue, Bilston, West Midlands, WV14 0QL, United Kingdom

Tel: +44 (0)1902 357777

E-mail: sales@jactone.com • Website: www.jactone.com

Certificate No: 783e to EN 1869:2019

Jactone JT510 Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
FBJT1111 (1.1m x 1.1m)	JPR1111 JPW1111 JS1111 JF1111	Red small Jacpack White small Jacpack White square pack Red small flat pack	783e/01
FBJT1212 (1.2m x 1.2m)	JPR1212 JPW1212 JF1212	Red medium Jacpack White medium Jacpack Red small flat pack	783e/02
FBJT1811 (1.8m x 1.1m)	JPR1811 JPW1811 JF1811	Red large Jacpack White large Jacpack Red medium flat pack	783e/03
FBJT1812 (1.8m x 1.2m)	JPR1812 JPW1812 JF1812	Red large Jacpack White large Jacpack Red medium flat pack	783e/04
FBJT180175 (1.8m x 1.75m)	JPR180175 JPW180175 JF180175	Red large Jacpack White large Jacpack Red large flat pack	783e/05

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463c to EN 1869:2019

'NAFFCO' Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
1.1m x 1.1m	NFB 1.2	Red rectangular hard PVC	463c/01
1.2m x 1.2m	NFB 1.4	Red rectangular hard PVC	463c/02
1.2m x 1.8m	NFB 2.1	Red rectangular hard PVC	463c/03

SensorTech Firefighting and Safety Equipment Trading

P.O.Box 231728, Office No. 506, Al Saud Building, Al Qusais – 4, Dubai, United Arab Emirates

Tel: +971 422 323 31

E-mail: info@sensortechuae.com • Website: www.sensortechuae.com

Certificate No: 1434Ea to EN 1869:2019

'WETPLUG' WFB Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
WFB 1.2m x 1.2m	WFB4X4	Red rectangular hard PVC	1434Ea/01
WFB 1.2m x 1.8m	WFB4X6	Red rectangular hard PVC	1434Ea/02
WFB 1.5m x 1.8m	WFB5X6	Red rectangular woven fabric	1434Ea/03

SFFECO GLOBAL FZE

S-10833, Jebel Ali Free Zone, Authority South 1, Dubai, 261318, United Arab Emirates

Tel: +971 4 880 9890

E-mail: info@sffecoglobal.com • Website: www.sffecoglobal.com

Certificate No: 1434Ga to EN 1869:2019

'SFFECO' SFD-FB Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
SFD-FB 1.2m x 1.2m	SFD-FB-1212F SFD-FB-1212P	Red rectangular woven fabric Red rectangular hard PVC	1434Ga/01
SFD-FB 1.2m x 1.8m	SFD-FB-1218F SFD-FB-1218P	Red rectangular woven fabric Red rectangular hard PVC	1434Ga/02

FIRE BLANKETS

SFD-FB 1.5m x 1.8m

SFD-FB-1518F

Red rectangular woven fabric

1434Ga/03

Shanghai Huiying Industry Co Ltd

Room 1313, Tower A, 1088 New Jinqiao Road, 201206, Shanghai, China

Tel: +86 21 61681700

E-mail: sales@pike-fire.com • Website: www.pike-fire.com

Certificate No: 1434Aa to EN 1869:2019

'PIKE' PK8 Fire Blankets

Product Name	Model	Container	LPCB Ref. No.
PK8 1.2m x 1.2m	PK8-S1212 PK8-H1212	Red rectangular woven fabric Red rectangular hard PVC	1434Aa/01
PK8 1.2m x 1.8m	PK8-S1218 PK8-H1218	Red rectangular woven fabric Red rectangular hard PVC	1434Aa/02
PK8 1.5m x 1.8m	PK8-S1518	Red rectangular woven fabric	1434Aa/03

SIBCA Electronic Equipment Co. Limited

SIBCA Building – Behind Etisalat Main Building, Khalidiya, P.O. Box 46944, Abu Dhabi, United Arab Emirates

Tel: +971 2 4978600

E-mail: guard@sibca.com • Website: www.sibca.com

Certificate No: 1434Ia to EN 1869:2019

'SIBCA' Fire Blankets

Product Name	Type (Size)	Model	Container	LPCB Ref. No.
'SIBCA' Fire Blanket	GN08 1.2m x 1.2m	GN-0601 GN-0602	Red rectangular woven fabric. Red rectangular hard PVC	1434Ia/01
'SIBCA' Fire Blanket	GN08 1.2m x 1.8m	GN-0603 GN-0604	Red rectangular woven fabric. Red rectangular hard PVC	1434Ia/02
'SIBCA' Fire Blanket	GN08 1.5m x 1.8m	GN-0605	Red rectangular woven fabric	1434Ia/03

FIRE HOSE COUPLINGS AND ANCILLARY EQUIPMENT

Fire hose couplings and ancillary equipment are intended for fire service use.

This section lists products approved in accordance with:

BS 336 - *Specification for fire hose couplings and ancillary equipment.*

Delivery hose couplings;

Are instantaneous pattern couplings, either male or female combined with a hose tail, fitted with pull-release or twist-release mechanism. Intended for fitment of a delivery hose of appropriate size, so enabling the delivery hose to connect to fire service equipment fitted with appropriate instantaneous pattern coupling or connector.

Standpipes;

Capable of engagement to an underground fire hydrant conforming to BS 750, enabling aboveground operation. Consisting of a shaft fitted with an instantaneous delivery hose coupling or a gland allowing continuous rotation of the swivel head. Swivel head containing outlet(s) fitted with instantaneous pattern female connector(s), anti-siphon facility fitted as necessary. Intended for fitment to delivery hose and fire service equipment with appropriate instantaneous pattern coupling.

Hydrant keys and bars;

Intended for use on underground hydrant valves conforming to BS 750, enabling above ground operation.

Note:

Unless otherwise specified by the purchaser, blank plugs for standpipes are non-vented. If venting is required it should be in accordance with BS 5041-1 and BS 5041-2.

Gulf Fire Fighting Equipments FZE

Plot No: S3118, Jebel Ali Free Zone, Dubai, United Arab Emirates

Tel: +971 48807127

E-mail: info@gulffireco.com • Website: www.gulffireco.com

Certificate No: 1153Wf to BS 336:2010

GULF FIRE' Delivery Hose Couplings

Product Name	Description	LPCB Ref. No.
GF-QC70A	2½" aluminium (LM25) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153Wf/01
GF-QC65A	2½" aluminium (LM25) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153Wf/02
GF-QC40A	2½" aluminium (LM25) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153Wf/05
GF-QC50A	2½" aluminium (LM25) delivery hose coupling with a 2" (51 mm) ribbed tails	1153Wf/03
GF-QC45A	2½" aluminium (LM25) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153Wf/04
GF-QC70G	2½" copper alloy (CC491K) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153Wf/06
GF-QC50G	2½" copper alloy (CC491K) delivery hose coupling with a 2" (51 mm) ribbed tails	1153Wf/08
GF-QC65G	2½" copper alloy (CC491K) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153Wf/07
GF-QC45G	2½" copper alloy (CC491K) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153Wf/09
GF-QC40G	2½" copper alloy (CC491K) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153Wf/10
GF-QC70B	2½" copper alloy (CW617N) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153Wf/11
GF-QC65B	2½" copper alloy (CW617N) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153Wf/12
GF-QC50B	2½" copper alloy (CW617N) delivery hose coupling with a 2" (51 mm) ribbed tails	1153Wf/13
GF-QC45B	2½" copper alloy (CW617N) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153Wf/14
GF-QC40B	2½" copper alloy (CW617N) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153Wf/15

MOBIK S.A.

96-98 M. Mpotsari St, Chania, Crete, 73136, Greece

Tel: +30 28210 63222

E-mail: sales@mobiak.gr • Website: http://www.mobiak.gr

Certificate No: 1153Af to BS 336:2010

'MOBIK' Delivery Hose Couplings

Product Name	Description	LPCB Ref. No.
30 Apr 2025		Page 8 of 76

FIRE HOSE COUPLINGS AND ANCILLARY EQUIPMENT

MBK08-201A-00	2½" aluminium (LM25) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153Af/01
MBK08-201A1-00	2½" aluminium (LM25) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153Af/02
MBK08-201A2-00	2½" aluminium (LM25) delivery hose coupling with a 2" (51 mm) ribbed tails	1153Af/03
MBK08-201A3-00	2½" aluminium (LM25) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153Af/04
MBK08-201A4-00	2½" aluminium (LM25) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153Af/05
MBK08-201B-00	2½" copper alloy (CC491K) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153Af/06
MBK08-201B1-00	2½" copper alloy (CC491K) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153Af/07
MBK08-201B2-00	2½" copper alloy (CC491K) delivery hose coupling with a 2" (51 mm) ribbed tails	1153Af/08
MBK08-201B3-00	2½" copper alloy (CC491K) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153Af/09
MBK08-201B4-00	2½" copper alloy (CC491K) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153Af/10
MBK08-201C-00	2½" copper alloy (CW617N) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153Af/11
MBK08-201C1-00	2½" copper alloy (CW617N) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153Af/12
MBK08-201C2-00	2½" copper alloy (CW617N) delivery hose coupling with a 2" (51 mm) ribbed tails	1153Af/13
MBK08-201C3-00	2½" copper alloy (CW617N) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153Af/14
MBK08-201C4-00	2½" copper alloy (CW617N) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153Af/15

NewAge Fire Fighting Co. Ltd.

Plot No. 86, 87, 93, 94, GIDC Phase-I, LMS Compound, Wadhwan city , Gujarat, 363030, India

Tel: +91 9825 063781 • Alt Tel: +91 2752 288000

E-mail: info@newage-india.in • Website: www.newage-india.in

Certificate No: 1842a to BS 336:2010

'NEWAGE' Delivery Hose Couplings 1842a

Product Name	Description	LPCB Ref. No.
NFFCL-CP-IS-AL	2½" aluminium (LM25) delivery hose coupling with 2½" (64 mm) ribbed tails	1842a/01

Ningbo Kaixuan Fire Control Equipment Co., Ltd.

No. 999 Zhonghe Road, Huangjiabu Town, Yuyao City, Zhejiang Province, 315466, China

Tel: +86 574 62025710

E-mail: info@kaixuanfire.com • Website: www.kaixuanfire.com

Certificate No: 1153f to BS 336:2010

Delivery hose couplings

Product Name	Description	LPCB Ref. No.
KX08-201A-00	2½" aluminium (LM25) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153f/01
KX08-201A1-00	2½" aluminium (LM25) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153f/02
KX08-201A2-00	2½" aluminium (LM25) delivery hose coupling with a 2" (51 mm) ribbed tails	1153f/03
KX08-201A3-00	2½" aluminium (LM25) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153f/04
KX08-201A4-00	2½" aluminium (LM25) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153f/05
KX08-201B-00	2½" copper alloy (CC491K) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153f/06
KX08-201B1-00	2½" copper alloy (CC491K) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153f/07
KX08-201B2-00	2½" copper alloy (CC491K) delivery hose coupling with a 2" (51 mm) ribbed tails	1153f/08
KX08-201B3-00	2½" copper alloy (CC491K) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153f/09
KX08-201B4-00	2½" copper alloy (CC491K) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153f/10
KX08-201C-00	2½" copper alloy (CW617N) delivery hose coupling with a 2¾" (70 mm) ribbed tails	1153f/11
KX08-201C1-00	2½" copper alloy (CW617N) delivery hose coupling with a 2½" (64 mm) ribbed tails	1153f/12
KX08-201C2-00	2½" copper alloy (CW617N) delivery hose coupling with a 2" (51 mm) ribbed tails	1153f/13
KX08-201C3-00	2½" copper alloy (CW617N) delivery hose coupling with a 1¾" (45 mm) ribbed tails	1153f/14
KX08-201C4-00	2½" copper alloy (CW617N) delivery hose coupling with a 1½" (38 mm) ribbed tails	1153f/15

Certificate No: 1153g to BS 336:2010

Standpipes

Product Name	Description	LPCB Ref. No.
Model KX08-058-00	Single outlet aluminium standpipe	1153g/16
Model KX08-059-00	Double outlet aluminium standpipe	1153g/17

FIRE HOSE COUPLINGS AND ANCILLARY EQUIPMENT

Shah Bhogilal Jethalal & Brothers

72, Siddhi Vinayak Estate, Opp. Ramdev Kitchen Express, Santej-Vadsar Road, Village : Santej, Taluka : Kalol, District : Gandhinagar, Gujarat, 382721, India

Tel: +91 2764 268612 to 15

E-mail: info@aaagindia.in • Website: www.aaagindia.in

Certificate No: 1584c to BS 336:2010

'AAAG' Delivery Hose Couplings

Product Name	Description	LPCB Ref. No.
G130-BS	2½" copper alloy (CC491K) delivery hose coupling with 2½" (64 mm) tails	1584c/01

FIRE HOSE REELS

Fire Hose Reels should be selected, sited, serviced and maintained in accordance with the relevant code of practice.

Hose reels are manufactured as:

- Fixed, swinging arm, swinging pipe or swinging door;
- Automatic or manual valve;
- 19 mm, 25mm or 33 mm bore hose.

They are normally approved for use to be located in a protective easily accessible cabinet to give protection from unauthorised interference, dust, rubbish etc.

A fully extended semi rigid fire hose is up to 30 meters long, red in colour and round in section and is intended to provide a controlled supply of water to combat a potential fire risk quickly without having to set up lengths of lay flat hose from another source. This is achieved via a control nozzle attached to the end of the hose which enables a single operator to control the direction and flow of water to the fire. Its semi rigid construction is flexible and durable, which helps to prevent kinks that would restrict the water supply.

Hose reels help to ensure that escape routes can be maintained and are often located in larger areas or corridors where a fire extinguisher does not provide sufficient cover. If appropriate to the risk the hose reel may also be used to fight the fire in its early stages.

In some countries layflat hose (which has a larger bore than semi rigid hose) may also be used in a similar manner to a conventional hose reel. The layflat hose, typically 30 metres in length, is located in a cupboard containing a hanging rack and a manual or automatic valve connection to a suitable water supply. The layflat hose system is installed in a fixed location within a building, ensuring a fast and easily available source of larger quantities of water. A branch or nozzle is also supplied to control the water distribution.

This section lists products approved in accordance with:

- EN 671-1 *Hose reels with semi-rigid hose*;
- EN 671-2 *Hose systems with lay-flat hose*.

Al Arabia for Safety & Security LLC

P.O.Box 60204, Dubai, United Arab Emirates

Tel: +971 4203 7348

E-mail: firenet@al-majid.com • Website: www.alarabiasafetysecurity.com

Certificate No: 1153Ya to EN 671-1:2012

'JAM GUARD' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
JG-HRA-1	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Ya/01
JG-HRA-2	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Ya/12

Al Rayan Security & Safety Trading

Al Qusais Industrial Area 4, PO Box 52257, Dubai, United Arab Emirates

Tel: 00971 04 252 5333

E-mail: rayandxb@eim.ae • Website: www.alrayandxb.com

Certificate No: 1153Ua to EN 671-1:2012

'SECURE' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
SE06-172-00	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Ua/01
SE06-173-00	Manual, fixed, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Ua/02
SE06-173B-00	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Ua/05

FIRE HOSE REELS

Al Tahadi Security And Safety Equipment Trading

PO Box 45668, Ind. Area 11, Sharjah, United Arab Emirates

Tel: +971 5 0868 4543

E-mail: Sharqawi61@yahoo.com • Website: www.tahadi-fire.com

Certificate No: 1038Ra to EN 671-1

Tahadi Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
TSS-08-A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Ra/01
TSS-07-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ra/02
TSS-06-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ra/04

Alfurat for Modern Systems

2 Metwaly Alshaarawy St, Al Hay Al Asher, Nasr City, Cairo, Egypt

Tel: +202 23822943

E-mail: sales@alfurat-eg.com • Website: www.alfurat-eg.com

Certificate No: 1153Za to EN 671-1:2012

'AL FURAT' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FHR-M	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Za/10
FHR-A	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Za/12

Armor Safety & Security Ltd

120 Baker Street, London, W1U 6TU, United Kingdom

Tel: +971506531199

Website: www.armorsafety.org

Certificate No: 1092Nd to EN 671-1:2012

'Armor' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
ARM-HR2530	Swinging, automatic, wall mounted	25	30	Rotary operated spray	1092Nd/07

Bahri & Mazroei Technical Systems Co. LLC

BMTC Building, PO Box 1247, Al Khabaisi, Dubai, United Arab Emirates

Tel: +971 4 269 9051

E-mail: Svetlana.Kostetskaya@rewire-intl.com • Website: www.bmts.ae

Certificate No: 1153Pa to EN 671-1:2012

'URANUS' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
BMUHR-AS2530	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Pa/01

FIRE HOSE REELS

Beijing Synergy Technology Co., Ltd

b-1901, Tian Yuan Gang, No. 2 Dongsanhuan North, Chaoyang, Beijing, 100027, China

Tel: +86 10 64680818

E-mail: export@synergyindustry.com • Website: www.synergyindustry.com

Certificate No: 1038AJa to EN 671-1:2012

'SNG' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
SNG07-03A - 'SNG' Fire Hose Reel	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AJa/01
SNG07-03B - 'SNG' Fire Hose Reel	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AJa/02
SNG07-03C - 'SNG' Fire Hose Reel	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AJa/03
SNG07-03D - 'SNG' Fire Hose Reel	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AJa/04
SNG07-02D - 'SNG' Fire Hose Reel	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038AJa/05
SNG07-04A - 'SNG' Fire Hose Reel	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AJa/06
SNG07-04B - 'SNG' Fire Hose Reel	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AJa/07
SNG07-02C - 'SNG' Fire Hose Reel	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AJa/12
SNG07-02A - 'SNG' Fire Hose Reel	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AJa/13
SNG07-02B - 'SNG' Fire Hose Reel	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AJa/14
SNG07-04C - 'SNG' Fire Hose Reel	Automatic, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AJa/17
SNG07-02E - 'SNG' Fire Hose Reel	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AJa/18
SNG07-04D - 'SNG' Fire Hose Reel	Automatic, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AJa/19

BETA Corporation s.r.o

Slavojova 579/9, Prague 2, Nusle, 128 00, Czech Republic

Tel: +420 721 554 641

E-mail: info@betacorporation.eu • Website: www.betacorporation.eu

Certificate No: 1038Xa to EN 671-1:2012

BETA Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
BETA-01	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Xa/01
BETA-02	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Xa/02
BETA-03	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038Xa/05

Bonfire Safety Equipment Trading L.L.C

601 Saheel Tower 1, Al Nahda, Dubai, United Arab Emirates

Tel: +971526574824

E-mail: sales@bonfireuae.ae • Website: www.bonfireuae.ae

Certificate No: 1038BHa to EN 671-1:2012

'BON FIRE' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
BNFHRRMB07	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BHa/02
BNFHRRAB06	Automatic, swinging arm, cabinet or wall	25	30	Lever operated jet only or rotary operated	1038BHa/04

FIRE HOSE REELS

mounted

jet/spray

Brake Fire Safety and Security

Building 8, Industrial Area / 1 Amman Street, Ajman, United Arab Emirates

Tel: +971 551 668 286

E-mail: info@brakefiregcc.com • Website: www.brakefiregcc.com

Certificate No: 1038BBa to EN 671-1:2012

'BRAKE FIRE' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
BFHR-19-M	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BBa/01
BFHR-25-M	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BBa/02
BFHR-19-A	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BBa/03
BFHR-25-A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BBa/04

Bristol Fire Engineering LLC

Al Quoz Industrial Area 3, P.O.Box 74582, Dubai, United Arab Emirates

Tel: +971 4 347 2426

E-mail: sami@bristol-fire.com • Website: www.bristol-fire.com

Certificate No: 1038APa to EN 671-1:2012

'BRISTOL' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
BF-MS-003N	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038APa/01
BF-MS-001N	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038APa/02
BF-AS-004N	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038APa/03
BF-AS-002N	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038APa/04

C-fire nv

Frank van Dyckelaan 3, B-9140, Temse, Belgium

Tel: +32 (0)3 710 69 01

E-mail: info@c-fire.eu • Website: www.c-fire.eu

Certificate No: 1038AYa to EN 671-1:2012

'C fire' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
CF-BHVB-20/19	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AYa/01
CF-BHVB-30/25	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AYa/02
CF-BHV-20/19	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AYa/06
CF-BHV-30/25	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AYa/07

FIRE HOSE REELS

COFFCO

PO Box 5, Pincode - 678002, India

Tel: +914912908940

E-mail: coffcoindia@gmail.com • Website: www.coffcofire.com

Certificate No: 1092Hd to EN 671-1

COFFCO Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
CFFHRFA19	Fixed, automatic, wall mounted	19	30	Rotary operated spray	1092Hd/01
CFFHRFM19	Fixed, manual, wall mounted	19	30	Rotary operated spray	1092Hd/02
CFFHRSA19	Swinging, automatic, wall mounted	19	30	Rotary operated spray	1092Hd/03
CFFHRSM19	Swinging, manual, wall mounted	19	30	Rotary operated spray	1092Hd/04
CFFHRFA25	Fixed, automatic, wall mounted	25	30	Rotary operated spray	1092Hd/05
CFFHRFM25	Fixed, manual, wall mounted	25	30	Rotary operated spray	1092Hd/06
CFFHRSA25	Swinging, automatic, wall mounted	25	30	Rotary operated spray	1092Hd/07
CFFHRSM25	Swinging, manual, wall mounted	25	30	Rotary operated spray	1092Hd/08

Certificate No: 1127Da to EN 671-1:2012

'COFFCO' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
CFHRA25	Automatic, swinging arm, wall mounted	25	30	Rotary operated jet/spray	1127Da/01
CFHRM25	Manual, swinging arm, wall mounted	25	30	Rotary operated jet/spray	1127Da/02
CFHRF25	Manual, fixed, wall mounted	25	30	Rotary operated jet/spray	1127Da/03
CFHRA19	Automatic, swinging arm, wall mounted	19	30	Rotary operated jet/spray	1127Da/04
CFHRM33	Manual, swinging arm, pillar or wall mounted	33	30	Rotary operated jet/spray or lever operated jet/spray	1127Da/07
CFHRF19	Manual, fixed, wall mounted	19	30	Rotary operated jet/spray	1127Da/06
CFHRM19	Manual, swinging arm, wall mounted	19	30	Rotary operated jet/spray	1127Da/05

Crico Engineering

Zuiddijk 10, 8340 Damme, Belgium

Tel: +32 (0)475 834 835

E-mail: info@crico-engineering.com • Website: www.crico.be

Certificate No: 1038Wa to EN 671-1:2012

Crico Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
AQUASPRAY 20S	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Wa/01
AQUASPRAY 30S	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Wa/02
AQUASPRAY 20F	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Wa/06
AQUASPRAY 30F	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Wa/07
AQUAJET MP33	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038Wa/05
AQUAJET MP25	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Wa/12

Crico Norway Ltd

Urnsis Veg 12, Jessheim, 2066, Norway

Tel: +32 475 834 835

E-mail: Christian@crico.no • Website: https://www.crico.no/

Certificate No: 1038BJc to EN 671-1:2012

'Crico' Fire Hose Reels

30 Apr 2025

Page 15 of 76

FIRE HOSE REELS

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
HR - Norway 30M x ¾"	Manual, swinging door, cabinet mounted	19	30	Rotary operated jet/spray	1038BJc/01

Demco Industries Sdn. Bhd.

Lot 3928, Jalan Keretapi Lama, Off Jalan Kapar 5 ½ Miles, Klang, Selangor Darul Ehsan, 42100, Malaysia

Tel: +60 3 3290 3333

E-mail: sales@demcoalarm.com • Website: www.demcoalarm.com

Certificate No: 1038ASa to EN 671-1:2012

'DEMCO' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
D-808-19	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038ASa/01
D-807-25	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ASa/02
D-810-19	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038ASa/03
D-806-25	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ASa/04

Dimex Protection NV

Lozen Boer, Bedrijvenlaan 14, B-9080 Lochristi, Belgium

Tel: +32 (0)9 233 45 50

E-mail: info@dimexprotection.be • Website: www.dimexprotection.be

Certificate No: 1038ANa to EN 671-1:2012

'DIMEX PROTECTION' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
DP 20S	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038ANa/01
DP 30S	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ANa/02
DP 20F	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038ANa/06
DP 30F	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ANa/07

EMACO GLOBAL LLC

3118 Beckett Way, Lakeland, FL 33810, USA

Tel: +1 (516) 288-8935

E-mail: info@emacoglobal.com • Website: www.emacoglobal.com

Certificate No: 1038ALa to EN 671-1:2012

'EMACO' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
E0161-08-A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038ALa/01
E0161-07-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ALa/02
E0161-10-B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038ALa/03
E0161-06-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ALa/04

FIRE HOSE REELS

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 863h to EN 671-1:2012

Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FX/HR/A25	Automatic, swinging arm, twist jet brass rotary nozzle, mild steel reels	25	30	jet/spray	863h/01

EUROFEU

12 Rue Albert Remy, Senonches, 28250, France

Tel: +33 82090 1818

Website: www.eurofeu.fr

Certificate No: 1127Aa to EN 671-1:2012

'EUROFEU' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
ERF3330P	Manual, swinging arm, pillar or wall mounted	33	30	Rotary operated jet/spray or lever operated jet/spray	1127Aa/07
ERF2530AP	Automatic, swinging arm, wall mounted	25	30	Rotary operated jet/spray	1127Aa/01
ERF2530P	Manual, swinging arm, wall mounted	25	30	Rotary operated jet/spray	1127Aa/02
ERF2530F	Manual, fixed, wall mounted	25	30	Rotary operated jet/spray	1127Aa/03
ERF1920P ERF1930P	Manual, swinging arm, wall mounted	19	30	Rotary operated jet/spray	1127Aa/05
ERF1920F ERF1930F	Manual, fixed, wall mounted	19	30	Rotary operated jet/spray	1127Aa/06

Eversafe Extinguisher Sdn Bhd

Lot 878, Jalan Subang 9, Taman Perindustrian Subang, Subang Jaya, Selangor Darul Ehsan, 47500, Malaysia

Tel: +603 8024 9898

E-mail: info@eversafe.net • Website: www.eversafe.net

Certificate No: 734a to EN 671-1

Fire Hose Reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle type	LPCB Ref. No.
EE-CSJR-08	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	19	30	Lever operated jet only or rotary operated jet/spray	734a/01
EE-CSJR-07	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	25	30	Lever operated jet only or rotary operated jet/spray	734a/02
EE-CSJR-10	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	19	30	Lever operated jet only or rotary operated jet/spray	734a/03
EE-CSJR-06	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	25	30	Lever operated jet only or rotary operated jet/spray	734a/04
EE-CSJR-01	Manual, swinging arm, wall mounted, rotary operated nozzle	33	30	Rotary operated jet/spray	734a/05
FS-CSJR-08	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	19	30	Lever operated jet only or rotary operated jet/spray	734a/06
FS-CSJR-07	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	25	30	Lever operated jet only or rotary operated jet/spray	734a/07
FS-CSJR-10	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	19	30	Lever operated jet only or rotary operated jet/spray	734a/08
FS-CSJR-06	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	25	30	Lever operated jet only or rotary operated jet/spray	734a/09
FS-CSJR-01	Manual, swinging arm, wall mounted, rotary operated nozzle	33	30	Rotary operated jet/spray	734a/10
RP-CSJR-08	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	19	30	Lever operated jet only or rotary operated jet/spray	734a/11
RP-CSJR-07	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	25	30	Lever operated jet only or rotary operated jet/spray	734a/12
RP-CSJR-10	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	19	30	Lever operated jet only or rotary operated jet/spray	734a/13

FIRE HOSE REELS

RP-CSJR-06	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	25	30	Lever operated jet only or rotary operated jet/spray	734a/14
RP-CSJR-01	Manual, swinging arm, wall mounted, rotary operated nozzle	33	30	Rotary operated jet/spray	734a/15

Falcon Gold General Trading L.L.C

First Floor Office #128, Al Wasl Building, Shiekh Zayed Road, Al Wasl, Dubai, United Arab Emirates

Tel: +971525051651

E-mail: info@falcon-gold.com • Website: www.falcon-gold.com

Certificate No: 1038Bla to EN 671-1:2012

'Falcon Gold' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FG-651HR	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Bla/02

Fire Control Protection Systems

P.O Box:9428, Jurf Industrial Area 1, Ajman, United Arab Emirates

Tel: +971 56 401 8883

E-mail: carolyn@firecps.com • Website: www.firecps.com

Certificate No: 1038BCa to EN 671-1:2012

'FRONTIER' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FRNHR-01M	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BCa/02
FRNHR-02A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BCa/04

Fire Fighter CO Security and Safety Equipment Trading LLC

Al Qusais Industry Area 4, P O Box 84926, Dubai, United Arab Emirates

Tel: 00971-4-2554494

E-mail: mutasem@firefighterco1.ae

Certificate No: 1038AUa to EN 671-1:2012

'FST' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FST-08	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AUa/01
FST-07	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AUa/02
FST-10	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AUa/03
FST-06	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AUa/04

Fire Inspection Services Pty Ltd

35 The Grove, Coburg, Victoria, 3058, Australia

Tel: +61 411 103 846

E-mail: projects@sfpmena.com

Certificate No: 1038BKa to EN 671-1:2012

'FIS MENA' Fire Hose Reels

30 Apr 2025

Page 18 of 76

FIRE HOSE REELS

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FIS-08-A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BKa/01
FIS-07-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BKa/02
FIS-10-B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BKa/03
FIS-06-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BKa/04

Fire King Security and Safety Equipment

Al Juwais Main Road, Ras Al Khaimah, United Arab Emirates

Tel: +971 7 2437050

E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1092Md to EN 671-1:2012

'FireKing' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FKSA19	Swinging, automatic, wall mounted	19	30	Rotary operated spray	1092Md/03
FKSM19	Swinging, manual, wall mounted	19	30	Rotary operated spray	1092Md/04
FKSA25	Swinging, automatic, wall mounted	25	30	Rotary operated spray	1092Md/07
FKSM25	Swinging, manual, wall mounted	25	30	Rotary operated spray	1092Md/08

Fireguard Global Ltd.

Unit 11 Chancel Industrial Estate, Newhall Street, Willenhall, West Midlands, WV13 1NX, United Kingdom

Tel: +44 (0)8450 751042

E-mail: info@fireguard-uk.com • Website: www.fireguard-uk.com

Certificate No: 1038Ba to EN 671-1:2012

Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FGHR-1930M	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Ba/01
FGHR-2530M	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ba/02
FGHR-1930A	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Ba/03
FGHR-2530A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ba/04
Pulsor-1930M	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Ba/05
Pulsor-2530M	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ba/06
Pulsor-1930A	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Ba/07
Pulsor-2530A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ba/08

FIRPROSAF BV

Hoge Akker 37, Wevelgem, 8560, Belgium

Tel: +32 473 285 446

E-mail: info@firprosaf.be • Website: www.firprosaf.be

Certificate No: 1038BLa to EN 671-1:2012

'FIRPROSAF' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FIRPROJET20Z	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BLa/01

FIRE HOSE REELS

FIRPROJET30Z	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BLa/02
FIRPROJET20V	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BLa/06
FIRPROJET30V	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BLa/07

Fullblaze Middle East

Zarqa Free Zone, New Expansionist Area, P.O.Box 922054, Amman, 11192, Jordan

Tel: +962 6 489 3373

E-mail: info@fullblaze-me.com • Website: www.fullblaze-me.com

Certificate No: 1092Ed to EN 671-1:2012

Fullblaze Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FB-SA25	Swinging, automatic, wall mounted, rotary operated nozzle	25	30	Rotary operated spray	1092Ed/07
FB-SM25	Swinging, manual, wall mounted, rotary operated nozzle	25	30	Rotary operated spray	1092Ed/08

GENCO for Electro-Mechanical Systems L.L.C

76 Makram Ebaid St, Nasr City, Cairo, Egypt

Tel: +20122 89 32321

E-mail: genco@genco-eg.com • Website: www.genco-eg.com

Certificate No: 1038ARa to EN 671-1:2012

Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
GENCO GEN-ASP-A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ARa/04
GENCO GEN-MSP-M	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ARa/14

Lichfield Fire & Safety Equipment Co. Ltd

Unit 8, Calibre Industrial Park, Laches Close, Four Ashes, Wolverhampton, WV10 7DZ, United Kingdom

Tel: +44 (0) 1902 798 706

E-mail: info@lifeco-uk.com • Website: www.lifeco-uk.com

Certificate No: 1038BFa to EN 671-1:2012

Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
LF-MA19	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/01
LF-MA25	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/02
LF-AA19	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/03
LF-AA25	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/04
LF-MF19	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/06
LF-MF25	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/07
LF-MP19	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/08
LF-AP19	Automatic, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/09
LF-MP25	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/10

FIRE HOSE REELS

LF-AP25	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/11
LF-AF19	Automatic, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/17
LF-AF25	Automatic, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/19

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building, 738471, Singapore

Tel: +65 6759 4163

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501b to BS EN 671-1

'Combat' Fire Hose Reels

Product Name	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle Type	LPCB Ref. No.
'Combat' model HR-1SW manual swinging hose reel	25	30	Jet, spray	501b/01
'Combat' model AHR-1SW automatic universal swinging hose reel	25	30	Jet, spray	501b/02
'Combat' model HR-19AS automatic swinging slim hose reel	19	30	Jet	501b/03
'Combat' model HR-1AF automatic fixed slim hose reel	25	30	Jet, spray	501b/04
'Combat' model HR-1AS automatic swinging slim hose reel	25	30	Jet, spray	501b/05
'Combat' model HR-1ASF automatic fixed super slim hose reel	25	30	Jet, spray	501b/06
'Combat' model HR-1MF manual fixed slim hose reel	25	30	Jet, spray	501b/07
'Combat' model HR-1MS manual swinging slim hose reel	25	30	Jet, spray	501b/08
'Combat' model HR-1MSF manual fixed super slim hose reel	25	30	Jet, spray	501b/09
'Combat' model HR-1SSW manual swinging slim hose reel	25	30	Jet, spray	501b/10
'Combat' model HR-1SWS manual swinging hose reel	25	30	Jet, spray	501b/11
'Combat' model HR0287 manual, titanium valve, stainless steel drum and swing arm hose reel	25	30	Jet, spray	501b/12
'Combat' model HR0288 manual, titanium valve, stainless steel drum and swing arm hose reel	33	30	Jet, spray	501b/13
'Combat' model HR0279 manual, bronze valve, stainless steel drum and swing arm hose reel	25	30	Jet, spray	501b/14
'Combat' model HR0281 manual, bronze valve, stainless steel drum and swing arm hose reel	33	30	Jet, spray	501b/15
'Combat' model HR0278 manual, bronze valve, mild steel drum and swing arm hose reel	25	30	Jet, spray	501b/16
'Combat' model HR0280 manual, bronze valve, mild steel drum and swing arm hose reel	33	30	Jet, spray	501b/17

Certificate No: 501b to BS EN 671-1

'Q Fire' Fire Hose Reels

Product Name	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle Type	LPCB Ref. No.
'Q Fire' model QF-19AS automatic swinging slim hose reel	19	30	Jet	501b/03
'Q Fire' model QF-1AF automatic fixed slim hose reel	25	30	Jet	501b/04
'Q Fire' model QF-1AS automatic swinging slim hose reel	25	30	Jet	501b/05
'Q Fire' model QF-1ASF automatic fixed super slim hose reel	25	30	Jet	501b/06
'Q Fire' model AQF-1SW automatic universal swinging hose reel	25	30	Jet	501b/02
'Q Fire' model QF-1MF manual fixed slim hose reel	25	30	Jet	501b/07
'Q Fire' model QF-1MS manual swinging slim hose reel	25	30	Jet	501b/08
'Q Fire' model QF-1MSF manual fixed super slim hose reel	25	30	Jet	501b/09
'Q Fire' model QF-1SSW manual swinging slim hose reel	25	30	Jet	501b/10
'Q Fire' model QF-1SW manual swinging hose reel	25	30	Jet	501b/01
'Q Fire' model QF-1SWS manual swinging hose reel	25	30	Jet	501b/11

Certificate No: 501b to BS EN 671-1

'Will' Fire Hose Reels

Product Name	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle Type	LPCB Ref. No.
30 Apr 2025				Page 21 of 76

FIRE HOSE REELS

'Will' model WEN-19AS automatic swinging slim hose reel	19	30	Jet	501b/03
'Will' model WEN-1AF automatic fixed slim hose reel	25	30	Jet	501b/04
'Will' model WEN-1AS automatic swinging slim hose reel	25	30	Jet	501b/05
'Will' model WEN-1ASF automatic fixed super slim hose reel	25	30	Jet	501b/06
'Will' model WEN1-04 automatic universal swinging hose reel	25	30	Jet	501b/02
'Will' model WEN-1MF manual fixed slim hose reel	25	30	Jet	501b/07
'Will' model WEN-1MS manual swinging slim hose reel	25	30	Jet	501b/08
'Will' model WEN-1MSF manual fixed super slim hose reel	25	30	Jet	501b/09
'Will' model WEN-1SSW manual swinging slim hose reel	25	30	Jet	501b/10
'Will' model WEN-1SW manual swinging hose reel	25	30	Jet	501b/01
'Will' model WEN-1SWS manual swinging hose reel	25	30	Jet	501b/11

Masar Fire Engineering

269 Khalda Amman, P.O.Box 1159, Amman, 11910, Jordan

Tel: +962 6 537 0320

E-mail: info@masarfire.com • Website: www.masarfire.com

Certificate No: 1038AVa to EN 671-1:2012

'FIRELESS' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
FIRELESS-MS1-25	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AVa/02
FIRELESS-AS-25	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AVa/04
FIRELESS-MS2-25	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AVa/14

Masry For Engineering & Trading

14 Block 28, Ahmed Al-Zomor St., 9th District, Nasr City, Cairo, Egypt

Tel: +202 2382 0354

E-mail: sales5@masryegypt.com • Website: www.masryegypt.com

Certificate No: 1038BEa to EN 671-1:2012

'MASRY GROUP' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MAS-01 MSA	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BEa/02
MAS-02 ASP	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BEa/11
MAS-03 MSP	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BEa/14

Mazen Abdulsalam Jadid Factory For Manufacturing Safety Equipment

Industrial City No. 3, Jazan Road, Jeddah, Kingdom of Saudi Arabia

Tel: +966 506 667 516

E-mail: mafco2000@gmail.com

Certificate No: 1038BDa to EN 671-1:2012

'MAFCO' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MF300/S	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BDa/02
MF600/S	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BDa/04
MF9000/S	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BDa/14

FIRE HOSE REELS

Melton Egypt

Block 20003, 3rd Plot, El Obour, Industrial Zone, Cairo, Egypt

Tel: +202 4489 2078

E-mail: info@melton-eg.com • Website: www.melton-eg.com

Certificate No: 1153Ma to EN 671-1:2012

'MELTON' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MT-03-AA	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Ma/01
MT-02-MA	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Ma/05

MOBIK S.A.

96-98 M. Mpotsari St, Chania, Crete, 73136, Greece

Tel: +30 28210 63222

E-mail: sales@mobiak.gr • Website: http://www.mobiak.gr

Certificate No: 1038Ac to EN 671-1:2012

'Altech' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MBK15-25BD NRF-9202501	Manual, swinging door, cabinet mounted	19	25	Rotary operated jet/spray	1038Ac/01
MBK15-30BD NRF-9202502	Manual, swinging door, cabinet mounted	19	30	Rotary operated jet/spray	1038Ac/01

Certificate No: 1038Sa to EN 671-1

Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MBK14-SJR-08A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Sa/01
MBK10-SJR-07B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Sa/02
MBK14-SJR-10B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Sa/03
MBK10-SJR-06B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Sa/04
MBK10-SJR-01B	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038Sa/05
MBK10-SJR-02A	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Sa/06
MBK10-SJR-02B	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Sa/07
MBK14-SJR-12A	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Sa/08
MBK14-SJR-13A	Automatic, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Sa/09
MBK14-SJR-14A	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Sa/10
MBK14-SJR-15A	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Sa/11
MBK14-SJR-01A	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Sa/12
MBK10-SJR-04A	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Sa/13
MBK10-SJR-04B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Sa/14

Monsher Fire Protection Systems (P) Ltd.

403 Tanta Jogani Estate, Off N.M Joshi Road, Lower Parel (East), Mumbai 400011, India

Tel: +91 22 4051 2000

E-mail: info@monsher.com • Website: www.monsher.com

FIRE HOSE REELS

Certificate No: 1038Pa to EN 671-1

Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
BF-MS-003	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Pa/01

MORX Fire Fighting Solutions

Plot 132, 6 Million Industrial Zone, 10th of Ramadan City, 7067113, Egypt

Tel: +20 1201333309

E-mail: info@morx-eg.com • Website: www.morx-eg.com

Certificate No: 1038AWa to EN 671-1:2012

'MORX' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MXR-01-MA	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AWa/02
MXR-02-AA	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AWa/04
MXR-03-MP	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AWa/10
MXR-04-AP	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AWa/11
MXR-06-B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AWa/14
MXR-05-D	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AWa/18

Certificate No: 1153Na to EN 671-1:2012

'MORX' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MXC-01-AW	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Na/01
MXC-02-FW	Manual, fixed, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Na/02
MXC-03-AW	Automatic, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153Na/03
MXC-04-FW	Manual, fixed, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153Na/04
MXC-05-AW	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Na/05
MXC-06-MW	Manual, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153Na/06
MXC-09-MW	Manual, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153Na/09
MXC-10-MW	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Na/10
MXC-11-AW	Automatic, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153Na/11
MXC-12-AW	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Na/12

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463d to EN 671-1:2012

'NAFFCO' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle Type	LPCB Ref. No.
19NFH-020A	swinging arm, automatic, plastic rotary nozzle, mild steel reels	19	30	jet/spray	463d/01
19NFH-030A	swinging pipe, automatic, plastic rotary nozzle, mild steel reels	19	30	jet/spray	463d/02
19NFH-040A	fixed, automatic, plastic rotary nozzle, mild steel reels	19	30	jet/spray	463d/03
19NFH-020M	swinging arm, manual, plastic rotary nozzle, mild steel reels	19	30	jet/spray	463d/04
19NFH-030M	swinging pipe, manual, plastic rotary nozzle, mild steel reels	19	30	jet/spray	463d/05
19NFH-040M	fixed, manual, plastic rotary nozzle, mild steel reels	19	30	jet/spray	463d/06
25NFH-020A	swinging arm, automatic, plastic rotary nozzle, mild steel reels	25	30	jet/spray	463d/07
25NFH-030A	swinging pipe, automatic, plastic rotary nozzle, mild steel reels	25	30	jet/spray	463d/08

FIRE HOSE REELS

25NFH-040A	fixed, automatic, plastic rotary nozzle, mild steel reels	25	30	jet/spray	463d/09
25NFH-020M	swinging arm, manual, plastic rotary nozzle, mild steel reels	25	30	jet/spray	463d/10
25NFH-030M	swinging pipe, manual, plastic rotary nozzle, mild steel reels	25	30	jet/spray	463d/11
25NFH-040M	fixed, manual, plastic rotary nozzle, mild steel reels	25	30	jet/spray	463d/12
19NFH-020AB	swinging arm, automatic, brass rotary nozzle, mild steel reels	19	30	jet/spray	463d/15
19NFH-020A/SS	swinging arm, automatic, plastic rotary nozzle, stainless steel reels	19	30	jet/spray	463d/16
19NFH-020A/SS-B	swinging arm, automatic, brass rotary nozzle, stainless steel reels	19	30	jet/spray	463d/17
19NFH-030AB	swinging pipe, automatic, brass rotary nozzle, mild steel reels	19	30	jet/spray	463d/18
19NFH-030A/SS	swinging pipe, automatic, plastic rotary nozzle, stainless steel reels	19	30	jet/spray	463d/19
19NFH-030A/SS-B	swinging pipe, automatic, brass rotary nozzle, stainless steel reels	19	30	jet/spray	463d/20
19NFH-040AB	fixed, automatic, brass rotary nozzle, mild steel reels	19	30	jet/spray	463d/21
19NFH-040A/SS	fixed, automatic, plastic rotary nozzle, stainless steel reels	19	30	jet/spray	463d/22
19NFH-040A/SS-B	fixed, automatic, brass rotary nozzle, stainless steel reels	19	30	jet/spray	463d/23
19NFH-020MB	swinging arm, manual, brass rotary nozzle, mild steel reels	19	30	jet/spray	463d/24
19NFH-020M/SS	swinging arm, manual, plastic rotary nozzle, stainless steel reels	19	30	jet/spray	463d/25
19NFH-020M/SS-B	swinging arm, manual, brass rotary nozzle, stainless steel reels	19	30	jet/spray	463d/26
19NFH-030MB	swinging pipe, manual, brass rotary nozzle, mild steel reels	19	30	jet/spray	463d/27
19NFH-030M/SS	swinging pipe, manual, plastic rotary nozzle, stainless steel reels	19	30	jet/spray	463d/28
19NFH-030M/SS-B	swinging pipe, manual, brass rotary nozzle, stainless steel reels	19	30	jet/spray	463d/29
19NFH-040MB	fixed, manual, brass rotary nozzle, mild steel reels	19	30	jet/spray	463d/30
19NFH-040M/SS	fixed, manual, plastic rotary nozzle, stainless steel reels	19	30	jet/spray	463d/31
19NFH-040M/SS-B	fixed, manual, brass rotary nozzle, stainless steel reels	19	30	jet/spray	463d/32
25NFH-020AB	swinging arm, automatic, brass rotary nozzle, mild steel reels	25	30	jet/spray	463d/33
25NFH-020A/SS	swinging arm, automatic, plastic rotary nozzle, stainless steel reels	25	30	jet/spray	463d/34
25NFH-020A/SS-B	swinging arm, automatic, brass rotary nozzle, stainless steel reels	25	30	jet/spray	463d/35
25NFH-030AB	swinging pipe, automatic, brass rotary nozzle, mild steel reels	25	30	jet/spray	463d/36
25NFH-030A/SS	swinging pipe, automatic, plastic rotary nozzle, stainless steel reels	25	30	jet/spray	463d/37
25NFH-030A/SS-B	swinging pipe, automatic, brass rotary nozzle, stainless steel reels	25	30	jet/spray	463d/38
25NFH-040AB	fixed, automatic, brass rotary nozzle, mild steel reels	25	30	jet/spray	463d/39
25NFH-040A/SS	fixed, automatic, plastic rotary nozzle, stainless steel reels	25	30	jet/spray	463d/40
25NFH-040A/SS-B	fixed, automatic, brass rotary nozzle, stainless steel reels	25	30	jet/spray	463d/41
25NFH-020MB	swinging arm, manual, brass rotary nozzle, mild steel reels	25	30	jet/spray	463d/42
25NFH-020M/SS	swinging arm, manual, plastic rotary nozzle, stainless steel reels	25	30	jet/spray	463d/43
25NFH-020M/SS-B	swinging arm, manual, brass rotary nozzle, stainless steel reels	25	30	jet/spray	463d/44
25NFH-030MB	swinging pipe, manual, brass rotary nozzle, mild steel reels	25	30	jet/spray	463d/45
25NFH-030M/SS	swinging pipe, manual, plastic rotary nozzle, stainless steel reels	25	30	jet/spray	463d/46
25NFH-030M/SS-B	swinging pipe, manual, brass rotary nozzle, stainless steel reels	25	30	jet/spray	463d/47
25NFH-040MB	fixed, manual, brass rotary nozzle, mild steel reels	25	30	jet/spray	463d/48
25NFH-040M/SS	fixed, manual, plastic rotary nozzle, stainless steel reels	25	30	jet/spray	463d/49
25NFH-040M/SS-B	fixed, manual, brass rotary nozzle, stainless steel reels	25	30	jet/spray	463d/50

Nasr Awwadeh Factory for Fire Fighting & Safety Equipment

Building No. 7, Mohammed Al Khodary Street, P.O. Box 330339, Marka 11134, Amman, Jordan

Tel: +962 6 488 1999

E-mail: info@naffire.com • Website: www.naffire.com

Certificate No: 1038AMa to EN 671-1:2012

'NAF' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
N-MS1-25A	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AMa/02
N-AS1-25A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AMa/04

FIRE HOSE REELS

National Factory for Security & Safety Equipment LLC

P.O.Box 129, Road No. 19, Ind. Estate, Al Rusayl, PC 124, Sultanate of Oman

Tel: +968 2444 6268

E-mail: sales@amancoglobal.com • Website: www.amancoglobal.com

Certificate No: 1038Qa to EN 671-1:2012

'AMANCO' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
AFHR-21	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Qa/03
AFHR-19	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Qa/04
AFHR-08-A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Qa/01
AFHR-07-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Qa/02

Ningbo Kaixuan Fire Control Equipment Co., Ltd.

No. 999 Zhonghe Road, Huangjiabu Town, Yuyao City, Zhejiang Province, 315466, China

Tel: +86 574 62025710

E-mail: info@kaixuanfire.com • Website: www.kaixuanfire.com

Certificate No: 1153a to EN 671-1:2012

'KXFIRE' Fire Hose Reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle type	LPCB Ref. No.
KX06-172-00	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153a/01
KX06-173-00	Manual, fixed, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153a/02
KX06-172A-00	Automatic, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153a/03
KX06-173A-00	Manual, fixed, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153a/04
KX06-173B-00	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153a/05
KX06-173C-00	Manual, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153a/06
KX06-217A-00	Manual, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153a/09
KX06-217-00	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153a/10
KX06-218A-00	Automatic, swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153a/11
KX06-218-00	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153a/12
KX06-216A-00	Manual swinging arm, cabinet or wall mounted	19	30	Rotary operated jet/spray	1153a/13
KX06-216-00	Manual swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153a/14

NORD PROTECTION SARL

2 et 4 Boulevard Al Imam Allait Ibn Asaad, El Qods, Sidi Bernoussi, Casablanca, 20610, Morocco

Tel: +212 522 76 52 40

E-mail: contact@nordprotection.ma • Website: www.nordprotection.ma

Certificate No: 1038Ya to EN 671-1:2012

NP Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
NP002C	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ya/02
NP001	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038Ya/05
NP002	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ya/10
NP002A	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ya/12
NP002B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Ya/14

FIRE HOSE REELS

Power Saints Ltd.

Tianhua Industrial District, Langxia Street Scene, Yuyao City, Zhejiang, 315480, China

Tel: 0086 (0)571 85772095

E-mail: sales@saintsea.com • Website: www.saintsea.com

Certificate No: 1127a to EN 671-1

'Krone' Fire Hose Reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle type	LPCB Ref. No.
SA10-314D-03S	Automatic, swinging arm, wall mounted, rotary operated nozzle	25	30	Rotary operated jet/spray	1127a/01
SA10-314D-02S	Manual, swinging arm, wall mounted, rotary operated nozzle	25	30	Rotary operated jet/spray	1127a/02
SA10-314D-14F	Manual, fixed, wall mounted, rotary operated nozzle	25	30	Rotary operated jet/spray	1127a/03
SA10-304D-03S	Automatic, swinging arm, wall mounted, rotary operated nozzle	19	30	Rotary operated jet/spray	1127a/04
SA10-304D-02S	Manual, swinging arm, wall mounted, rotary operated nozzle	19	30	Rotary operated jet/spray	1127a/05
SA10-304D-14F	Manual, fixed, wall mounted, rotary operated nozzle	19	30	Rotary operated jet/spray	1127a/06
PSHR3330SF	Manual, swinging arm, pillar or wall mounted	33	30	Rotary operated jet/spray or lever operated jet/spray	1127a/07

Rapidrop Global Limited

Rutland Business Park, Newark Road, Peterborough, PE1 5WA, United Kingdom

Tel: +44 1733 847 525 • Alt Tel: +44 7803 024 886

E-mail: rapidrop@rapidrop.com • Website: www.rapidrop.com

Certificate No: 566g to EN 671-1:2012

'Rapidrop' Fire Hose Reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle type	LPCB Ref. No.
Fig401	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	566g/01
Fig402	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	566g/02
Fig403	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	566g/03
Fig404	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	566g/04
Fig405	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	566g/05

SANAL Italia Srl

Via Bellino, 48, Catanzaro, 88100, Italy

Tel: +39 0961 62404

E-mail: info@sanalitalia.com • Website: http://www.sanalitalia.com/

Certificate No: 1038Va to EN 671-1:2012

S&L Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
SNL30M-A	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Va/02
SNL-10-B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Va/03
SNL-06-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Va/04
SNL-01-B	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038Va/05
SNL-04-B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Va/14
SNL-1930F	Manual, swinging door, cabinet mounted	19	30	Rotary operated jet/spray	1038Va/20

FIRE HOSE REELS

SensorTech Firefighting and Safety Equipment Trading

P.O.Box 231728, Office No. 506, Al Saud Building, Al Qusais – 4, Dubai, United Arab Emirates

Tel: +971 422 323 31

E-mail: info@sensortechuae.com • Website: www.sensortechuae.com

Certificate No: 1092Ld to EN 671-1:2012

'WETPLUG' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
W-FHR-A19	Fixed, automatic, wall mounted	19	30	Rotary operated spray	1092Ld/01
W-FHR-M19	Fixed, manual, wall mounted	19	30	Rotary operated spray	1092Ld/02
W-SHR-A19	Swinging, automatic, wall mounted	19	30	Rotary operated spray	1092Ld/03
W-SHR-M19	Swinging, manual, wall mounted	19	30	Rotary operated spray	1092Ld/04
W-FHR-A25	Fixed, automatic, wall mounted	25	30	Rotary operated spray	1092Ld/05
W-FHR-M25	Fixed, manual, wall mounted	25	30	Rotary operated spray	1092Ld/06
W-SHR-A25	Swinging, automatic, wall mounted	25	30	Rotary operated spray	1092Ld/07
W-SHR-M25	Swinging, manual, wall mounted	25	30	Rotary operated spray	1092Ld/08

Sentura Group Ltd. (including Fire Depot and Firechief Global)

Sentura House, 3 Lands End Way, Oakham, Rutland, LE15 6RB, United Kingdom

Tel: +44 (0)330 999 22 33

E-mail: sales@firedepot.co.uk • Website: www.firedepot.co.uk

Certificate No: 1093e to EN 671-1:2012

'FIRECHIEF REELMAX' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
RMSM19-B	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/01
RMSM25-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/02
RMSA19-B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/03
RMSA25-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/04
RMFM19-B	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/05
RMFM25-B	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/06
RMFA19-B	Automatic, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1093e/07
RMFA25-B	Automatic, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1093e/08

Shanghai Huiying Industry Co Ltd

Room 1313, Tower A, 1088 New Jinqiao Road, 201206, Shanghai, China

Tel: +86 21 61681700

E-mail: sales@pike-fire.com • Website: www.pike-fire.com

Certificate No: 1038Fa to EN 671-1:2012

'PIKE' Fire Hose Reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (mm)	Nozzle type	LPCB Ref. No.
PKHR-001	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants.	19	30	Lever operated jet only or rotary operated jet/spray	1038Fa/01
PKHR-002	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants.	25	30	Lever operated jet only or rotary operated jet/spray	1038Fa/02
PKHR-003	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants.	19	30	Lever operated jet only or rotary operated jet/spray	1038Fa/03
PKHR-004	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants	25	30	Lever operated jet only or rotary operated jet/spray	1038Fa/04

FIRE HOSE REELS

Certificate No: 1038Na to EN 671-1:2012

'MOSAFE' Fire Hose Reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle type	LPCB Ref. No.
MOSHR-07	Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants.	25	30	Lever operated jet only or rotary operated jet/spray	1038Na/02
MOSHR-06	Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants.	25	30	Lever operated jet only or rotary operated jet/spray	1038Na/04

Shanghai Iron Man Fire Fighting Equipment Co., Ltd.

Room 716, 7F No. 100, Xiuyan Road, Shanghai, 201315, China

Tel: +86-21-68062016

E-mail: sales@ironman-safety.com • Website: www.firefightingtool.com

Certificate No: 1038AFa to EN 671-1:2012

'IMSECUR' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
IMHR-08-A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AFa/01
IMHR-07-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AFa/02
IMHR-10-B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AFa/03
IMHR-06-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AFa/04
IMHR-01-B	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038AFa/05
IMHR-02-A	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AFa/06
IMHR-02-B	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AFa/07
IMHR-01-A	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AFa/12
IMHR-04-A	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038AFa/13
IMHR-04-B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AFa/14

Sheter International for Trading and Supplies

Factory No. 55, Industrial Zone, Southwest A6, 10th of Ramadan City, Egypt

Tel: +201099009062

E-mail: info@sheter.net • Website: www.sheter.net

Certificate No: 1153Sa to EN 671-1:2012

'SHETER' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
SH-402	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Sa/05

SIBCA Electronic Equipment Co. Limited

SIBCA Building – Behind Etisalat Main Building, Khalidiya, P.O. Box 46944, Abu Dhabi, United Arab Emirates

Tel: +971 2 4978600

E-mail: guard@sibca.com • Website: www.sibca.com

Certificate No: 1038BGa to EN 671-1:2012

Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
30 Apr 2025					Page 29 of 76

FIRE HOSE REELS

GC-0181A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BGa/01
GC-0181B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/02
GC-0182A	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BGa/03
GC-0182B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/04
GC-0183A	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038BGa/05
GC-0184A	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BGa/06
GC-0184B	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/07
GC-0185A	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BGa/08
GC-0186A	Automatic, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BGa/09
GC-0185B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/10
GC-0186B	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/11
GC-0183B	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/12
GC-0185C	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BGa/13
GC-0185D	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/14
GC-0187A	Automatic, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BGa/17
GC-0186C	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/18
GC-0187B	Automatic, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BGa/19

Sky for Import, General Contracting & Trading

5/18 Anwar El-Mofty St., Abbas El Akkad, Nasr City, Cairo, Egypt

Tel: +202 2075 0366

E-mail: info@sky-ict.com • Website: www.skytrading-eg.com

Certificate No: 1153Va to EN 671-1:2012

'SKY' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
SKYEG-AA-25	Automatic, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Va/01
SKYEG-MA-25	Manual, swinging arm, cabinet or wall mounted	25	30	Rotary operated jet/spray	1153Va/05

Somati FIE NV

Industrielaan 19a, B-9320 Erembodegem, Belgium

Tel: +32 (0)53 85 22 22

E-mail: info@somatifie.be • Website: http://www.somatifie.be/

Certificate No: 1038Za to EN 671-1:2012

SANILITE Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
SANILITE 20S	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Za/01
SANILITE 30S	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Za/02
SANILITE 20F	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038Za/06
SANILITE 30F	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038Za/07

FIRE HOSE REELS

Suzhou HLC Plastics Industry Co. Ltd

No. 103 Fengbeidang Road, Beiqiao Block, Xiangcheng District, Suzhou, China

Tel: +86 512 65366918

E-mail: info@suzhou-csj.com • Website: www.suzhou-csj.com

Certificate No: 1038a to EN 671-1:2012

'CSJ' & 'HLC' Fire hose reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle type	LPCB Ref. No.
CSJR-08-A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet / spray	1038a/01
CSJR-07-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet / spray	1038a/02
CSJR-10-B	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet / spray	1038a/03
CSJR-06-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet / spray	1038a/04
CSJR-01-B	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038a/05
CSJR-02-A	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038a/06
CSJR-02-B	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/07
CSJR-12-A	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038a/08
CSJR-13-A	Automatic, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038a/09
CSJR-14-A	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/10
CSJR-15-A	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/11
CSJR-01-A	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/12
CSJR-04-A	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038a/13
CSJR-04-B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/14
CSJR-02-C	Automatic, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038a/17
CSJR-04-D	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/18
CSJR-02-D	Automatic, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/19
HLCR-06-B	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/04
HLCR-07-B	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/02
HLCR-08-A	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038a/01
HLCR-04-D	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038a/18

Certificate No: 1038c to EN 671-1:2012

Fire Hose Reel

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
MBK-1925F	Manual, swinging door, cabinet mounted	19	25	Rotary operated jet/spray	1038c/01
MBK-1930F	Manual, swinging door, cabinet mounted	19	30	Rotary operated jet/spray	1038c/01

VALMECA MAROC S.A.R.L.

6 Bd Al Imam Allait Ibn Saad, Al Quods, Sidi Bernoussi, Casablanca, Morocco

Tel: +212 6 65 07 57 52

E-mail: valmeca.maroc@gmail.com

Certificate No: 1038Ala to EN 671-1:2012

'VM' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
VM002C	Manual, swinging arm, cabinet or wall	25	30	Lever operated jet only or rotary operated	1038Ala/02

30 Apr 2025

FIRE HOSE REELS

mounted				jet/spray	
VM001	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	1038A1a/05
VM002	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038A1a/10
VM002A	Manual, swinging arm, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038A1a/12
VM002B	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038A1a/14

Watania For Advanced Systems

7 Amin Abu Zeid Street, Saba Basha, Alexandria, Egypt

Tel: +2 (03) 5857668

E-mail: info@adstems.info • Website: <http://www.adstems.info/>

Certificate No: 1038AEa to EN 671-1:2012

Advanced Systems Fire Hose Reel

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
ADSYS-5000	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AEa/02

Watania For Modern Industries

3rd Industrial Zone, Borg Elarab, Alexandria, Egypt

Tel: +20 3585 7006

E-mail: watania@wataniagroup.net • Website: www.wataniagroup.net

Certificate No: 1038ACa to EN 671-1:2012

'WATANIA' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
WMIFHR	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ACa/02
WMIFHR-A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ACa/04

Watania for Trading and Engineering (Sherif Shaker & Corp.)

603 El Horreya Avenue, Zezenia, Alexandria, Egypt

Tel: +20 3575 8008

E-mail: watania@wataniagroup.com • Website: www.wataniagroup.com

Certificate No: 1038AXa to EN 671-1:2012

'Watania' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
WSSFHR	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AXa/02
WSSFHR-A	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038AXa/04

Watex Pumps Industries

D8, New Industrial Area, Amman Street, Ajman, United Arab Emirates

Tel: +971 552148105

E-mail: info@watexindustries.com • Website: www.watexindustries.com

Certificate No: 1038ABa to EN 671-1:2012

FIRE HOSE REELS

WATEX Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
WMH-25MM	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ABa/02
WAH-25MM	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038ABa/04

Yuyao Tianbo Fire Fighting Equipment Co., Ltd.

Baishuicong Industrial Park, Lianglong Town, Yuyao City, Zhejiang, China

Tel: +86-21-61602389

E-mail: export@yytianbo.cn • Website: www.yytianbo.cn

Certificate No: 1092d to EN 671-1:2012

'TIANBO' Fire Hose Reels

Product Name	Description	Hose nominal bore (mm)	Hose maximum length (m)	Nozzle type	LPCB Ref. No.
FA19	Fixed, automatic, wall mounted, rotary operated nozzle	19	30	Rotary operated spray	1092d/01
FM19	Fixed, manual, wall mounted, rotary operated nozzle	19	30	Rotary operated spray	1092d/02
SA19	Swinging, automatic, wall mounted, rotary operated nozzle	19	30	Rotary operated spray	1092d/03
SM19	Swinging, manual, wall mounted, rotary operated nozzle	19	30	Rotary operated spray	1092d/04
FA25	Fixed, automatic, wall mounted, rotary operated nozzle	25	30	Rotary operated spray	1092d/05
FM25	Fixed, manual, wall mounted, rotary operated nozzle	25	30	Rotary operated spray	1092d/06
SA25	Swinging, automatic, wall mounted, rotary operated nozzle	25	30	Rotary operated spray	1092d/07
SM25	Swinging, manual, wall mounted, rotary operated nozzle	25	30	Rotary operated spray	1092d/08

Yuyao Tianning Fire Control Equipment Co., Ltd.

Ganxuan Village, Liangnong Town, Yuyao City, Ningbo, Zhejiang Province, China

Tel: 0086 15618883100

E-mail: Nicole.mengxiao Zhang@hotmail.com • Website: www.tianningfire.com

Certificate No: 1364b to EN 671-1:2012

'TenNeed' Fire Hose Reels

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
TN04-D-03B	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1364b/01
TN04-D-03A	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1364b/02
TN04-D-08B	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1364b/03
TN04-D-08A	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1364b/04

GATE VALVES

Copper alloy gate valves are for use in fixed firefighting applications such as risers and hydrant systems having flanged, threaded, capillary, compression or loose nut/union body ends.

These products are approved to BS 5154 - *Specification for Copper alloy globe, globe stop and check, check and gate valves*

Fire Inspection Services Pty Ltd

35 The Grove, Coburg, Victoria, 3058, Australia

Tel: +61 411 103 846

E-mail: projects@sfpmena.com

Certificate No: 1153AAb to BS 5154:1991

'FIS MENA' Copper Alloy Gate Valves

Product Name	Description	LPCB Ref. No.
FIS-LS	1" Copper alloy gate valve with lockshield	1153AAb/01
FIS-HW	1" Copper alloy gate valve with handwheel	1153AAb/02

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete, 73136, Greece

Tel: +30 28210 63222

E-mail: sales@mobiak.gr • Website: <http://www.mobiak.gr>

Certificate No: 1153Ab to BS 5154:1991

'MOBIAK' Copper Alloy Gate Valves

Product Name	Description	LPCB Ref. No.
MBK06-043A-00	1" Copper alloy gate valve with lockshield	1153Ab/01
MBK06-043A1-00	1" Copper alloy gate valve with handwheel	1153Ab/02

Ningbo Kaixuan Fire Control Equipment Co., Ltd.

No. 999 Zhonghe Road, Huangjiabu Town, Yuyao City, Zhejiang Province, 315466, China

Tel: +86 574 62025710

E-mail: info@kaixuanfire.com • Website: www.kaixuanfire.com

Certificate No: 1153b to BS 5154:1991


'JINTIAN FIRE' Copper Alloy Gate Valves

Product Name	Description	LPCB Ref. No.
KX06-043A-00	1" Copper alloy gate valve with lockshield	1153b/01
KX06-043A1-00	1" Copper alloy gate valve with handwheel	1153b/02

HAND-HELD BRANCHPIPES

Hand-held branchpipes are intended for fire service use with water only as the extinguishing media. The hand-held branchpipes have a combination of components that connect to a water supply via a hose and coupling and projects water according to the operators requirements. A hand-held branchpipe is comprised of at least the following components: fitting system; gripping device; open and shut-off device, one or more jet/spray system(s) and a flow adjustment system (if applicable).

Branchpipes are defined in accordance with EN 15182-1 Annex A and using the spray types defined by Annex C.



Key

- 1 hollow cone spray
- 2 full cone spray
- 3 hollow/full cone spray alternatively
- 4 hollow cone spray combined with narrow spray jet
- 5 hollow cone spray combined with full jet

The hand-held branchpipes shall be used in accordance with the manufacturers instructions for use and maintenance.

This section lists products approved in accordance with:

- EN 15182-1 - Common requirements
- EN 15182-2 - Combination branchpipes PN16
- EN 15182-3 - Smooth bore jet and/or one fixed spray jet angle branchpipes PN16
- EN 15182-4 - High pressure branchpipes PN40

Exceptions:

The standards do not apply to branchpipes covered by EN 671, foam branchpipes, powder branchpipes or branchpipes with a maximum working pressure above 40 bar.

Note:

Branchpipes covered by EN 15182-3 offer no or inadequate protection for firefighters when the spray angle is less than 30° and therefore, should not be used in high risk firefighting situations such as internal attack. They should also not be used when fighting fire in or near electrical installations when the spray angle is less than 30° without written authorisation from the manufacturer in the manual. This authorisation from the manufacturer should include safety distances.

Advanced Systems Company Ltd

Office 1301 Capricorn Tower, Sheik Zayed Road, Trade Center Second, Dubai, United Arab Emirates

E-mail: sales@adsystems.info • Website: www.adsystems.info

Certificate No: 1153Qc to EN 15182-1:2019 and EN 15182-3:2019

'ADVANCED SYSTEMS' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
AD-250	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2½" BSP threaded male inlet, hand-held branchpipe	1153Qc/07

Al Arabia for Safety & Security LLC

P.O.Box 60204, Dubai, United Arab Emirates

Tel: +971 4203 7348

E-mail: firenet@al-majid.com • Website: www.alarabiasafetysecurity.com

HAND-HELD BRANCHPIPES

Certificate No: 1153Yc to EN 15182-1:2019 & EN 15182-3:2019

'JAM GUARD' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
JG-NZ-1	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153Yc/06
JG-NZ-2	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153Yc/03

Fireguard Global Ltd.

Unit 11 Chancel Industrial Estate, Newhall Street, Willenhall, West Midlands, WV13 1NX, United Kingdom

Tel: +44 (0)8450 751042

E-mail: info@fireguard-uk.com • Website: www.fireguard-uk.com

Certificate No: 1153Oc to EN 15182-1:2019 and EN 15182-3:2019

'FIREGUARD' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
FG07-131C-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153Oc/03
FG07-131B-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153Oc/06

Gulf Fire Fighting Equipments FZE

Plot No: S3118, Jebel Ali Free Zone, Dubai, United Arab Emirates

Tel: +971 48807127

E-mail: info@gulffireco.com • Website: www.gulffireco.com

Certificate No: 1153Wc to EN 15182-1:2019 and EN 15182-3:2019

Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
GF-HHBP-65	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153Wc/06

Melton Egypt

Block 20003, 3rd Plot, El Obour, Industrial Zone, Cairo, Egypt

Tel: +202 4489 2078

E-mail: info@melton-eg.com • Website: www.melton-eg.com

Certificate No: 1153Mc to EN 15182-1:2019 and EN 15182-3:2019

'Melton' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
MT-65A	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153Mc/03
MT-65AP	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153Mc/06

MOBIK S.A.

96-98 M. Mpotsari St, Chania, Crete, 73136, Greece

Tel: +30 28210 63222

E-mail: sales@mobiak.gr • Website: http://www.mobiak.gr

HAND-HELD BRANCHPIPES

Certificate No: 1153Ac to EN 15182-1:2019 and EN 15182-3:2019

'MOBIAC' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
MBK07-108C-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2" BSP threaded male inlet, hand-held branchpipe	1153Ac/01
MBK07-108A-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M56 x 4 threaded female inlet, hand-held branchpipe	1153Ac/02
MBK07-127F-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153Ac/03
MBK07-108D-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2" BSP threaded male inlet, hand-held branchpipe	1153Ac/04
MBK07-108B-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M56 x 4 threaded female inlet, hand-held branchpipe	1153Ac/05
MBK07-127E-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153Ac/06
MBK07-107C-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2½" BSP threaded male inlet, hand-held branchpipe	1153Ac/07
MBK07-107A-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M85*6*6H threaded female inlet, hand-held branchpipe	1153Ac/08
MBK07-107D-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2½" BSP threaded male inlet, hand-held branchpipe	1153Ac/09
MBK07-107B-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M85*6*6H threaded female inlet, hand-held branchpipe	1153Ac/10

MORX Fire Fighting Solutions

Plot 132, 6 Million Industrial Zone, 10th of Ramadan City, 7067113, Egypt

Tel: +20 1201333309

E-mail: info@morx-eg.com • Website: www.morx-eg.com

Certificate No: 1153Nc to EN 15182-1:2019 and EN 15182-3:2019

'MORX' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
MXN-01-A65	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153Nc/03
MXN-02-P65	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153Nc/06

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463t to EN 15182-1:2019 and EN 15182-3:2019

'NAFFCO' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
NF-FP330	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	463t/01

Ningbo Kaixuan Fire Control Equipment Co., Ltd.

No. 999 Zhonghe Road, Huangjiabu Town, Yuyao City, Zhejiang Province, 315466, China

Tel: +86 574 62025710

E-mail: info@kaixuanfire.com • Website: www.kaixuanfire.com

Certificate No: 1153c to EN 15182-1:2019 and EN 15182-3:2019

'JINTIAN FIRE' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
30 Apr 2025		Page 37 of 76

HAND-HELD BRANCHPIPES

KX07-108C-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2" BSP threaded male inlet, hand-held branchpipe	1153c/01
KX07-108A-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M56 x 4 threaded female inlet, hand-held branchpipe	1153c/02
KX07-127F-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153c/03
KX07-108D-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2" BSP threaded male inlet, hand-held branchpipe	1153c/04
KX07-108B-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M56 x 4 threaded female inlet, hand-held branchpipe	1153c/05
KX07-127E-00	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153c/06
KX07-107C-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2½" BSP threaded male inlet, hand-held branchpipe	1153c/07
KX07-107A-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M85*6*6H threaded female inlet, hand-held branchpipe	1153c/08
KX07-107D-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2½" BSP threaded male inlet, hand-held branchpipe	1153c/09
KX07-107B-00	16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M85*6*6H threaded female inlet, hand-held branchpipe	1153c/10

Sheter International for Trading and Supplies

Factory No. 55, Industrial Zone, Southwest A6, 10th of Ramadan City, Egypt

Tel: +201099009062

E-mail: info@sheter.net • Website: www.sheter.net

Certificate No: 1153Sc to EN 15182-1:2019 and EN 15182-3:2019

'SHETER' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
SHBP-405	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153Sc/03

Sky for Import, General Contracting & Trading

5/18 Anwar El-Mofty St., Abbas El Akkad, Nasr City, Cairo, Egypt

Tel: +202 2075 0366

E-mail: info@sky-ict.com • Website: www.skytrading-eg.com

Certificate No: 1153Vc to EN 15182-1:2019 and EN 15182-3:2019

'SKY' Hand-Held Branchpipes

Product Name	Description	LPCB Ref. No.
SKYEG-16A	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe	1153Vc/03
SKYEG-16P	13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe	1153Vc/06

INLET BREECHINGS

Dry riser inlets are permanently connected to uncharged water pipe systems that are installed within protected service riser shafts within the building.

The inlet breeching is suitably located on the ground floor to enable the fire and rescue service to connect hoses to a suitable water supply allowing water to be pumped up to higher floors.

Inlet breechings are tested to BS 5041-3.

This section lists products approved in accordance with:

BS 5041-3 - *Fire hydrant systems equipment. Specification for inlet breechings for dry riser inlets*

Brake Fire Safety and Security

Building 8, Industrial Area / 1 Amman Street, Ajman, United Arab Emirates

Tel: +971 551 668 286

E-mail: info@brakefiregcc.com • Website: www.brakefiregcc.com

Certificate No: 1153Rd to BS 5041-3:1975

'BRAKE FIRE' Inlet Breechings for Dry Riser Inlets

Product Name	Description	LPCB Ref. No.
BFBV-4-F	4 way inlet breeching, 150mm flanged outlet	1153Rd/01
BFBV-2-F	2 way inlet breeching, 100mm flanged outlet	1153Rd/02

EMACO GLOBAL LLC

3118 Beckett Way, Lakeland, FL 33810, USA

Tel: +1 (516) 288-8935

E-mail: info@emacoglobal.com • Website: www.emacoglobal.com

Certificate No: 1153Jd to BS 5041-3:1975

'EMACO' Inlet Breechings

Product Name	Description	LPCB Ref. No.
E0191-203-00	4 way inlet breeching, 150mm flanged outlet	1153Jd/01
E0191-202-00	2 way inlet breeching, 100mm flanged outlet	1153Jd/02

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 863d to BS 5041-3

Inlet Breechings

Product Name	Description	LPCB Ref. No.
APDR2-100-BI	2 way inlet breeching, 100mm flanged outlet	863d/01
APDR4-150-BI	4 way inlet breeching, 150mm flanged outlet	863d/02

Fire King Security and Safety Equipment

Al Juwais Main Road, Ras Al Khaimah, United Arab Emirates

Tel: +971 7 2437050

E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1153Xd to BS 5041-3:1975

INLET BREECHINGS

Inlet Breechings

Product Name	Description	LPCB Ref. No.
FK08-203-00	4 way inlet breeching, 150mm flanged outlet	1153Xd/01
FK08-202-00	2 way inlet breeching, 100mm flanged outlet	1153Xd/02

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building, 738471, Singapore

Tel: +65 6759 4163

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501d to BS 5041-3

Inlet Breechings

Product Name	Description	LPCB Ref. No.
DR 095	2 way inlet breeching, 100 mm flanged outlet	501d/01
WR 115	4 way inlet breeching, 150 mm flanged outlet	501d/02

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete, 73136, Greece

Tel: +30 28210 63222

E-mail: sales@mobiak.gr • Website: http://www.mobiak.gr

Certificate No: 1153Ad to BS 5041-3:1975

'MOBIAK' Inlet Breechings

Product Name	Description	LPCB Ref. No.
MBK08-203-00	4 way inlet breeching, 150mm flanged outlet	1153Ad/01
MBK08-202-00	2 way inlet breeching, 100mm flanged outlet	1153Ad/02

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463f to BS 5041-3

Inlet Breechings

Product Name	Description	LPCB Ref. No.
NDR 095	4 inch x 2 way inlet breeching	463f/01
NWR 115	6 inch x 4 way inlet breeching	463f/02
NWRX 115	6 inch x 4 way inlet breeching	463f/03

Ningbo Kaixuan Fire Control Equipment Co., Ltd.

No. 999 Zhonghe Road, Huangjiabu Town, Yuyao City, Zhejiang Province, 315466, China

Tel: +86 574 62025710

E-mail: info@kaixuanfire.com • Website: www.kaixuanfire.com

Certificate No: 1153d to BS 5041-3:1975

'KAIXUAN' Inlet Breechings for Dry Riser Inlets

Product Name	Description	LPCB Ref. No.
KX08-203-00	4 way inlet breeching, copper alloy (LG2/CC491K) couplings, 150mm flanged outlet	1153d/01
KX08-202-00	2 way inlet breeching, copper alloy (LG2/CC491K) couplings, 100mm flanged outlet	1153d/02
KX08-203B-00	4 way inlet breeching, copper alloy (CZ122/CW617N) couplings, 150mm flanged outlet	1153d/03
KX08-202B-00	2 way inlet breeching, copper alloy (CZ122/CW617N) couplings, 100mm flanged outlet	1153d/04

INLET BREECHINGS

Rapidrop Global Limited

Rutland Business Park, Newark Road, Peterborough, PE1 5WA, United Kingdom

Tel: +44 1733 847 525 • Alt Tel: +44 7803 024 886

E-mail: rapidrop@rapidrop.com • Website: www.rapidrop.com

Certificate No: 566k to BS 5041-3:1975

'RAPIDROP' Inlet Breechings for Dry Riser Inlets

Product Name	Description	LPCB Ref. No.
Fig.604	4 way inlet breeching, 150mm flanged outlet	566k/01
Fig.603	2 way inlet breeching, 100mm flanged outlet	566k/02

Shah Bhogilal Jethalal & Brothers

72, Siddhi Vinayak Estate, Opp. Ramdev Kitchen Express, Santej-Vadsar Road, Village : Santej, Taluka : Kalol, District : Gandhinagar, Gujarat, 382721, India

Tel: +91 2764 268612 to 15

E-mail: info@aaagindia.in • Website: www.aaagindia.in

Certificate No: 1584b to BS 5041-3:1975

'AAAG' Inlet Breechings

Product Name	Description	LPCB Ref. No.
G151-BS	2 way inlet breeching, 100mm flanged outlet	1584b/01
G154-BS	4 way inlet breeching, 150mm flanged outlet	1584b/02

Shanghai Firetech Co. Ltd.

21F, Building B, No. 2157 Hunan Road, Pudong District, Shanghai, 201204, China

Tel: +86 13917676168

E-mail: info@firetechsh.com • Website: www.firetechsh.com

Certificate No: 1153ld to BS 5041-3:1975

'FIRETECH' Inlet Breechings

Product Name	Description	LPCB Ref. No.
FT202	4 way inlet breeching, 150mm flanged outlet	1153ld/03
FT201	2 way inlet breeching, 100mm flanged outlet	1153ld/04

Shaoxing Jia Sheng Fire Fighting Equipment Co. Limited

No 30, Zijin Road, Tianjia Industrial Zone, Xiaoyue Town, Shangyu District, Shaoxing City, Zhejiang Province, 312367, China

Tel: +86-575-82039618

E-mail: rachel.yan@jsfire.com.cn • Website: www.jsfire.com.cn

Certificate No: 1366b to BS 5041-3:1975

Inlet Breechings

Product Name	Description	LPCB Ref. No.
JS06.002.01A	2 way inlet breeching, 100 mm flanged outlet	1366b/01
JS06.002.02B	4 way inlet breeching, 150 mm flanged outlet	1366b/02

INLET BREECHINGS

Shaoxing Shangyu Hongye Fire Protection Equipment Factory

No 56, West of Wucheyan National Road, Wucheyan Village, Huangjiabu Town, Yuyao City, China

Tel: +86 176823456868 • Alt Tel: +86 13858532457

E-mail: info@hongye-fire.com • Website: www.hongye-fire.com

Other

Foundry Address - Wushan Village, Xiaoyue Town, Shangyu District, Zhejiang, 312367, China

Certificate No: 1823a to BS 5041-3:1975

'HY FIRE' Inlet Breechings for Dry Riser Inlets

Product Name	Description	LPCB Ref. No.
HY008-001-00-LPCB	2 way inlet breeching, 100mm flanged outlet	1823a/01
HY008-002-00-LPCB	4 way inlet breeching, 150mm flanged outlet	1823a/02

The Viking Corporation

210 N Industrial Park, Hastings, Michigan 49058, USA

Tel: +1 269 945 9501

E-mail: techsvcs@vikingcorp.com • Website: www.vikingcorp.com

Certificate No: 1153Kd to BS 5041-3:1975

Viking Corp Fireking Inlet Breechings

Product Name	Description	LPCB Ref. No.
FK-4W-336	4 way inlet breeching, 150mm flanged outlet	1153Kd/01
FK-2W-336	2 way inlet breeching, 100mm flanged outlet	1153Kd/02

LAYFLAT HOSES

Layflat hose is typically used by the fire service to convey large quantities of water to the fire. Lengths of hose may be connected together via couplings and the hose should be flexible, strong, resist kinking, watertight, rot-proof, impervious to chemicals and operate in varying extremes of temperature.

To achieve these requirements layflat hose comes in three types.

Type 1 hoses are those to which no external treatments have been applied to the reinforcement and may be liable to absorb liquids and need to be thoroughly dried after use. These types of fire hose are sometimes called conventional hoses.

Type 2 hoses are those to which an external elastomeric coating has been applied to the reinforcement to give some protection against the absorption of liquids and to improve resistance to abrasion of the reinforcement.

Type 3 hoses are those to which an external elastomeric coating or covering has been applied to or been incorporated within the reinforcement to give the hoses very low absorption of liquids and high resistance to abrasion and heat.

In some countries layflat hose may also be concertinaed in a hanging rack adjacent to a dry riser in a fixed location within a building ensuring a fast and easily available source of large quantities of water. A branch (nozzle) is usually also supplied at this location.

This section lists products approved in accordance with:

BS 6391 - *Requirements for non-percolating layflat delivery hoses and hose assemblies for fire fighting purposes.*

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463g to BS 6391

Layflat delivery hoses

Product Name	Description	LPCB Ref. No.
NF-DH2 65R	2.5" Layflat delivery hose , colour red	463g/01
NF-DH2 65W	2.5" Layflat delivery hose, colour white	463g/02

MOBILE FIRE EXTINGUISHERS

Mobile fire extinguishers are manufactured to suit different types of fires and should be selected, sited, serviced and maintained in accordance with the relevant code of practice. Third party approval of the mobile fire extinguisher will help to ensure that they will function correctly if properly maintained, it will also demonstrate due diligence in supporting risk assessed based legislation.

LPCB approval helps to ensure that fire extinguishers meet and continue to meet appropriate standards. LPCB approval includes testing of the individual component parts of the fire extinguisher, pressure safety of the vessel, correct labelling and operation instructions and the satisfactory performance of the extinguisher when tested to the relevant fire test. These elements are continuously monitored during regular factory production control (FPC) surveillance audits.

CE marking may be found on a mobile fire extinguisher as required by the European Union - Pressure Equipment Directive (PED) but should not be confused with LPCB approval. This directive has been published for products that are to be sold within the European Union (EU) and it requires proof of safety of the pressure vessel. The CE mark placed on a fire extinguisher demonstrates conformance with this pressure safety requirement and fire testing is not carried out as part of this directive.

Caution: To be sure of reliable, proven, performance of the fire extinguisher in fire conditions, the extinguisher should carry independent proof of performance, such as the LPCB mark, and if it is to be supplied into the EU the additional CE mark will also be required as defined by the PED.

Mobile fire extinguishers are manufactured and tested to a class B type fire but also cover class A fire if necessary, with powder and water based extinguishing media tested in accordance with EN 3-7.

EN 1866 applies to mobile fire extinguishers with a total mass above 20kg for powder, water based and CO² extinguishers and manoeuvred by an operator on foot only. - This standard does not cover fire tests for class C and class F fires but the extinguishing media can be effective on these types of fire. Class D fires are considered to be very specialist application and are not included.

Caution: To be sure of reliable, proven, performance of the fire extinguisher in fire condition, the extinguisher should carry independent proof of performance, such as the LPCB mark, and if it is to be supplied into the EU the additional CE mark will also be required as defined by PED.

Always follow manufacturers use, installation and servicing instruction and replace after use.

The test standards used for LPCB certification of mobile fire extinguishers are:

EN 1866-1	<i>Characteristics, performance requirements and test methods</i>
EN 1866-2	<i>Requirements for the construction, pressure resistance and mechanical tests for extinguishers, with a maximum allowable pressure equal to or lower than 30 bar, which comply with the requirements of EN 1866-1</i>
EN 1866-3	<i>Requirements for the assembly, construction and pressure resistance of CO₂ extinguishers which comply with the requirements of EN 1866-1</i>

Abbreviations used for LPCB listing of mobile fire extinguishers

LPCB use the following abbreviations in the Red Book listings for mobile fire extinguishers.

Extinguishing Agent	
W - Water	WB - Water based (water plus additive)
ABC or BC - Dry powder	CO ₂ - Carbon Dioxide
Method of Actuation	
SP - Stored pressure actuation	GC - Gas cartridge actuation
Units or Capacity	
kg - Kilogram	l - litre

Labelling

A requirement of EN 1866 is that each mobile fire extinguisher must be clearly labelled to identify the classes of fire for which they have demonstrated satisfactory performance as defined in BS EN 1866. In summary:

Class A :	for use on flammable solid materials, for example wood, paper, coal, straw, cloth etc.
Class B :	for use on fires involving flammable liquids or liquefiable solids.

Colour Coding

EN 1866 permits a zone of colour of up to 10% of the external area of the extinguisher body to be used to identify the

MOBILE FIRE EXTINGUISHERS

extinguishing agent in accordance with national specifications.

Associated Enterprises (S) Pte Ltd.

Block 28, Sin Ming Drive, #01-173, 575702, Singapore

Tel: +65-64550555

E-mail: enquiry@aespl.com.sg • Website: www.aespl.com.sg

Certificate No: 1092Ac to EN 1866-1

PROTEC Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
PRO-50-MF	Foam (Stored Pressure)	50 litre	IV B	1092Ac/04
PRO-100-MF	Foam (Stored Pressure)	100 litre	IV B	1092Ac/05
PRO-25-MDC	ABC Powder (Stored Pressure)	25 kg	II B	1092Ac/06
PRO-50-MDC	ABC Powder (Stored Pressure)	50 kg	IV B	1092Ac/07
PRO-100-MDC	ABC Powder (Stored Pressure)	100 kg	IV B	1092Ac/08
PRO-10-CD	CO ₂	10 kg	144 B	1092Ac/01
PRO-20-CD	CO ₂	20 kg	183 B	1092Ac/02
PRO-30-CD	CO ₂	30 kg	183 B	1092Ac/03

Bristol Fire Engineering LLC

Al Quoz Industrial Area 3, P.O.Box 74582, Dubai, United Arab Emirates

Tel: +971 4 347 2426

E-mail: sami@bristol-fire.com • Website: www.bristol-fire.com

Certificate No: 1092Oc to EN 1866-1:2007

'BRISTOL' Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
CD10L	CO ₂	10 kg	144 B	1092Oc/01
CD20L	CO ₂	20 kg	183 B	1092Oc/02
CD30L	CO ₂	30 kg	183 B	1092Oc/03
MFE50L	Foam (Stored Pressure)	50 litre	IV B	1092Oc/04
MFE100L	Foam (Stored Pressure)	100 litre	IV B	1092Oc/05
BFE25L	ABC Powder (Stored Pressure)	25 kg	II B	1092Oc/06
BFE50L	ABC Powder (Stored Pressure)	50 kg	IV B	1092Oc/07
BFE100L	ABC Powder (Stored Pressure)	100 kg	IV B	1092Oc/08

Ceasefire Industries Private Limited

E6, Selaqui Industrial Area, Dehradun, Uttarakhand, 248011, India

Tel: +911204223473

E-mail: amit@ceasefire.in

Certificate No: 1329i to EN 1866-1:2007, EN 1866-2:2014 & EN 1866-3:2013

'CEASEFIRE' Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
CF-000747	Foam (Stored Pressure)	25 Litre	IV B	1329i/01
CF-000748	Foam (Stored Pressure)	50 Litre	IV B	1329i/02
CF-001018	Foam (Stored Pressure)	50 Litre	IV B	1329i/03
CF-000749	Foam (Stored Pressure)	100 Litre	IV B	1329i/04
CF-001021	Foam (Stored Pressure)	100 Litre	IV B	1329i/05
CF-000744	Foam Mist (Stored Pressure)	25 Litre	IV B	1329i/06
CF-000750	Foam Mist (Stored Pressure)	25 Litre	I B	1329i/07
CF-000745	Foam Mist (Stored Pressure)	50 Litre	IV B	1329i/08
CF-000751	Foam Mist (Stored Pressure)	50 Litre	IV B	1329i/09
CF-000746	Foam Mist (Stored Pressure)	100 Litre	IV B	1329i/10
CF-000752	Foam Mist (Stored Pressure)	100 Litre	IV B	1329i/11
CF-000808	ABC 50 Powder (Stored Pressure)	25 kg	IV B	1329i/12
CF-000809	ABC 50 Powder (Stored Pressure)	50 kg	IV B	1329i/13
CF-000810	ABC 50 Powder (Stored Pressure)	100 kg	IV B	1329i/14

MOBILE FIRE EXTINGUISHERS

CF-001031	Water (Stored Pressure)	50 litre	-	1329i/15
CF-001033	Water (Stored Pressure)	100 litre	-	1329i/16
CF-000741	Water Mist (Stored Pressure)	25 litre	-	1329i/17
CF-000742	Water Mist (Stored Pressure)	50 litre	-	1329i/18
CF-000743	Water Mist (Stored Pressure)	100 litre	-	1329i/19
CF-000740	CO ₂	20 kg	113 B	1329i/20
CF-000754	Foam (Cartridge Operated)	50 litre	IV B	1329i/21
CF-001019	Foam (Cartridge Operated)	50 litre	IV B	1329i/22
CF-000753	Foam (Stored Pressure)	50 litre	IV B	1329i/23
CF-001020	Foam (Stored Pressure)	100 litre	IV B	1329i/24
CF-001022	Foam (Stored Pressure)	135 litre	IV B	1329i/25
CF-000811	ABC 50 Powder (Cartridge Operated)	25 kg	II B	1329i/26
CF-000812	ABC 50 Powder (Cartridge Operated)	50 kg	IV B	1329i/27
CF-000756	Water (Cartridge Operated)	50 litre	-	1329i/28
CF-001032	Water (Cartridge Operated)	50 litre	-	1329i/29
CF-000755	Water (Stored Pressure)	50 litre	-	1329i/30
CF-000886	Water (Stored Pressure)	100 litre	-	1329i/31
CF-000973	Water (Stored Pressure)	135 litre	-	1329i/32

Ceasefire Industries U.K. Limited

Office Number 301.3, One Victoria Square, Birmingham, West Midlands, B1 1BD, United Kingdom

Tel: +44 (0) 113 868 6666 / (0) 1268 919999

Website: www.ceasefire.co.uk

Certificate No: 1329Ai to EN 1866-1:2007, EN 1866-2:2014 & EN 1866-3:2013

'CEASEFIRE' & 'SECUREZONE' Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
000740	CO ₂	20 kg	113 B	1329Ai/20
000754	Foam (Cartridge Operated)	50 litre	IV B	1329Ai/21
001019	Foam (Cartridge Operated)	50 litre	IV B	1329Ai/22
000747	Foam (Stored Pressure)	25 litre	IV B	1329Ai/01
000748	Foam (Stored Pressure)	50 litre	IV B	1329Ai/02
000753	Foam (Stored Pressure)	50 litre	IV B	1329Ai/23
001018	Foam (Stored Pressure)	50 litre	IV B	1329Ai/03
000749	Foam (Stored Pressure)	100 litre	IV B	1329Ai/04
001020	Foam (Stored Pressure)	100 litre	IV B	1329Ai/24
001021	Foam (Stored Pressure)	100 litre	IV B	1329Ai/05
001022	Foam (Stored Pressure)	135 litre	IV B	1329Ai/25
000744	Foam Mist (Stored Pressure)	25 litre	IV B	1329Ai/06
000750	Foam Mist (Stored Pressure)	25 litre	I B	1329Ai/07
000745	Foam Mist (Stored Pressure)	50 litre	IV B	1329Ai/08
000751	Foam Mist (Stored Pressure)	50 litre	IV B	1329Ai/09
000746	Foam Mist (Stored Pressure)	100 litre	IV B	1329Ai/10
000752	Foam Mist (Stored Pressure)	100 litre	IV B	1329Ai/11
000811	ABC 50 Powder (Cartridge Operated)	25 kg	II B	1329Ai/26
000812	ABC 50 Powder (Cartridge Operated)	50 kg	IV B	1329Ai/27
000808	ABC 50 Powder (Stored Pressure)	25 kg	IV B	1329Ai/12
000809	ABC 50 Powder (Stored Pressure)	50 kg	IV B	1329Ai/13
000810	ABC 50 Powder (Stored Pressure)	100 kg	IV B	1329Ai/14
000756	Water (Cartridge Operated)	50 litre	-	1329Ai/28
001032	Water (Cartridge Operated)	50 litre	-	1329Ai/29
000755	Water (Stored Pressure)	50 litre	-	1329Ai/30
001031	Water (Stored Pressure)	50 litre	-	1329Ai/15
000886	Water (Stored Pressure)	100 litre	-	1329Ai/31
001033	Water (Stored Pressure)	100 litre	-	1329Ai/16
000973	Water (Stored Pressure)	135 litre	-	1329Ai/32
000741	Water Mist (Stored Pressure)	25 litre	-	1329Ai/17
000742	Water Mist (Stored Pressure)	50 litre	-	1329Ai/18
000743	Water Mist (Stored Pressure)	100 litre	-	1329Ai/19

COFFCO

PO Box 5, Pincode - 678002, India

Tel: +914912908940

E-mail: coffcoindia@gmail.com • Website: www.coffcofire.com

MOBILE FIRE EXTINGUISHERS

Certificate No: 1092Hc to EN 1866-1

COFFCO Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
CFCO10	CO ₂	10 kg	144 B	1092Hc/01
CFCO20	CO ₂	20 kg	183 B	1092Hc/02
CFCO30	CO ₂	30 kg	183 B	1092Hc/03
CFF50	Foam (Stored Pressure)	50 litre	IV B	1092Hc/04
CFF100	Foam (Stored Pressure)	100 litre	IV B	1092Hc/05
CFDP25	ABC Powder (Stored Pressure)	25 kg	II B	1092Hc/06
CFDP50	ABC Powder (Stored Pressure)	50 kg	IV B	1092Hc/07
CFDP100	ABC Powder (Stored Pressure)	100 kg	IV B	1092Hc/08

EMACO GLOBAL LLC

3118 Beckett Way, Lakeland, FL 33810, USA

Tel: +1 (516) 288-8935

E-mail: info@emacoglobal.com • Website: www.emacoglobal.com

Certificate No: 1092Kc to EN 1866-1:2007

'EMACO' Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
E0803-CD10	CO ₂	10 kg	144 B	1092Kc/01
E0803-CD20	CO ₂	20 kg	183 B	1092Kc/02
E0803-CD30	CO ₂	30 kg	183 B	1092Kc/03
E0804-FM50	Foam (Stored Pressure)	50 litre	IV B	1092Kc/04
E0804-FM100	Foam (Stored Pressure)	100 litre	IV B	1092Kc/05
E0801-PD25	ABC Powder (Stored Pressure)	25 kg	II B	1092Kc/06
E0801-PD50	ABC Powder (Stored Pressure)	50 kg	IV B	1092Kc/07
E0801-PD100	ABC Powder (Stored Pressure)	100 kg	IV B	1092Kc/08

EUROFEU

12 Rue Albert Remy, Senonches, 28250, France

Tel: +33 82090 1818

Website: www.eurofeu.fr

Certificate No: 1092Jc to EN 1866-1:2007

'eurofeu' Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
GT010 CO2	CO ₂	10kg	144 B	1092Jc/01
GT020 CO2	CO ₂	20 kg	183 B	1092Jc/02
GT030 CO2	CO ₂	30 kg	183 B	1092Jc/03
GT050 EPA	Foam (Stored Pressure)	50 litre	IV B	1092Jc/04
GT0100 EPA	Foam (Stored Pressure)	100 litre	IV B	1092Jc/05
GT025 ABC	ABC Powder (Stored Pressure)	25 kg	II B	1092Jc/06
GT050 ABC	ABC Powder (Stored Pressure)	50 kg	IV B	1092Jc/07
GT0100 ABC	ABC Powder (Stored Pressure)	100 kg	IV B	1092Jc/08

Fire King Security and Safety Equipment

Al Juwais Main Road, Ras Al Khaimah, United Arab Emirates

Tel: +971 7 2437050

E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1092Mc to EN 1866-1:2007

'FIREKING' Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
FKCD10	CO ₂	10 kg	144 B	1092Mc/01
FKCD20	CO ₂	20 kg	183 B	1092Mc/02

MOBILE FIRE EXTINGUISHERS

FKCD30	CO ₂	30 kg	183 B	1092Mc/03
FKFM50	Foam (Stored Pressure)	50 litre	IV B	1092Mc/04
FKFM100	Foam (Stored Pressure)	100 litre	IV B	1092Mc/05
FKPD25	ABC Powder (Stored Pressure)	25 kg	II B	1092Mc/06
FKPD50	ABC Powder (Stored Pressure)	50 kg	IV B	1092Mc/07
FKPD100	ABC Powder (Stored Pressure)	100 kg	IV B	1092Mc/08

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building, 738471, Singapore

Tel: +65 6759 4163

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501f to EN 1866-1

Mobile fire extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
C-20C	CO ₂	20 kg	89 B	501f/01
C-30C	CO ₂	30 kg	113 B	501f/02
C-50FTC	Foam (Cartridge Operated)	50 litre	IV B	501f/03
C-100FTC	Foam (Cartridge Operated)	100 litre	IV B	501f/04
C-135FTC	Foam (Cartridge Operated)	135 litre	IV B	501f/05
C-25FTP	Foam (Stored Pressure)	25 litre	II B	501f/06
C-50FTP	Foam (Stored Pressure)	50 litre	II B	501f/07
C-50ATC	ABC Powder (Cartridge Operated)	50 kg	IV B	501f/08
C-100ATC	ABC Powder (Cartridge Operated)	100 kg	IV B	501f/09
C-150ATC	ABC Powder (Cartridge Operated)	150 kg	IV B	501f/10
C-25ATP	ABC Powder (Stored Pressure)	25 kg	II B	501f/11
C-50ATP	ABC Powder (Stored Pressure)	50 kg	II B	501f/12
C-50PTC	Purple K Powder (Cartridge Operated)	50 kg	IV B	501f/13
C-100PTC	Purple K Powder (Cartridge Operated)	100 kg	IV B	501f/14
C-150PTC	Purple K Powder (Cartridge Operated)	150 kg	IV B	501f/15
C-25PTP	Purple K Powder (Stored Pressure)	25 kg	II B	501f/16
C-50PTP	Purple K Powder (Stored Pressure)	50 kg	II B	501f/17
C-25MTC	Monnex Powder (Cartridge Operated)	25 kg	III B	501f/18
C-50MTC	Monnex Powder (Cartridge Operated)	50 kg	III B	501f/19
C-100MTC	Monnex Powder (Cartridge Operated)	100 kg	III B	501f/20

Certificate No: 501g to Technical Approval based upon EN 1866-1

Mobile fire extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
C-75ATC	ABC Powder (Cartridge operated)	75 kg	IVB	501g/02
C-75PTC	Purple K Powder (Cartridge operated)	75 kg	IVB	501g/03

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463m to EN 1866 Parts 1 and 2.

Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
NTFC50X	AFFF foam (GC)	50 litre	IV B	463m/01
NTFC100X	AFFF foam (GC)	100 litre	IV B	463m/02
NTFC135X	AFFF foam (GC)	135 litre	IV B	463m/03
NTP25	ABC Powder (SP)	25 kg	II B	463m/07
NTP50	ABC Powder (SP)	50 kg	IV B	463m/08
NTP100	ABC Powder (SP)	100 kg	IV B	463m/09

MOBILE FIRE EXTINGUISHERS

SensorTech Firefighting and Safety Equipment Trading

P.O.Box 231728, Office No. 506, Al Saud Building, Al Qusais – 4, Dubai, United Arab Emirates

Tel: +971 422 323 31

E-mail: info@sensortechuae.com • Website: www.sensortechuae.com

Certificate No: 1092Lc to EN 1866-1:2007

'WETPLUG' Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
WMC10	CO ₂	10 kg	144 B	1092Lc/01
WMC20	CO ₂	20 kg	183 B	1092Lc/02
WMC30	CO ₂	30 kg	183 B	1092Lc/03
WMF50	Foam (Stored Pressure)	50 litre	IV B	1092Lc/04
WMF100	Foam (Stored Pressure)	100 litre	IV B	1092Lc/05
WMP25	ABC Powder (Stored Pressure)	25 kg	II B	1092Lc/06
WMP50	ABC Powder (Stored Pressure)	50 kg	IV B	1092Lc/07
WMP100	ABC Powder (Stored Pressure)	100 kg	IV B	1092Lc/08

Sentura Group Ltd. (including Fire Depot and Firechief Global)

Sentura House, 3 Lands End Way, Oakham, Rutland, LE15 6RB, United Kingdom

Tel: +44 (0)330 999 22 33

E-mail: sales@firedepot.co.uk • Website: www.firedepot.co.uk

Certificate No: 1093c to EN 1866-1

FIRECHIEF XTR Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
FXF50	Foam (SP)	50 litre	IV B	1093c/04
FXF100	Foam (SP)	100 litre	IV B	1093c/05
FXP25	ABC Powder (SP)	25 kg	II B	1093c/06
FXP50	ABC Powder (SP)	50 kg	IV B	1093c/07
FXP100	ABC Powder (SP)	100 kg	IV B	1093c/08

Yuyao Tianbo Fire Fighting Equipment Co., Ltd.

Baishuicong Industrial Park, Lianglong Town, Yuyao City, Zhejiang, China

Tel: +86-21-61602389

E-mail: export@yytianbo.cn • Website: www.yytianbo.cn

Certificate No: 1092c to EN 1866-1:2007

Mobile Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
TMFM50	Foam (Stored Pressure)	50 litre	IV B	1092c/04
TMFM100	Foam (Stored Pressure)	100 litre	IV B	1092c/05
TMPD25	ABC Powder (Stored Pressure)	25 kg	II B	1092c/06
TMPD50	ABC Powder (Stored Pressure)	50 kg	IV B	1092c/07
TMPD100	ABC Powder (Stored Pressure)	100 kg	IV B	1092c/08
TMCD10	CO ₂ (Stored Pressure)	10 kg	144 B	1092c/01
TMCD20	CO ₂ (Stored Pressure)	20 kg	183 B	1092c/02
TMCD30	CO ₂ (Stored Pressure)	30 kg	183 B	1092c/03

Zhejiang Ruihua Machinery Co. Ltd

No. 1 Fengqixi Road, Western Industrial Zone, Linshan Town, Yuyao, Zhejiang, 315460, China

Tel: 0086 1350 578 4280

E-mail: jingxingli@ruihuafire.com

Certificate No: 867c to EN 1866-1

MOBILE FIRE EXTINGUISHERS

Mobile fire extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
P25TG	ABC Powder (Stored Pressure)	25 kg	II B	867c/01
P50TG	ABC Powder (Stored Pressure)	50 kg	IV B	867c/02

PILLAR FIRE HYDRANTS

The purpose of a fire hydrant installation is to provide a connection to the water main to which the fire fighter can connect firefighting equipment. Pillar fire hydrants consist of one or more valves and connection outlets in a column shape, which emerges from below ground level, intended primarily to supply water for firefighting and also may be used by water utilities.

Pillar fire hydrants are tested to EN 14384.

This section lists products approved in accordance with:

EN 14384 - *Pillar fire hydrants*

Brake Fire Safety and Security

Building 8, Industrial Area / 1 Amman Street, Ajman, United Arab Emirates

Tel: +971 551 668 286

E-mail: info@brakefiregcc.com • Website: www.brakefiregcc.com

Certificate No: 1280Ia to EN 14384:2005

'BRAKE FIRE' Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
BFHD-4"-P	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ia/01
BFHD-6"-P	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ia/04

Bristol Fire Engineering LLC

Al Quoz Industrial Area 3, P.O.Box 74582, Dubai, United Arab Emirates

Tel: +971 4 347 2426

E-mail: sami@bristol-fire.com • Website: www.bristol-fire.com

Certificate No: 1280Fa to EN 14384:2005

'BRISTOL' Pillar fire hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
BFE04	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Fa/06
BFE06	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Fa/08

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 1280Aa to EN 14384:2005

Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
FX16-117S	4" (DN 100)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Aa/01
FX16-082S	4" (DN 100)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Aa/02
FX16-083S	6" (DN 150)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Aa/03
FX16-117T	6" (DN 150)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Aa/04

Eversafe Extinguisher Sdn Bhd

Lot 878, Jalan Subang 9, Taman Perindustrian Subang, Subang Jaya, Selangor Darul Ehsan, 47500, Malaysia

Tel: +603 8024 9898

E-mail: info@eversafe.net • Website: www.eversafe.net

Certificate No: 1280Ga to EN 14384:2005

PILLAR FIRE HYDRANTS

Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
EE16-117S	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ga/01
EE16-082S	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ga/02
EE16-083S	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ga/03
EE16-117T	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ga/04
EE16-082T	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ga/05
EE16-117U	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ga/06
EE16-083T	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ga/07
EE16-117V	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ga/08

Exon For Fire Protection Inc.

615 Remnor Ave, Ottawa, Ontario, K2T 0A6, Canada

Tel: +613 276 7755

E-mail: info@exonfire.com • Website: www.exonfire.com

Certificate No: 1280Da to EN 14384:2005

EZULA Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
EX16-117S	4" (DN 100)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Da/01
EX16-082S	4" (DN 100)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Da/02
EX16-083S	6" (DN 150)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Da/03
EX16-117T	6" (DN 150)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Da/04

Fireguard Global Ltd.

Unit 11 Chancel Industrial Estate, Newhall Street, Willenhall, West Midlands, WV13 1NX, United Kingdom

Tel: +44 (0)8450 751042

E-mail: info@fireguard-uk.com • Website: www.fireguard-uk.com

Certificate No: 1280Ha to EN 14384:2005

'FIREGUARD' Pillar fire hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
FGDH100	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ha/02
FGDH150	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ha/03

Mazen Abdulsalam Jadid Factory For Manufacturing Safety Equipment

Industrial City No. 3, Jazan Road, Jeddah, Kingdom of Saudi Arabia

Tel: +966 506 667 516

E-mail: mafco2000@gmail.com

Certificate No: 1280Ka to EN 14384:2005

'MAFCO' Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
MAFH4	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ka/02
MAFH6	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ka/03

Melton Egypt

Block 20003, 3rd Plot, El Obour, Industrial Zone, Cairo, Egypt

Tel: +202 4489 2078

E-mail: info@melton-eg.com • Website: www.melton-eg.com

Certificate No: 1280Ja to EN 14384:2005

PILLAR FIRE HYDRANTS

'MELTON' Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
MT-3FH-4	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ja/02
MT-3FH-6	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ja/03

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463n to EN 14384

Pillar Fire Hydrants

Product Name	Inlet size	Hose Outlet	Pumper Outlet	LPCB Ref. No.
100 NHC - 800	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/01
100 NHC - 1200	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/02
100 NFHV - 800	4" (DN 100)	2 x 2½" straight landing valve with BS 336 quick coupling	1 x G4" (100mm)	463n/03
100 NFHV - 1200	4" (DN 100)	2 x 2½" straight landing valve with BS 336 quick coupling	1 x G4" (100mm)	463n/04
150 NFHV - 800	6" (DN 150)	2 x 2½" straight landing valve with BS 336 quick coupling	1 x G4" (100mm)	463n/05
150 NFHV - 1200	6" (DN 150)	2 x 2½" straight landing valve with BS 336 quick coupling	1 x G4" (100mm)	463n/06
100 NFHQ - 800	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/07
100 NFHQ - 1200	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/08
150 NFHQ - 800	6" (DN 150)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/09
150 NFHQ - 1200	6" (DN 150)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/10
100 NFHQC - 800	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/11
100 NFHQC - 1200	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/12
150 NFHQC - 800	6" (DN 150)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/13
150 NFHQC - 1200	6" (DN 150)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/14
100 NFHQSC-CD - 800	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/15
150 NFHQSC-CD - 1200	6" (DN 150)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/18
100 NFHQSC-CD - 1200	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/16
150 NFHQSC-CD - 800	6" (DN 100)	2 x G2½" BS 336 quick coupling	1 x G4" (100mm)	463n/17
100NFHQV-CD1	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 v G4" (100 mm)	463n/19
100NFHQV-CD2	4" (DN 100)	2 x G2½" BS 336 quick coupling	1 v G4" (100 mm)	463n/20
150NFHQV-CD1	6" (DN 150)	2 x G2½" BS 336 quick coupling	1 v G4" (100 mm)	463n/21
150NFHQV-CD2	6" (DN 150)	2 x G2½" BS 336 quick coupling	1 v G4" (100 mm)	463n/22

National Factory for Security & Safety Equipment LLC

P.O.Box 129, Road No. 19, Ind. Estate, Al Rusayl, PC 124, Sultanate of Oman

Tel: +968 2444 6268

E-mail: sales@amancoglobal.com • Website: www.amancoglobal.com

Certificate No: 1280Ca to EN 14384:2005

AMANCO Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
AFH4-DR	4" (DN 100)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ca/02
AFH6-DR	6" (DN 150)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ca/03

Ningbo Kaixuan Fire Control Equipment Co., Ltd.

No. 999 Zhonghe Road, Huangjiabu Town, Yuyao City, Zhejiang Province, 315466, China

Tel: +86 574 62025710

E-mail: info@kaixuanfire.com • Website: www.kaixuanfire.com

Certificate No: 1280a to EN 14384:2005

'FLAMETECH' Pillar fire hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
FT16-117S	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280a/01
FT16-082S	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280a/02

PILLAR FIRE HYDRANTS

FT16-083S	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280a/03
FT16-117T	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280a/04
FT16-082T	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280a/05
FT16-117U	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280a/06
FT16-083T	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280a/07
FT16-117V	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280a/08

SFFECO GLOBAL FZE

S-10833, Jebel Ali Free Zone, Authority South 1, Dubai, 261318, United Arab Emirates

Tel: +971 4 880 9890

E-mail: info@sffecoglobal.com • Website: www.sffecoglobal.com

Certificate No: 1280Ba to EN 14384:2005

SFFECO Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
SFH100-LPLD	4" (DN 100)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ba/01
SFH100-LPHD	4" (DN 100)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ba/02
SFH150-LPHD	6" (DN 150)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ba/03
SFH150-LPLD	6" (DN 150)	2 x 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280Ba/04
SFH100-LPHDAT	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ba/05
SFH100-LPLDAT	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ba/06
SFH150-LPHDAT	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ba/07
SFH150-LPLDAT	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280Ba/08

The Viking Corporation

210 N Industrial Park, Hastings, Michigan 49058, USA

Tel: +1 269 945 9501

E-mail: techsvcs@vikingcorp.com • Website: www.vikingcorp.com

Certificate No: 096w to EN 14384:2005

Viking Corp Firing Pillar Fire Hydrants

Product Name	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
HYF5	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	096w/01
HYF2	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	096w/02
HYF3	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	096w/03
HYF4	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	096w/04

Watania For Modern Industries

3rd Industrial Zone, Borg Elarab, Alexandria, Egypt

Tel: +20 3585 7006

E-mail: watania@wataniagroup.net • Website: www.wataniagroup.net

Certificate No: 1280La to EN 14384:2005

'WATANIA' Pillar Fire Hydrants

Product Name	Model	Inlet size	Hose outlet	Pumper	LPCB Ref. No.
Pillar Fire Hydrants	WFE04/117S	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280La/01
Pillar Fire Hydrants	WFE04/S	4" (DN 100)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280La/02
Pillar Fire Hydrants	WFE06/S	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280La/03
Pillar Fire Hydrants	WFE06/117T	6" (DN 150)	2 X 2.5" BSP (65mm)	1 x 4" BSP (100mm)	1280La/04
Pillar Fire Hydrants	WFE04/T	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280La/05
Pillar Fire Hydrants	WFE04/117U	4" (DN 100)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280La/06
Pillar Fire Hydrants	WFE06/T	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280La/07
Pillar Fire Hydrants	WFE06/117V	6" (DN 150)	2 X 2.5" BS 336 (delivery hose connector)	1 x 4" BSP (100mm)	1280La/08

PORTABLE FIRE EXTINGUISHERS

Portable fire extinguishers are manufactured to suit different types of fires and should be selected, sited, serviced and maintained in accordance with the relevant code of practice. Third party approval of the portable fire extinguisher will help to ensure that they will function correctly if properly maintained, it will also demonstrate due diligence in supporting risk assessed based legislation.

LPCB approval helps to ensure that fire extinguishers meet and continue to meet appropriate standards. LPCB approval includes testing of the individual component parts of the fire extinguisher, pressure safety of the vessel, correct labelling and operation instructions and the satisfactory performance of the extinguisher when tested to the relevant fire test. These elements are continuously monitored during regular factory production control (FPC) surveillance audits.

CE marking may be found on a portable fire extinguisher as required by the European Union - Pressure Equipment Directive (PED) but should not be confused with LPCB approval. This directive has been published for products that are to be sold within the European Union (EU) and it requires proof of safety of the pressure vessel. The CE mark placed on a fire extinguisher demonstrates conformance with this pressure safety requirement and fire testing is not carried out as part of this directive.

Caution: To be sure of reliable, proven, performance of the fire extinguisher in fire conditions, the extinguisher should carry independent proof of performance, such as the LPCB mark, and if it is to be supplied into the EU the additional CE mark will also be required as defined by the PED.

The test standards used for LPCB certification of portable fire extinguishers are:

EN 3-7 +A1	<i>Characteristics, performance requirements and test methods</i>
EN 3-8	<i>Additional requirements to EN 3-7 for the construction, resistance to pressure and mechanical tests for extinguishers with a maximum allowable pressure equal to or lower than 30 bar</i>
EN 3-9	<i>Additional requirements to EN 3-7 for pressure resistance of CO₂ extinguishers</i>
EN 3-10	<i>Provisions for evaluating the conformity of a portable fire extinguisher to EN 3-7</i>

Abbreviations used for LPCB listing of portable fire extinguishers

LPCB use the following abbreviations in the RedBook listings for portable fire extinguishers.

Extinguishing Agent	
W - Water	WB - Water based (water plus additive)
ABC or BC - Dry powder	CO ₂ - Carbon Dioxide
CA - Clean Agent	WC - Wet Chemical
Method of Actuation	
SP - Stored pressure actuation	GC - Gas cartridge actuation
Units or Capacity	
kg - Kilogram	l - litre

Labelling

A requirement of EN 3 is that each portable fire extinguisher must be clearly labelled to identify the classes of fire for which they have demonstrated satisfactory performance as defined in EN 3. In summary:

Class A :	for use on flammable solid materials, for example wood, paper, coal, straw, cloth etc.
Class B :	for use on fires involving flammable liquids or liquefiable solids.
Class C :	for fires involving gases.
Class D :	for fires involving metals for example magnesium, sodium, cadmium, manganese.
Class F :	for use on cooking oil fires.

Colour Coding

EN 3-7 permits a zone of colour of up to 10% of the external area of the extinguisher body to be used to identify the extinguishing agent in accordance with national specifications.

Colour coding of portable fire extinguishers is not mandatory in the UK, however BS 5306-10: *Colour coding to indicate the extinguishing medium contained in portable fire extinguishers*, was published to provide a consistent approach where colour coding is used.

PORTABLE FIRE EXTINGUISHERS

Associated Enterprises (S) Pte Ltd.

Block 28, Sin Ming Drive, #01-173, 575702, Singapore

Tel: +65-64550555

E-mail: enquiry@aespl.com.sg • Website: www.aespl.com.sg

Certificate No: 1092Aa to EN3 Parts 7,8 and 9

Portable fire extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
PRO-2-FOAM	Foam (SP)	2 litre	8A/55B	1092Aa/14
PRO-6-FOAM	Foam (SP)	6 litre	21A/144B	1092Aa/17
PRO-9-FOAM	Foam (SP)	9 litre	27A/233B	1092Aa/19
PRO-1-DC	ABC Powder (SP)	1 kg	8A/34B	1092Aa/01
PRO-2-DC	ABC Powder (SP)	2 kg	13A/89B	1092Aa/05
PRO-3-DC	ABC Powder (SP)	3 kg	21A/113B	1092Aa/07
PRO-4-DC	ABC Powder (SP)	4 kg	27A/144B	1092Aa/08
PRO-6-DC	ABC Powder (SP)	6 kg	43A/233B	1092Aa/09
PRO-9-DC	ABC Powder (SP)	9 kg	55A/233B	1092Aa/11
PRO-12-DC	ABC Powder (SP)	12 kg	55A/233B	1092Aa/12
PRO-6-W	Water (SP)	6 litre	13A	1092Aa/24
PRO-9-W	Water (SP)	9 litre	21A	1092Aa/25
PRO-2-WC	Wet Chemical (SP)	2 litre	8A/34B/25F	1092Aa/21
PRO-6-WC	Wet Chemical (SP)	6 litre	21A/113B/75F	1092Aa/23
PRO-2-CD-AL	CO ₂	2 kg	34B	1092Aa/30
PRO-2-CD	CO ₂	2 kg	34B	1092Aa/31
PRO-5-CD-AL	CO ₂	5 kg	70B	1092Aa/32
PRO-5-CD	CO ₂	5 kg	70B	1092Aa/33
PRO-3-WC	Wet Chemical (SP)	3 litre	13A/70B/40F	1092Aa/22

Ceasefire Industries Private Limited

E6, Selaqui Industrial Area, Dehradun, Uttarakhand, 248011, India

Tel: +911204223473

E-mail: amit@ceasefire.in

Certificate No: 1329b to EN 3-7:2004+A1:2007, EN 3-8:2006 & EN 3-9:2006

'CEASEFIRE' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
CF-000722	ABC 90 Powder (SP)	2 kg	13A / 55B	1329b/01
CF-000723	ABC 90 Powder (SP)	4 kg	21A / 144B	1329b/02
CF-000724	ABC 90 Powder (SP)	6 kg	27A / 183B	1329b/03
CF-000725	ABC 90 Powder (SP)	9 kg	43A / 233B	1329b/04
CF-000737	BC Powder (SP)	4 kg	233B	1329b/05
CF-000738	BC Powder (SP)	6 kg	233B	1329b/06
CF-000706	Clean Agent (SP)	4 kg	34B	1329b/07
CF-000707	Clean Agent (SP)	6 kg	34B	1329b/08
CF-000779	Foam (SP)	3 litre	8A / 89B	1329b/09
CF-000805	Foam (SP)	3 litre	8A / 89B	1329b/10
CF-000715	Foam (SP)	6 litre	13A / 144B	1329b/11
CF-000806	Foam (SP)	6 litre	13A / 144B	1329b/12
CF-000716	Foam (SP)	9 litre	21A / 233B	1329b/13
CF-000807	Foam (SP)	9 litre	21A / 233B	1329b/14
CF-000838	Foam Mist (SP)	2 litre	5A / 34B / 25F	1329b/15
CF-000696	Foam Mist (SP)	2 litre	5A / 55B / 25F	1329b/16
CF-000839	Foam Mist (SP)	6 litre	13A / 113B / 40F	1329b/17
CF-000698	Foam Mist (SP)	6 litre	13A / 144B / 40F	1329b/18
CF-000732	ABC 50 Powder (SP)	4 kg	21A / 144B	1329b/19
CF-000733	ABC 50 Powder (SP)	6 kg	27A / 183B	1329b/20
CF-000734	ABC 50 Powder (SP)	9 kg	43A / 233B	1329b/21
CF-000717	Water (SP)	6 litre	13A	1329b/22
CF-000798	Water (SP)	6 litre	13A	1329b/23
CF-000718	Water (SP)	9 litre	21A	1329b/24
CF-000709	Water Mist (SP)	2 litre	5A / 25F	1329b/25
CF-000710	Water Mist (SP)	3 litre	8A / 25F	1329b/26
CF-000711	Water Mist (SP)	6 litre	13A / 75F	1329b/27
CF-000712	Water Mist (SP)	9 litre	21A / 75F	1329b/28
CF-000780	Wet Chemical (SP)	3 litre	8A / 40F	1329b/29

PORTABLE FIRE EXTINGUISHERS

CF-000719	Wet Chemical (SP)	6 litre	13A / 75F	1329b/30
CF-000720	Wet Chemical (SP)	9 litre	21A / 75F	1329b/31
CF-000700	CO ₂	2 kg	34B	1329b/32
CF-000702	CO ₂	2 kg	34B	1329b/33
CF-000701	CO ₂	5 kg	70B	1329b/34
CF-000703	CO ₂	5 kg	70B	1329b/35
CF-000705	Clean Agent (SP)	2 kg	21B	1329b/36
CF-000849	Clean Agent (SP)	2 kg	21B	1329b/37
CF-000850	Clean Agent (SP)	4 kg	21B	1329b/38
CF-000851	Clean Agent (SP)	6 kg	34B	1329b/39
CF-000708	Clean Agent (SP)	9 kg	55B	1329b/40
CF-000852	Clean Agent (SP)	9 kg	55B	1329b/41
CF-000730	ABC 50 Powder (SP)	1 kg	5A / 34B	1329b/42
CF-000803	ABC 50 Powder (SP)	1 kg	5A / 34B	1329b/43
CF-000731	ABC 50 Powder (SP)	2 kg	8A / 70B	1329b/44
CF-000804	ABC 50 Powder (SP)	2 kg	8A / 70B	1329b/45
CF-000721	ABC 90 Powder (SP)	1 kg	5A / 21B	1329b/46
CF-000736	BC Powder (SP)	2 kg	89B	1329b/47
CF-000739	BC Powder (SP)	9 kg	233B	1329b/48
CF-000800	Wet Chemical (SP)	3 litre	8A / 40F	1329b/49
CF-000801	Wet Chemical (SP)	6 litre	13A / 75F	1329b/50
CF-000802	Wet Chemical (SP)	9 litre	21A / 75F	1329b/51
CF-000735	ABC 50 Powder (SP)	12 kg	55A / 233B	1329b/52
CF-000726	ABC 90 Powder (SP)	12 kg	55A / 233B	1329b/53
CF-000799	Water (SP)	9 litre	21A	1329b/54
CF-000805S	Foam Spray (SP)	3 litre	8A/89B/25F	1329b/60
CF-000779S	Foam Spray (SP)	3 litre	8A/89B/25F	1329b/59
CF-000806S	Foam Spray (SP)	6 litre	13A/144B/40F	1329b/62
CF-000715S	Foam Spray (SP)	6 litre	13A/144B/40F	1329b/61
CF-000807S	Foam Spray (SP)	9 litre	21A/233B/75F	1329b/64
CF-000716S	Foam Spray (SP)	9 litre	21A/233B/75F	1329b/63
CF-000717S	Water Spray (SP)	6 litre	13A/25F	1329b/55
CF-000718S	Water Spray (SP)	9 litre	21A/40F	1329b/56
CF-000798S	Water Spray (SP)	6 litre	13A/25F	1329b/57
CF-000799S	Water Spray (SP)	9 litre	21A/40F	1329b/58
CF-001335	Clean Agent FK-5-1-12 (SP)	6 kg	34B	1329b/67
CF-001333	Clean Agent FK-5-1-12 (SP)	2 kg	21B	1329b/65
CF-001334	Clean Agent FK-5-1-12 (SP)	4 kg	34B	1329b/66
CF-001336	Clean Agent FK-5-1-12 (SP)	9 kg	55B	1329b/68
CF-001479	Fluorine free foam (SP)	3 litre	8A/55B	1329b/69
CF-001480	Fluorine free foam (SP)	6 litre	13A/113B	1329b/70
CF-001482	Wet Chemical Spray (SP)	3 litre	8A/40F	1329b/72
CF-001481	Fluorine free foam (SP)	9 litre	21A/183B	1329b/71
CF-001483	Wet Chemical Spray (SP)	6 litre	13A/75F	1329b/73
CF-001503	Wet Chemical Spray (SP)	9 litre	21A/75F	1329b/77
CF-001501	Wet Chemical Spray (SP)	3 litre	8A/40F	1329b/75
CF-001502	Wet Chemical Spray (SP)	6 litre	13A/75F	1329b/76
CF-001484	Wet Chemical Spray (SP)	9 litre	21A/75F	1329b/74
CF-000706C	Clean Agent (SP)	4 kg	21B	1329b/80
CF-000707C	Clean Agent (SP)	6 kg	34B	1329b/81
CF-000700C	CO ₂	2 kg	34B	1329b/78
CF-000708C	Clean Agent (SP)	9 kg	55B	1329b/82
CF-000701C	CO ₂	5 kg	70B	1329b/79

Certificate No: 1329g to a Technical Approval based upon EN 3 Parts 7, 8 & 9 with the exception of EN 3-7 clause 16.1 - Colour

'CEASEFIRE' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
CF-000984	CO ₂	2 kg	34B	1329g/32
CF-000985	CO ₂	5 kg	70B	1329g/34
CF-000986	Foam (SP)	6 litre	13A / 144B	1329g/11
CF-000987	Foam (SP)	9 litre	21A / 233B	1329g/13
CF-000990	ABC 50 Powder (SP)	6 kg	27A / 183B	1329g/20
CF-000991	ABC 50 Powder (SP)	9 kg	43A / 233B	1329g/21
CF-001105	ABC 90 Powder (SP)	1 kg	5A / 21B	1329g/46-1
CF-001106	ABC 90 Powder (SP)	1 kg	5A / 21B	1329g/46-2
CF-001107	ABC 90 Powder (SP)	1 kg	5A / 21B	1329g/46-3
CF-001185	ABC 90 Powder (SP)	1 kg	5A / 21B	1329g/46-4
CF-000988	Water (SP)	6 litre	13A	1329g/22
CF-000989	Water (SP)	9 litre	21A	1329g/24
CF-001180	Wet Chemical (SP)	3 litre	8A / 40F	1329g/29
CF-001181	Wet Chemical (SP)	6 litre	13A / 75F	1329g/30

PORTABLE FIRE EXTINGUISHERS

CF-001182

Wet Chemical (SP)

9 litre

21A / 75F

1329g/31

Certificate No: 1329h to a Technical Approval based upon EN 3 Parts 7, 8 & 9 with the exception of EN 3-7 clause 16.2 - Marking

'CEASEFIRE' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
CF-001108	CO ₂	2 kg	34B	1329h/32
CF-001109	CO ₂	2 kg	34B	1329h/33
CF-001110	Clean Agent (SP)	2 kg	21B	1329h/36
CF-001111	Clean Agent (SP)	2 kg	21B	1329h/37
CF-001112	Clean Agent (SP)	4 kg	34B	1329h/07
CF-001113	Clean Agent (SP)	4 kg	21B	1329h/38
CF-001114	Clean Agent (SP)	6 kg	34B	1329h/08
CF-001115	Clean Agent (SP)	6 kg	34B	1329h/39
CF-001125	Foam (SP)	6 litre	13A / 144B	1329h/11
CF-001126	Foam (SP)	6 litre	13A / 144B	1329h/12
CF-001127	Foam (SP)	9 litre	21A / 233B	1329h/13
CF-001128	Foam (SP)	9 litre	21A / 233B	1329h/14
CF-001121	Foam Mist (SP)	2 litre	5A / 55B / 25F	1329h/16
CF-001122	Foam Mist (SP)	6 litre	13A / 144B / 40F	1329h/18
CF-001137	ABC 50 Powder (SP)	1 kg	5A / 34B	1329h/42
CF-001137SG	ABC 50 Powder (SP)	1 kg	5A / 34B	1329h/43
CF-001138	ABC 50 Powder (SP)	2 kg	8A / 70B	1329h/44
CF-001138SG	ABC 50 Powder (SP)	2 kg	8A / 70B	1329h/45
CF-001139	ABC 50 Powder (SP)	4 kg	21A / 144B	1329h/19
CF-001140	ABC 50 Powder (SP)	6 kg	27A / 183B	1329h/20
CF-001141	ABC 50 Powder (SP)	9 kg	43A / 233B	1329h/21
CF-001142	ABC 90 Powder (SP)	1 kg	5A / 21B	1329h/46
CF-001143	ABC 90 Powder (SP)	2 kg	13A / 55B	1329h/01
CF-001144	ABC 90 Powder (SP)	4 kg	21A / 144B	1329h/02
CF-001145	ABC 90 Powder (SP)	6 kg	27A / 183B	1329h/03
CF-001146	ABC 90 Powder (SP)	9 kg	43A / 233B	1329h/04
CF-001147	BC Powder (SP)	2 kg	89B	1329h/47
CF-001149	BC Powder (SP)	4 kg	233B	1329h/05
CF-001150	BC Powder (SP)	6 kg	233B	1329h/06
CF-001148	BC Powder (SP)	9 kg	233B	1329h/48
CF-001129	Water (SP)	6 litre	13A	1329h/22
CF-001130	Water (SP)	6 litre	13A	1329h/23
CF-001131	Water (SP)	9 litre	21A	1329h/24
CF-001132	Water (SP)	9 litre	21A	1329h/54
CF-001118	Water Mist (SP)	2 litre	5A / 25F	1329h/25
CF-001119	Water Mist (SP)	6 litre	13A / 75F	1329h/27
CF-001120	Water Mist (SP)	9 litre	21A / 75F	1329h/28
CF-001133	Wet Chemical (SP)	6 litre	13A / 75F	1329h/30
CF-001135	Wet Chemical (SP)	6 litre	13A / 75F	1329h/50
CF-001134	Wet Chemical (SP)	9 litre	21A / 75F	1329h/31
CF-001136	Wet Chemical (SP)	9 litre	21A / 75F	1329h/51

Ceasefire Industries U.K. Limited

Office Number 301.3, One Victoria Square, Birmingham, West Midlands, B1 1BD, United Kingdom

Tel: +44 (0) 113 868 6666 / (0) 1268 919999

Website: www.ceasefire.co.uk

Certificate No: 1329Ab to EN 3-7:2004+A1:2007, EN 3-8:2006 & EN 3-9:2006

'CEASEFIRE' & 'SECUREZONE' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
000700	CO ₂	2 kg	34B	1329Ab/32
000702	CO ₂	2 kg	34B	1329Ab/33
000701	CO ₂	5 kg	70B	1329Ab/34
000703	CO ₂	5 kg	70B	1329Ab/35
000705	Clean Agent (SP)	2 kg	21B	1329Ab/36
000849	Clean Agent (SP)	2 kg	21B	1329Ab/37
000706	Clean Agent (SP)	4 kg	34B	1329Ab/07
000850	Clean Agent (SP)	4 kg	21B	1329Ab/38
000707	Clean Agent (SP)	6 kg	34B	1329Ab/08
000851	Clean Agent (SP)	6 kg	34B	1329Ab/39
000708	Clean Agent (SP)	9 kg	55B	1329Ab/40

PORTABLE FIRE EXTINGUISHERS

000852	Clean Agent (SP)	9 kg	9 kg	1329Ab/41
000779	Foam (SP)	3 litre	8A / 89B	1329Ab/09
000805	Foam (SP)	3 litre	8A / 89B	1329Ab/10
000715	Foam (SP)	6 litre	13A / 144B	1329Ab/11
000806	Foam (SP)	6 litre	13A / 144B	1329Ab/12
000716	Foam (SP)	9 litre	21A / 233B	1329Ab/13
000807	Foam (SP)	9 litre	21A / 233B	1329Ab/14
000838	Foam Mist (SP)	2 litre	5A / 34B / 25F	1329Ab/15
000696	Foam Mist (SP)	2 litre	5A / 55B / 25F	1329Ab/16
000839	Foam Mist (SP)	6 litre	13A / 113B / 40F	1329Ab/17
000698	Foam Mist (SP)	6 litre	13A / 144B / 40F	1329Ab/18
000730	ABC 50 Powder (SP)	1 kg	5A / 34B	1329Ab/42
000803	ABC 50 Powder (SP)	1 kg	5A / 34B	1329Ab/43
000731	ABC 50 Powder (SP)	2 kg	8A / 70B	1329Ab/44
000804	ABC 50 Powder (SP)	2 kg	8A / 70B	1329Ab/45
000732	ABC 50 Powder (SP)	4 kg	21A / 144B	1329Ab/19
000733	ABC 50 Powder (SP)	6 kg	27A / 183B	1329Ab/20
000734	ABC 50 Powder (SP)	9 kg	43A / 233B	1329Ab/21
000735	ABC 50 Powder (SP)	12 kg	55A / 233B	1329Ab/52
000721	ABC 90 Powder (SP)	1 kg	5A / 21B	1329Ab/46
000722	ABC 90 Powder (SP)	2 kg	13A / 55B	1329Ab/01
000723	ABC 90 Powder (SP)	4 kg	21A / 144B	1329Ab/02
000724	ABC 90 Powder (SP)	6 kg	27A / 183B	1329Ab/03
000725	ABC 90 Powder (SP)	9 kg	43A / 233B	1329Ab/04
000726	ABC 90 Powder (SP)	12 kg	55A / 233B	1329Ab/53
000736	BC Powder (SP)	2 kg	89B	1329Ab/47
000737	BC Powder (SP)	4 kg	233B	1329Ab/05
000738	BC Powder (SP)	6 kg	233B	1329Ab/06
000739	BC Powder (SP)	9 kg	233B	1329Ab/48
000717	Water (SP)	6 litre	13A	1329Ab/22
000798	Water (SP)	6 litre	13A	1329Ab/23
000718	Water (SP)	9 litre	21A	1329Ab/24
000799	Water (SP)	9 litre	21A	1329Ab/54
000709	Water Mist (SP)	2 litre	5A / 25F	1329Ab/25
000710	Water Mist (SP)	3 litre	8A / 25F	1329Ab/26
000711	Water Mist (SP)	6 litre	13A / 75F	1329Ab/27
000712	Water Mist (SP)	9 litre	21A / 75F	1329Ab/28
000780	Wet Chemical (SP)	3 litre	8A / 40F	1329Ab/29
000800	Wet Chemical (SP)	3 litre	8A / 40F	1329Ab/49
000719	Wet Chemical (SP)	6 litre	13A / 75F	1329Ab/30
000801	Wet Chemical (SP)	6 litre	13A / 75F	1329Ab/50
000720	Wet Chemical (SP)	9 litre	21A / 75F	1329Ab/31
000802	Wet Chemical (SP)	9 litre	21A / 75F	1329Ab/51

Certificate No: 1329Ag to a Technical Approval based upon EN 3 Parts 7, 8 & 9 with the exception of EN 3-7 clause 16.1 - Colour

'CEASEFIRE' & 'SECUREZONE' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
000984	CO ₂	2 kg	34B	1329Ag/32
000985	CO ₂	5 kg	70B	1329Ag/34
000986	Foam (SP)	6 litre	13A / 144B	1329Ag/11
000987	Foam (SP)	9 litre	21A / 233B	1329Ag/13
000990	ABC 50 Powder (SP)	6 kg	27A / 183B	1329Ag/20
000991	ABC 50 Powder (SP)	9 kg	43A / 233B	1329Ag/21
001105	ABC 90 Powder (SP)	1 kg	5A / 21B	1329Ag/46-1
001106	ABC 90 Powder (SP)	1 kg	5A / 21B	1329Ag/46-2
001107	ABC 90 Powder (SP)	1 kg	5A / 21B	1329Ag/46-3
001185	ABC 90 Powder (SP)	1 kg	5A / 21B	1329Ag/46-4
000988	Water (SP)	6 litre	13A	1329Ag/22
000989	Water (SP)	9 litre	21A	1329Ag/24
001180	Wet Chemical (SP)	3 litre	8A / 40F	1329Ag/29
001181	Wet Chemical (SP)	6 litre	13A / 75F	1329Ag/30
001182	Wet Chemical (SP)	9 litre	21A / 75F	1329Ag/31

EMACO GLOBAL LLC

3118 Beckett Way, Lakeland, FL 33810, USA

Tel: +1 (516) 288-8935

E-mail: info@emacoglobal.com • Website: www.emacoglobal.com

PORTABLE FIRE EXTINGUISHERS

Certificate No: 1092Ka to EN 3 Parts 7, 8 & 9

'EMACO' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
E0803-CD2	CO ₂	2 kg	34B	1092Ka/31
E0803-CD5	CO ₂	5 kg	70B	1092Ka/33
E0804-FM6S	Foam (SP)	6 litre	21A/144B	1092Ka/17
E0804-FM9S	Foam (SP)	9 litre	27A/233B	1092Ka/19
E0801-PD1E	ABC Powder (SP)	1 kg	8A/34B	1092Ka/01
E0801-PD2S	ABC Powder (SP)	2 kg	13A/89B	1092Ka/05
E0801-PD4S	ABC Powder (SP)	4 kg	27A/144B	1092Ka/08
E0801-PD6S	ABC Powder (SP)	6 kg	43A/233B	1092Ka/09
E0801-PD9S	ABC Powder (SP)	9 kg	55A/233B	1092Ka/11
E0801-PD12	ABC Powder (SP)	12 kg	55A/233B	1092Ka/12
E0802-WT6	Water (SP)	6 litre	13A	1092Ka/24
E0802-WT9	Water (SP)	9 litre	21A	1092Ka/25

Fire King Security and Safety Equipment

Al Juwais Main Road, Ras Al Khaimah, United Arab Emirates

Tel: +971 7 2437050

E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1092Ma to EN 3 Parts 7, 8 & 9

'FIREKING' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
FKCD2	CO ₂	2 kg	34B	1092Ma/31
FKCD5	CO ₂	5 kg	70B	1092Ma/33
FKFM6	Foam (SP)	6 litre	21A/144B	1092Ma/17
FKFM9	Foam (SP)	9 litre	27A/233B	1092Ma/19
FKPD1	ABC Powder (SP)	1 kg	8A/34B	1092Ma/01
FKPD2	ABC Powder (SP)	2 kg	13A/89B	1092Ma/05
FKPD4	ABC Powder (SP)	4 kg	27A/144B	1092Ma/08
FKPD6	ABC Powder (SP)	6 kg	43A/233B	1092Ma/09
FKPD9	ABC Powder (SP)	9 kg	55A/233B	1092Ma/11
FKPD12	ABC Powder (SP)	12 kg	55A/233B	1092Ma/12
FKWT6	Water (SP)	6 litre	13A	1092Ma/24
FKWT9	Water (SP)	9 litre	21A	1092Ma/25
FKWC3	Wet Chemical (SP)	3 litre	13A/70B/40F	1092Ma/22
FKWC6	Wet Chemical (SP)	6 litre	21A/113B/75F	1092Ma/23

Firemark Ltd.

BFF Business Park, Bath Road, Bridgwater, Somerset, TA6 4NZ, United Kingdom

Tel: +44 (0)1278 727460

E-mail: sales@firemark-ltd.co.uk • Website: www.firemark-ltd.co.uk

Certificate No: 867Ca to EN 3 Parts 7, 8 and 9

FIREMARK Portable Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
C2/1S	CO ₂	2 kg	34B	867Ca/10
C5/1S	CO ₂	5 kg	89B	867Ca/11
F6/1	Foam (SP)	6 litre	21A/183B	867Ca/12
F9/1	Foam (SP)	9 litre	27A/233B	867Ca/13
P1/1	ABC Powder (SP)	1 kg	8A/55B	867Ca/04
P2/1	ABC Powder (SP)	2 kg	13A/89B	867Ca/01
P4/1	ABC Powder (SP)	4 kg	27A/233B	867Ca/07
P6/1	ABC Powder (SP)	6 kg	43A/233B	867Ca/02
P9/1	ABC Powder (SP)	9 kg	55A/233B	867Ca/08
W6/1	Water (SP)	6 litre	13A	867Ca/17
W9/1	Water (SP)	9 litre	21A	867Ca/09
WC6/1	Wet Chemical (SP)	6 litre	21A/ 113B/ 75F	867Ca/16
WA6/2	Water Additive (SP)	6 litre	21A	867Ca/19
F6/2	Foam (SP)	6 litre	34A / 183B	867Ca/20

PORTABLE FIRE EXTINGUISHERS

F2/1

Foam (SP)

2 litre

8A / 55B

867Ca/21

Fullblaze Middle East

Zarqa Free Zone, New Expansionist Area, P.O.Box 922054, Amman, 11192, Jordan

Tel: +962 6 489 3373

E-mail: info@fullblaze-me.com • Website: www.fullblaze-me.com

Certificate No: 1092Ea to EN 3 parts 7, 8 & 9

Fullblaze Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
FBCD2	CO ₂	2 kg	34B	1092Ea/31
FBCD5	CO ₂	5 kg	70B	1092Ea/33
FBFM6S	Foam (SP)	6 litre	21A/144B	1092Ea/17
FBFM9S	Foam (SP)	9 litre	27A/233B	1092Ea/19
FBPD1E	ABC Powder (SP)	1 kg	8A/34B	1092Ea/01
FBPD2S	ABC Powder (SP)	2 kg	13A/89B	1092Ea/05
FBPD6S	ABC Powder (SP)	6 kg	43A/233B	1092Ea/09
FBPD9S	ABC Powder (SP)	9 kg	55A/233B	1092Ea/11
FBPD12	ABC Powder (SP)	12 kg	55A/233B	1092Ea/12

Jactone Products Limited

Springvale Business Park, Springvale Avenue, Bilston, West Midlands, WV14 0QL, United Kingdom

Tel: +44 (0)1902 357777

E-mail: sales@jactone.com • Website: www.jactone.com

Certificate No: 783a to EN 3 Parts 7 & 8

Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
EWCS3	F Class (SP)	3 litre	8A/25F	783a/01
EWCS6	F Class (SP)	6 litre	13A/75F	783a/02

Certificate No: 783b to EN 3-7:2004 + A1:2007

Portable Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
EFS6 PLUS	Foam (SP)	6 litre	34A/183B	783b/01
EC2	CO ₂	2 kg	34B	783b/02
EC2F	CO ₂	2 kg	55B	783b/03
EC5	CO ₂	5 kg	70B	783b/04

Jewel Fire Group Limited

Units A1-A3 Aldwarke Wharf Business Park, Waddington Way, Aldwarke, Rotherham, S65 3SH, United Kingdom

Tel: +44 (0)1709 703223

E-mail: sales@jewelfiregroup.com • Website: www.jewelfiregroup.com

Certificate No: 1094a to EN 3-7:2004+A1:2007

'JEWEL FIRE GROUP' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
3WMX	Water Mist (SP)	3 litre	8A/25F	1094a/01
6WMX	Water Mist (SP)	6 litre	13A/75F	1094a/02

Certificate No: 1094b to a Technical Approval based upon EN 3-7:2004+A1:2007 with the exception of Clause 6.1 – Nominal Charges

JEWEL FIRE GROUP' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
1WMX	Water Mist (SP)	1 litre	5F	1094b/01

PORTABLE FIRE EXTINGUISHERS

1.4WMX

Water Mist (SP)

1.4 litre

5A / 5F

1094b/02

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building, 738471, Singapore

Tel: +65 6759 4163

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501a to EN 3 Parts 7,8 and 9

Portable fire extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
C-1ASE (1)	ABC Powder (SP)	1kg	5A/55B	501a/01
C-2ASE (1)	ABC Powder (SP)	2kg	13A/55B	501a/02
C-3ASE (1)	ABC Powder (SP)	3kg	13A/55B	501a/03
C-4ASE (1)	ABC Powder (SP)	4kg	21A/144B	501a/04
C-6ASE (1)	ABC Powder (SP)	6kg	34A/233B	501a/05
C-9ASE (1)	ABC Powder (SP)	9kg	43A/233B	501a/06
C-6FSE (1)	Foam (SP)	6 litre	8A/113B	501a/07
C-9FSE (1)	Foam (SP)	9 litre	34A/233B	501a/08
C-6WSE (1)	Water (SP)	6 litre	8A	501a/09
C-9WSE (1)	Water (SP)	9 litre	13A	501a/10
Q-1SP (2)	ABC Powder (SP)	1 kg	5A/55B	501a/01
Q-2SP (2)	ABC Powder (SP)	2 kg	13A/55B	501a/02
Q-3SP (2)	ABC Powder (SP)	3 kg	13A/55B	501a/03
Q-4SP (2)	ABC Powder (SP)	4 kg	21A/144B	501a/04
Q-6SP (2)	ABC Powder (SP)	6 kg	34A/233B	501a/05
Q-9SP (2)	ABC Powder (SP)	9 kg	43A/233B	501a/06
Q-6SF (2)	Foam (SP)	6 litre	8A/113B	501a/07
Q-9SF (2)	Foam (SP)	9 litre	34A/233B	501a/08
Q-6SW (2)	Water (SP)	6 litre	8A	501a/09
Q-9SWE (2)	Water (SP)	9 litre	13A	501a/10
C-9FCE (1)	Foam (GC)	9 litre	34A/233B	501a/11
C-9WSEA (1)	Water additive (SP)	9 litre	21A	501a/12
C-9WCEA (1)	Water additive (GC)	9 litre	21A	501a/13
C-2CSEC (1)	Carbon dioxide	2 kg	34B	501a/14
C-5CSEC (1)	Carbon dioxide	5 kg	55B	501a/15
Q-9CF (2)	Foam (GC)	9 litre	34A/233B	501a/11
Q-9WSEA (2)	Water additive (SP)	9 litre	21A	501a/12
Q-9WCEA (2)	Water additive (GC)	9 litre	21A	501a/13
Q-2CSEC (2)	Carbon dioxide	2 kg	34B	501a/14
Q-5CSEC (2)	Carbon dioxide	5 kg	55B	501a/15
C-6ACE (1)	ABC Powder (GC)	6 kg	27A/233B	501a/16
C-9ACE (1)	ABC Powder (GC)	9 kg	43A/233B	501a/17
C-12ACE (1)	ABC Powder (GC)	12 kg	55A/233B	501a/18
Q-6CP (2)	ABC Powder (GC)	6 kg	27A/233B	501a/16
Q-9CP (2)	ABC Powder (GC)	9 kg	43A/233B	501a/17
Q-12CP (2)	ABC Powder (GC)	12 kg	55A/233B	501a/18
C-9MSE(1)	BC Powder (SP)	9 kg	233B	501a/19
C-9PKSE(1)	BC Powder (SP)	9 kg	233B	501a/20
C-12PKCE(1)	BC Powder (GC)	12 kg	233B	501a/21
Q-9MSE(2)	BC Powder (SP)	9 kg	233B	501a/19
Q-9PKSE(2)	BC Powder (SP)	9 kg	233B	501a/20
Q-12PKCE(2)	BC Powder (GC)	12 kg	233B	501a/21

Certificate No: 501h to A Technical Approval based on BS EN 3 Part 7.

Portable Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
C-11MCE	BC Powder (GC)	11 kg	233B	501h/01
Q-11MCE	BC Powder (GC)	11 kg	233B	501h/02

PORTABLE FIRE EXTINGUISHERS

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463a to EN 3: Parts 7, 8 & 9

Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
NC2	CO ₂	2 kg	34B	463a/01
NCS2	CO ₂	2 kg	34B	463a/06
NCZ2	CO ₂	2 kg	55B	463a/07
NC5	CO ₂	5 kg	55B	463a/02
NF6	Foam (SP)	6 litre	21A/144B	463a/08
NF9	Foam (SP)	9 litre	21A/183B	463a/09
NP1	ABC Powder (SP)	1 kg	8A/34B	463a/05
NP2	ABC Powder (SP)	2 kg	13A/70B	463a/37
NP4	ABC Powder (SP)	4 kg	21A/113B	463a/10
NP6	ABC Powder (SP)	6 kg	34A/183B	463a/38
NP9	ABC Powder (SP)	9 kg	43A/233B	463a/03
NP12	ABC Powder (SP)	12 kg	55A/233B	463a/04
NW6	Water (SP)	6 litre	13A	463a/11
NW9	Water (SP)	9 litre	21A	463a/12
NWN6	Water (SP)	6 litre	13A	463a/13
NWN9	Water (SP)	9 litre	13A	463a/14
NC5X	CO ₂	5 kg	70B	463a/15
NCA5X	CO ₂	5 kg	70B	463a/16
NF3	Foam (SP)	3 litre	8A/70B	463a/17
NF3X	Foam (SP)	3 litre	8A/70B	463a/18
NF6X	Foam (SP)	6 litre	27A/144B	463a/19
NF9X	Foam (SP)	9 litre	27A/233B	463a/20
NFA9	Foam (SP)	9 litre	21A/183B	463a/21
NW6X	Water (SP)	6 litre	13A	463a/22
NW9X	Water (SP)	9 litre	21A	463a/23
NWA9	Water (SP)	9 litre	21A	463a/24
NHFC4	Clean Agent (SP)	4 kg	34B	463a/33
NHFC6	Clean Agent (SP)	6 kg	5A/55B	463a/34
NHFC9	Clean Agent (SP)	9 kg	8A/70B	463a/35
NHFC12	Clean Agent (SP)	12 kg	13A/70B	463a/36
NFC6X	Foam (GC)	6 litre	27A/144B	463a/26
NFC9X	Foam (GC)	9 litre	34A/233B	463a/27
NP3	ABC Powder (SP)	3 kg	21A/89B	463a/28
NWC6X	Water (SP)	6 litre	13A	463a/29
NWC9X	Water (SP)	9 litre	21A	463a/30
NKE2	Wet Chemical	2 litre	5F	463a/31
NKE3X	Wet Chemical	3 litre	8A/25F	463a/32
NKE6	Wet Chemical	6 litre	13A/75F	463a/25
NF 2EB	Eco Barid Foam (SP)	2 litre	8A/89B/5F	463a/39
NF 3EB	Eco Barid Foam (SP)	3 litre	8A/113B/25F	463a/40
NF 6EB	Eco Barid Foam (SP)	6 litre	21A/183B/40F	463a/41
NF 9EB	Eco Barid Foam (SP)	9 litre	27A/183B/40F	463a/42

Nasr Awwadeh Factory for Fire Fighting & Safety Equipment

Building No. 7, Mohammed Al Khodary Street, P.O. Box 330339, Marka 11134, Amman, Jordan

Tel: +962 6 488 1999

E-mail: info@naffire.com • Website: www.naffire.com

Certificate No: 1092la to EN 3 Parts 7, 8 & 9

'NAF' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
NCD5	CO ₂	5 kg	70B	1092la/33
NPD6S	ABC Powder (SP)	6 kg	43A/233B	1092la/09
NFM6	Foam (SP)	6 litre	21A/144B	1092la/17
NFM9	Foam (SP)	9 litre	27A/233B	1092la/19
NPD9	ABC Powder (SP)	9 kg	55A/233B	1092la/11
NPD12	ABC Powder (SP)	12 kg	55A/233B	1092la/12

PORTABLE FIRE EXTINGUISHERS

Qatar Factory For Fire Fighting Equipment & Safety Systems - NAFFCO

Building No195, Zone 81, Street 23 K, Doha, Qatar

Tel: +974 4402 5888

E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 463Aa to EN 3 - Parts 7 and,8

Portable fire extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
NQHFC4	Clean agent (SP)	4 kg	34B	463Aa/33
NQHFC6	Clean agent (SP)	6 kg	5A/55B	463Aa/34
NQHFC9	Clean agent (SP)	9 kg	8A/70B	463Aa/35
NQHFC12	Clean agent (SP)	12 kg	13A/70B	463Aa/36

SensorTech Firefighting and Safety Equipment Trading

P.O.Box 231728, Office No. 506, Al Saud Building, Al Qusais – 4, Dubai, United Arab Emirates

Tel: +971 422 323 31

E-mail: info@sensortechuae.com • Website: www.sensortechuae.com

Certificate No: 1092La to EN 3 Parts 7, 8 & 9

'WETPLUG' Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
WPC2A	CO ₂	2 kg	34B	1092La/30
WPC2	CO ₂	2 kg	34B	1092La/31
WPC5A	CO ₂	5 kg	70B	1092La/32
WPC5	CO ₂	5 kg	70B	1092La/33
WPF2	Foam (SP)	2 litre	8A/55B	1092La/14
WPF3	Foam (SP)	3 litre	13A/89B	1092La/16
WPF6	Foam (SP)	6 litre	21A/144B	1092La/17
WPF6RS	Foam (SP)	6 litre	27A/183B	1092La/18
WPF9	Foam (SP)	9 litre	27A/233B	1092La/19
WPP1	ABC Powder (SP)	1 kg	8A/55B	1092La/04
WPP2	ABC Powder (SP)	2 kg	13A/89B	1092La/05
WPP3	ABC Powder (SP)	3 kg	21A/113B	1092La/07
WPP4	ABC Powder (SP)	4 kg	27A/144B	1092La/08
WPP6	ABC Powder (SP)	6 kg	43A/233B	1092La/09
WPP6RS	ABC Powder (SP)	6 kg	55A/233B	1092La/10
WPP9	ABC Powder (SP)	9 kg	55A/233B	1092La/11
WPP12	ABC Powder (SP)	12 kg	55A/233B	1092La/12
WPW6	Water (SP)	6 litre	13A	1092La/24
WPW9	Water (SP)	9 litre	21A	1092La/25
WPWA3	Water Additive (SP)	3 litre	13A	1092La/28
WPWA6	Water Additive (SP)	6 litre	27A	1092La/29
WPWC2	Wet Chemical (SP)	2 litre	8A/34B/25F	1092La/21
WPWC3	Wet Chemical (SP)	3 litre	13A/70B/40F	1092La/22
WPWC6	Wet Chemical (SP)	6 litre	21A/113B/75F	1092La/23

Sentura Group Ltd. (including Fire Depot and Firechief Global)

Sentura House, 3 Lands End Way, Oakham, Rutland, LE15 6RB, United Kingdom

Tel: +44 (0)330 999 22 33

E-mail: sales@firedepot.co.uk • Website: www.firedepot.co.uk

Certificate No: 1093a to EN 3 Parts 7, 8 & 9

FIRECHIEF FM, XTR, POWERPLUS & ECOSPRAY Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
FXF2	Foam (SP)	2 litre	8A/55B	1093a/15
FXF6	Foam (SP)	6 litre	21A/144B	1093a/17
FXF9	Foam (SP)	9 litre	27A/233B	1093a/19

PORTABLE FIRE EXTINGUISHERS

FMP1	ABC Powder (SP)	1 kg	8A/34B	1093a/01
PPP1	ABC Powder (SP)	1 kg	8A/55B	1093a/04
FXP2	ABC Powder (SP)	2 kg	13A/89B	1093a/06
FXP4	ABC Powder (SP)	4 kg	27A/144B	1093a/08
FXP6	ABC Powder (SP)	6 kg	43A/233B	1093a/09
FXP9	ABC Powder (SP)	9 kg	55A/233B	1093a/11
FXP12	ABC Powder (SP)	12 kg	55A/233B	1093a/12
FXW6	Water (SP)	6 litre	13A	1093a/24
FXW9	Water (SP)	9 litre	21A	1093a/25
ESW3	Water Additive (SP)	3 litre	13A	1093a/28
ESW6	Water Additive (SP)	6 litre	27A	1093a/29
FXWC6	Wet Chemical (SP)	6 litre	21A/113B/75F	1093a/23
FXF3	Foam (SP)	3 litre	13A/89B	1093a/16
FXP3	ABC Powder (SP)	3 kg	21A/113B	1093a/07
FXWC2	Wet Chemical (SP)	2 litre	8A/34B/25F	1093a/21
FXCD2S	CO ₂	2 kg	34B	1093a/31
FXCD5S	CO ₂	5 kg	70B	1093a/33
FXWC3	Wet Chemical (SP)	3 litre	13A/70B/40F	1093a/22

Certificate No: 1093b to EN 3-7:2004+A1:2007

FIRECHIEF FM Portable Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
FMP600	ABC Powder (SP)	0.6 kg	5A/21B	1093b/01
FMP800	ABC Powder (SP)	0.8 kg	5A/34B	1093b/03

Yuyao Tianbo Fire Fighting Equipment Co., Ltd.

Baishuicong Industrial Park, Lianglong Town, Yuyao City, Zhejiang, China

Tel: +86-21-61602389

E-mail: export@yytianbo.cn • Website: www.yytianbo.cn

Certificate No: 1092a to EN 3 Parts 7,8 & 9

Portable Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
TMFM2S	Foam (SP)	2 litre	8A/55B	1092a/14
TMFM6S	Foam (SP)	6 litre	21A/144B	1092a/17
TMPD1	ABC Powder (SP)	1 kg	8A/34B	1092a/03
TMPD1E	ABC Powder (SP)	1 kg	8A/34B	1092a/01
TMPD1S	ABC Powder (SP)	1 kg	8A/55B	1092a/04
TMPD2S	ABC Powder (SP)	2 kg	13A/89B	1092a/05
TMPD4S	ABC Powder (SP)	4 kg	27A/144B	1092a/08
TMPD6S	ABC Powder (SP)	6 kg	43A/233B	1092a/09
TMPD6RS	ABC Powder (SP)	6 kg	55A/233B	1092a/10
TMPD9S	ABC Powder (SP)	9 kg	55A/233B	1092a/11
TMPD12	ABC Powder (SP)	12 kg	55A/233B	1092a/12
TMWT6	Water (SP)	6 litre	13A	1092a/24
TMWT9	Water (SP)	9 litre	21A	1092a/25
TMWT3A	Water Additive (SP)	3 litre	13A	1092a/28
TMWT6A	Water Additive (SP)	6 litre	27A	1092a/29
TMWC6	Wet Chemical (SP)	6 litre	21A/113B/75F	1092a/23
TMFM9S	Foam (SP)	9 litre	27A/233B	1092a/19
TMFM3S	Foam (SP)	3 litre	13A/89B	1092a/16
TMPD3S	ABC Powder (SP)	3 kg	21A/113B	1092a/07
TMWC2	Wet Chemical (SP)	2 litre	8A/34B/25F	1092a/21
TMPD1A	ABC Powder (SP)	1 kg	8A/34B	1092a/02
TMCD2	CO ₂	2 kg	34B	1092a/31
TMCD5	CO ₂	5 kg	70B	1092a/33
TMCD2A	CO ₂	2 kg	34B	1092a/30
TMCD5A	CO ₂	5 kg	70B	1092a/32
TMFM6RS	Foam (SP)	6 litre	27A/183B	1092a/18
TMWC3	Wet Chemical (SP)	3 litre	13A/70B/40F	1092a/22

Certificate No: 1092b to Technical Approval based upon EN 3-7:2004+A1:2007

'TIANBO' Portable Fire Extinguishers

30 Apr 2025

Page 65 of 76

PORTABLE FIRE EXTINGUISHERS

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
PD600	ABC Powder (SP)	0.6 kg	5A/21B	1092b/01
PD800	ABC Powder (SP)	0.8 kg	5A/34B	1092b/03

Zhejiang Orientx Fire Safety Equipment Co., Ltd.

Wucheyan, Huangjiabu Town, Yuyao City, Zhejiang, 315466, China

Tel: 0086-574-62003908

E-mail: chendian@orientxfire.com • Website: <http://www.orientxfire.com>

Certificate No: 1327a to EN 3-7:2004+A1:2007 & EN 3-9:2006

Portable Fire Extinguishers

Product Name	Type	Capacity	Fire Rating	LPCB Ref. No.
OCE2-LWB117	CO ₂	2 kg	34B	1327a/01
OCE5-LWB152	CO ₂	5 kg	70B	1327a/02

Zhejiang Ruihua Machinery Co. Ltd

No. 1 Fengqixi Road, Western Industrial Zone, Linshan Town, Yuyao, Zhejiang, 315460, China

Tel: 0086 1350 578 4280

E-mail: jingxingli@ruihuafire.com

Certificate No: 867a to EN 3-7:2004+A1:2007, EN 3-8:2006 & EN 3-9:2006

RUIHUA Portable Fire Extinguishers

Product Name	Type	Capacity	Fire rating	LPCB Ref. No.
K2S (1)	CO ₂	2 kg	34B	867a/10
P1GS (1,2)	ABC Powder (SP)	1 kg	8A/55B	867a/04
PG2/P2GS (1,2)	ABC Powder (SP)	2 kg	13A/89B	867a/01
PG3/P3GS	ABC Powder (SP)	3 kg	21A/144B	867a/05
PG4/P4GS (1)	ABC Powder (SP)	4 kg	27A/233B	867a/07
P6GS (1,2)	ABC Powder (SP)	6 kg	43A/233B	867a/02
PG9/P9GS (1,2)	ABC Powder (SP)	9 kg	55A/233B	867a/08
PG12/P12GS	ABC Powder (SP)	12 kg	55A/233B	867a/03
W9 (1)	Water (SP)	9 litre	21A	867a/09
K5S (1)	CO ₂	5 kg	89B	867a/11
P2P	ABC Powder (SP)	2 kg	13A/89B	867a/15
S6 Eco Plus	Foam (SP)	6 litre	34A/183B	867a/20
S9 Eco (1,2)	Foam (SP)	9 litre	27A/233B	867a/13
W6 (1)	Water (SP)	6 litre	13A	867a/17
F6 (1)	Wet Chemical (SP)	6 litre	21A/113B/75F	867a/16
WA6	Water Additive (SP)	6 litre	21A	867a/19
S6 Eco (1,2)	Foam (SP)	6 litre	21A / 183B	867a/12
S2 Eco (1,2)	Foam (SP)	2 litre	8A / 55B	867a/21

SEMI RIGID HOSES

Semi-rigid hose is used as part of a hose reel system typically (but not exclusively) red in colour, round in section and up to 30 metres in length. The purpose of this type of hose is to provide a steady flow of water quickly as a first response in a fire situation without having to set up lengths of hose from another source. The semi-rigid construction helps to prevent kinks which would restrict supply, is durable and operates in a fairly wide temperature range.

This section lists products approved in accordance with:

EN 694 - *Requirements for Fire-fighting hoses - semi-rigid hoses for fixed systems.*

Al Ayed Hoses Factory

Al Manakh Industrial Area, P.O.Box 26381, Riyadh, 11486, Kingdom of Saudi Arabia

Tel: +966112600555

E-mail: info@ayed-sa.com • Website: www.ayed-sa.com

Certificate No: 1585a to EN 694:2014

Semi-Rigid Hose

Product Name	Description	LPCB Ref. No.
Al Ayed Semi-Rigid Fire Hose	Semi rigid hose, 25mm, colour red	1585a/01

Alfurat for Modern Systems

2 Metwaly Alshaarawy St, Al Hay Al Asher, Nasr City, Cairo, Egypt

Tel: +202 23822943

E-mail: sales@alfurat-eg.com • Website: www.alfurat-eg.com

Certificate No: 1288Aa to EN 694:2014

'ALFURAT-RH' Semi-rigid Hose

Product Name	Description	LPCB Ref. No.
ALFURAT-RH	25mm inside diameter, type A, class 2, red PVC semi-rigid fire hose	1288Aa/02

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463h to EN 694

Semi rigid hoses

Product Name	Model	LPCB Ref. No.
Semi rigid hose, 19 mm, colour red	NF-RH-19R	463h/01
Semi rigid hose, 25mm, colour red	NF-RH-25R	463h/02

Shaoxing Hongrun Fire Control Equipment Co., Ltd.

No. 16 Zijin Road, Xiaoyue Industrial Zone, Shangyu District, Shaoxing City, Zhejiang Province, China

Tel: +86-575-82716911

E-mail: mkt-hongrun@hr-fire.com • Website: www.hr-fire.com

Certificate No: 1288a to EN 694:2014

HR Semi-rigid Hose

Product Name	Description	LPCB Ref. No.
HR01-01-01	19mm inside diameter, type A, class 2, red PVC semi-rigid fire hose	1288a/01
HR01-02-01	25mm inside diameter, type A, class 2, red PVC semi-rigid fire hose	1288a/02
HR01-03-01	33mm inside diameter, type A, class 2, red PVC semi-rigid fire hose	1288a/03

SEMI RIGID HOSES

Suzhou HLC Plastics Industry Co. Ltd

No. 103 Fengbeidang Road, Beiqiao Block, Xiangcheng District, Suzhou, China

Tel: +86 512 65366918

E-mail: info@suzhou-csj.com • Website: www.suzhou-csj.com

Certificate No: 1038b to EN 694:2014

CSJ Semi-Rigid Hose

Product Name	Description	LPCB Ref. No.
19mm Fire Hose (1)	Semi rigid hose, 19mm, colour red/black	1038b/01
25mm Fire Hose (1)	Semi rigid hose, 25 mm, colour red/black	1038b/02
33mm Fire Hose (2)	Semi rigid hose, 33 mm, colour red/black	1038b/03

Yuyao Tianning Fire Control Equipment Co., Ltd.

Ganxuan Village, Liangnong Town, Yuyao City, Ningbo, Zhejiang Province, China

Tel: 0086 15618883100

E-mail: Nicole.mengxiao Zhang@hotmail.com • Website: www.tianningfire.com

Certificate No: 1364a to EN 694:2014

'TN' Semi-Rigid Hose

Product Name	Description	LPCB Ref. No.
TN04-D-08B-08	Semi rigid hose, 19mm, colour red	1364a/01
TN04-D-08A-08	Semi rigid hose, 25mm, colour red	1364a/02

WET LANDING VALVES

A Wet Riser is a system of pipe-work and valves which is kept permanently charged by a dedicated pump supplying clean water on demand on each floor of a building and is typically used on larger, high rise buildings.

Wet landing valves are located at discharge points, typically on the upper floors of a taller building. Layflat hoses are coupled into the valve to supply water to the location of the fire. The valve is normally located within an easily accessible, protective and approved box or cabinet to prevent damage, dust and rubbish collection.

The system components must be regularly maintained to prevent leaks, corrosion, and loss of adequate pressure. Landing valves that are used as part of a wet riser system are tested to BS 5041-1.

This section lists products approved in accordance with:

BS 5041-1 - *Fire hydrant systems equipment. Specification for landing valves for wet risers*

Brake Fire Safety and Security

Building 8, Industrial Area / 1 Amman Street, Ajman, United Arab Emirates

Tel: +971 551 668 286

E-mail: info@brakefiregcc.com • Website: www.brakefiregcc.com

Certificate No: 1153Re to BS 5041-1:1987

'BRAKE FIRE' Landing Valves for Wet Risers

Product Name	Description	LPCB Ref. No.
BFLV-2.5-T	2 ½", oblique type, low pressure, BSPT male threaded inlet, globe valve	1153Re/17
BFLV-2.5-F	DN65, oblique type, low pressure, flanged inlet, globe valve	1153Re/20
BFLV-2.5-FPRV	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153Re/31

EMACO GLOBAL LLC

3118 Beckett Way, Lakeland, FL 33810, USA

Tel: +1 (516) 288-8935

E-mail: info@emacoglobal.com • Website: www.emacoglobal.com

Certificate No: 1153Je to BS 5041-1:1987

'EMACO' Wet Landing Valves

Product Name	Description	LPCB Ref. No.
E0190-198A1-00	DN65 flanged inlet, oblique type, low pressure	1153Je/02
E0190-198B1-00	2 ½" BSPT male threaded inlet, oblique type, low pressure	1153Je/04

Emerson Automation Solutions Final Control UK Ltd

Sharp Street, Worsley, Manchester, M28 3NA, United Kingdom

Tel: 0161 703 1971

E-mail: David.Kerr@Emerson.com • Website: Emerson.com/en-gb

Certificate No: 1767a to BS 5041-1

Bailey Class F, DN 40 flanged inlet, bib nosed type high pressure regulating landing valve.

Product Name	Description	LPCB Ref. No.
Bailey Class F	DN40, bib nosed type, high pressure, flanged inlet, landing valve	1767a/01

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 863g to BS 5041-1:1987

WET LANDING VALVES

'FIREX' Landing Valves for Wet Risers

Product Name	Description	LPCB Ref. No.
APDR-65-ST	2 ½", oblique type, low pressure, BSPT male threaded inlet, globe valve	863g/01
APDR-65-FT	DN65, oblique type, low pressure, flanged inlet, globe valve	863g/02

Fire King Security and Safety Equipment

Al Juwais Main Road, Ras Al Khaimah, United Arab Emirates

Tel: +971 7 2437050

E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1153Xe to BS 5041-1:1987

Wet Landing Valves

Product Name	Description	LPCB Ref. No.
FK06-198E-00	2 ½", oblique type, low pressure, BSPT male threaded inlet, globe valve	1153Xe/17
FK06-198E1-00	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1153Xe/18
FK06-198F1-00	DN65, oblique type, low pressure, flanged inlet, globe valve	1153Xe/20
FK06-198G-00	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	1153Xe/21
FK06-198G1-00	2 ½", right angle type, low pressure, BSP female threaded inlet, globe valve	1153Xe/22
FK06-198H1-00	DN65, right angle type, low pressure, flanged inlet, globe valve	1153Xe/24
FK06-200E-00	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	1153Xe/25
FK06-200E1-00	2 ½", horizontal type, low pressure, BSP female threaded inlet, globe valve	1153Xe/26
FK06-200F1-00	DN65, horizontal type, low pressure, flanged inlet, globe valve	1153Xe/28
FK06-199C-00	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1153Xe/29
FK06-199D1-00	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153Xe/31

Knowsley SK Limited

Centrepont, Marshall Stevens Way, Trafford Park, Manchester, M17 1AE, United Kingdom

Tel: +44 (0) 161 872 7511

E-mail: sales@knowsleysk.co.uk • Website: www.knowsleysk.co.uk

Certificate No: 1480a to BS 5041-1:1987

Knowsley SK Wet Landing Valves

Product Name	Description	LPCB Ref. No.
4220	DN65, bib-nosed type, low pressure, flanged inlet, diaphragm valve	1480a/01
4240	DN65, horizontal type, low pressure, flanged inlet, diaphragm valve	1480a/02

Certificate No: 1480b to a Technical Approval based upon BS 5041-1:1987

Knowsley SK Wet Landing Valves

Product Name	Description	LPCB Ref. No.
3120	DN65, bib-nosed type, high pressure, flanged inlet (alternative flange drilling combinations 3" and 4", 150lb and 300lb), integral BS 336 outlet, globe valve	1480b/01
3121	2 ½", bib-nosed type, high pressure, male threaded inlet (BSP parallel, NPT and NST), integral BS 336 outlet, globe valve	1480b/02
3123	DN65, bib-nosed type, high pressure, flanged inlet alternative flange drilling combinations 3" and 4", 150lb and 300lb), screwed BS 336 outlet (2 ½" BSP, NPT, NST thread types), globe valve	1480b/03
3124	2 ½", bib-nosed type, high pressure, male threaded inlet (BSP parallel, NPT and NST), screwed BS 336 outlet (2 ½" BSP, NPT, NST thread types), globe valve	1480b/04
3130	DN65, oblique type, high pressure, flanged inlet (alternative flange drilling combinations 3" and 4", 150lb and 300lb), integral BS 336 outlet, globe valve	1480b/05
3131	2 ½", oblique type, high pressure, male threaded inlet (BSP parallel, NPT and NST), integral BS 336, outlet globe valve	1480b/06
3133	DN65, oblique type, high pressure, flanged inlet (alternative flange drilling combinations 3" and 4", 150lb and 300lb), screwed BS 336 outlet (2 ½" BSP, NPT, NST thread types), globe valve	1480b/07
3134	2 ½", oblique type, high pressure, male threaded inlet (BSP parallel, NPT and NST), screwed BS 336 outlet (2 ½" BSP, NPT, NST thread types), globe valve	1480b/08

WET LANDING VALVES

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building, 738471, Singapore

Tel: +65 6759 4163

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501c to BS 5041-1:1987

'Lingjack' Wet Landing Valves

Product Name	Description	LPCB Ref. No.
LV-DR25	2½" PN16, oblique, screwed inlet, low pressure	501c/01
LV-OF25	2½" PN16, oblique, flanged inlet, low pressure	501c/02
LV-RA25	2½" PN16, right angle, screwed inlet, low pressure	501c/03
LV-RAF25	2½" PN16, right angle, flanged inlet, low pressure	501c/04
LV-HS25	2½" PN16, horizontal, screwed inlet, low pressure	501c/05
LV-HF25	2½" PN16, horizontal, flanged inlet, low pressure	501c/06
LV-BNS25	2½" PN16, bib nosed, screwed inlet, low pressure	501c/07
LV-BNF25	2½" PN16, bib nosed, flanged inlet, low pressure	501c/08
DH6I screw	2½" , bib nosed, screwed inlet, high pressure	501c/09
DH6I flange	2½" , bib nosed, flanged inlet, high pressure	501c/10
DV-RAF25	2½" PN16, diaphragm valve, right angle, flanged inlet, low pressure	501c/11
DV-HF25	2½" PN16, diaphragm valve, horizontal, flanged inlet, low pressure	501c/12
LV-BNF25	2½" PN16, diaphragm valve, bib nosed, flanged inlet, low pressure (3)	501c/13

MOBIAS S.A.

96-98 M. Mpotsari St, Chania, Crete, 73136, Greece

Tel: +30 28210 63222

E-mail: sales@mobiak.gr • Website: http://www.mobiak.gr

Certificate No: 1153Ae to BS 5041-1:1987

'MOBIAS' Wet Landing Valves

Product Name	Description	LPCB Ref. No.
MBK06-198A-00	DN50 flanged inlet, oblique type, low pressure	1153Ae/01
MBK06-198A1-00	DN65 flanged inlet, oblique type, low pressure	1153Ae/02
MBK06-198B-00	2 ½" BSP female threaded inlet, oblique type, low pressure	1153Ae/03
MBK06-198B1-00	2 ½" BSPT male threaded inlet, oblique type, low pressure	1153Ae/04
MBK06-198C-00	DN50 flanged inlet, right angle type, low pressure	1153Ae/05
MBK06-198C1-00	DN65 flanged inlet, right angle type, low pressure	1153Ae/06
MBK06-198D1-00	2 ½" BSPT male threaded inlet, right angle type, low pressure	1153Ae/07
MBK06-200A1-00	2 ½" BSPT male threaded inlet, horizontal type, low pressure	1153Ae/08
MBK06-200B-00	DN50 flanged inlet, horizontal type, low pressure	1153Ae/09
MBK06-200B1-00	DN65 flanged inlet, horizontal type, low pressure	1153Ae/10
MBK06-200C1-00	2 ½" BSPT male threaded inlet, bib nosed type, low pressure	1153Ae/11
MBK06-200D-00	DN50 flanged inlet, bib nosed type, low pressure	1153Ae/12
MBK06-200D1-00	DN65 flanged inlet, bib nosed type, low pressure	1153Ae/13
MBK06-199A-00	DN50 flanged inlet, bib nosed type, high pressure	1153Ae/14
MBK06-199A1-00	DN65 flanged inlet, bib nosed type, high pressure	1153Ae/15
MBK06-199B-00	2 ½" BSPT male threaded inlet, bib nosed type, high pressure	1153Ae/16

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463e to BS 5041-1

NDR 098 Wet Landing Valves

Product Name	Description	LPCB Ref. No.
NDR 098	2.5 inch wet landing valve, low pressure (1), oblique type with flanged inlet	463e/01

WET LANDING VALVES

Ningbo Kaixuan Fire Control Equipment Co., Ltd.

No. 999 Zhonghe Road, Huangjiabu Town, Yuyao City, Zhejiang Province, 315466, China

Tel: +86 574 62025710

E-mail: info@kaixuanfire.com • Website: www.kaixuanfire.com

Certificate No: 1153e to BS 5041-1:1987

'JINTIAN FIRE' Wet Landing Valves

Product Name	Description	LPCB Ref. No.
KX06-198A-00	DN50, oblique type, low pressure, flanged inlet, globe valve	1153e/01
KX06-198A1-00	DN65, oblique type, low pressure, flanged inlet, globe valve	1153e/02
KX06-198B-00	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1153e/03
KX06-198B1-00	2 ½", oblique type, low pressure BSPT male threaded inlet, globe valve	1153e/04
KX06-198C-00	DN50, right angle type, low pressure, flanged inlet, globe valve	1153e/05
KX06-198C1-00	DN65, right angle type, low pressure, flanged inlet, globe valve	1153e/06
KX06-198D1-00	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	1153e/07
KX06-200A1-00	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	1153e/08
KX06-200B-00	DN50, horizontal type, low pressure, flanged inlet, globe valve	1153e/09
KX06-200B1-00	DN65, horizontal type, low pressure, flanged inlet, globe valve	1153e/10
KX06-200C1-00	2 ½", bib nosed type, low pressure, BSPT male threaded inlet, globe valve	1153e/11
KX06-200D-00	DN50, bib nosed type, low pressure, flanged inlet, globe valve	1153e/12
KX06-200D1-00	DN65, bib nosed type, low pressure, flanged inlet, globe valve	1153e/13
KX06-199A-00	DN50, bib nosed type, high pressure, flanged inlet, globe valve	1153e/14
KX06-199A1-00	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153e/15
KX06-199B-00	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1153e/16
KX06-198E-00	2 ½", oblique type, low pressure, BSPT male threaded inlet, globe valve	1153e/17
KX06-198E1-00	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1153e/18
KX06-198F-00	DN50, oblique type, low pressure, flanged inlet, globe valve	1153e/19
KX06-198F1-00	DN65, oblique type, low pressure, flanged inlet, globe valve	1153e/20
KX06-198G-00	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	1153e/21
KX06-198G1-00	2 ½", right angle type, low pressure, BSP female threaded inlet, globe valve	1153e/22
KX06-198H-00	DN50, right angle type, low pressure, flanged inlet, globe valve	1153e/23
KX06-198H1-00	DN65, right angle type, low pressure, flanged inlet, globe valve	1153e/24
KX06-200E-00	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	1153e/25
KX06-200E1-00	2 ½", horizontal type, low pressure, BSP female threaded inlet, globe valve	1153e/26
KX06-200F-00	DN50, horizontal type, low pressure, flanged inlet, globe valve	1153e/27
KX06-200F1-00	DN65, horizontal type, low pressure, flanged inlet, globe valve	1153e/28
KX06-199C-00	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1153e/29
KX06-199D-00	DN50, bib nosed type, high pressure, flanged inlet, globe valve	1153e/30
KX06-199D1-00	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153e/31

Rapidrop Global Limited

Rutland Business Park, Newark Road, Peterborough, PE1 5WA, United Kingdom

Tel: +44 1733 847 525 • Alt Tel: +44 7803 024 886

E-mail: rapidrop@rapidrop.com • Website: www.rapidrop.com

Certificate No: 5661 to BS 5041-1:1987

'RAPIDROP' Landing Valves for Wet Risers

Product Name	Description	LPCB Ref. No.
Fig.605M	2 ½", oblique type, low pressure, BSPT male threaded inlet, globe valve	5661/01
Fig.605F	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	5661/02
Fig.605	DN65, oblique type, low pressure, flanged inlet, globe valve	5661/03
Fig.606M	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	5661/04
Fig.606F	2 ½", right angle type, low pressure, BSP female threaded inlet, globe valve	5661/05
Fig.606	DN65, right angle type, low pressure, flanged inlet, globe valve	5661/06
Fig.607M	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	5661/07
Fig.607F	2 ½", horizontal type, low pressure, BSP female threaded inlet, globe valve	5661/08
Fig.607	DN65, horizontal type, low pressure, flanged inlet, globe valve	5661/09
Fig.608M	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	5661/10
Fig.608	DN65, bib nosed type, high pressure, flanged inlet, globe valve	5661/11

WET LANDING VALVES

Shah Bhogilal Jethalal & Brothers

72, Siddhi Vinayak Estate, Opp. Ramdev Kitchen Express, Santej-Vadsar Road, Village : Santej, Taluka : Kalol, District : Gandhinagar, Gujarat, 382721, India

Tel: +91 2764 268612 to 15

E-mail: info@aaagindia.in • Website: www.aaagindia.in

Certificate No: 1584a to BS 5041-1:1987

'AAAG' Wet Landing Valves

Product Name	Description	LPCB Ref. No.
G104-BS	DN65, oblique type, low pressure, flanged inlet, globe valve	1584a/01
G1080-BS	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1584a/02
G108-BS	2 ½", oblique type, low pressure BSPT male threaded inlet, globe valve	1584a/03
G1041-BS	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1584a/04

Shanghai Firetech Co. Ltd.

21F, Building B, No. 2157 Hunan Road, Pudong District, Shanghai, 201204, China

Tel: +86 13917676168

E-mail: info@firetechsh.com • Website: www.firetechsh.com

Certificate No: 1153le to BS 5041-1:1987

'FIRETECH' Wet Landing Valves

Product Name	Description	LPCB Ref. No.
FT105M	2 ½" BSPT male threaded inlet, bib nosed type, low pressure	1153le/11
FT105S	DN50 flanged inlet, bib nosed type, low pressure	1153le/12
FT105	DN65 flanged inlet, bib nosed type, low pressure	1153le/13
FT102M	2 ½", oblique type, low pressure, BSPT male threaded inlet, globe valve	1153le/17
FT102F	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1153le/18
FT102	DN65, oblique type, low pressure, flanged inlet, globe valve	1153le/20
FT103M	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	1153le/21
FT103F	2 ½", right angle type, low pressure, BSP female threaded inlet, globe valve	1153le/22
FT103	DN65, right angle type, low pressure, flanged inlet, globe valve	1153le/24
FT104M	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	1153le/25
FT104F	2 ½", horizontal type, low pressure, BSP female threaded inlet, globe valve	1153le/26
FT104	DN65, horizontal type, low pressure, flanged inlet, globe valve	1153le/28
FT101M	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1153le/29
FT101	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153le/31
FT102S	DN50, oblique type, low pressure, flanged inlet, globe valve	1153le/19
FT103S	DN50, right angle type, low pressure, flanged inlet, globe valve	1153le/23
FT104S	DN50, horizontal type, low pressure, flanged inlet, globe valve	1153le/27
FT101S	DN50, bib nosed type, high pressure, flanged inlet, globe valve	1153le/30

Shaoxing Jia Sheng Fire Fighting Equipment Co. Limited

No 30, Zijin Road, Tianjia Industrial Zone, Xiaoyue Town, Shangyu District, Shaoxing City, Zhejiang Province, 312367, China

Tel: +86-575-82039618

E-mail: rachel.yan@jsfire.com.cn • Website: www.jsfire.com.cn

Certificate No: 1366a to BS 5041-1:1987

Wet Landing Valves

Product Name	Description	LPCB Ref. No.
JS02.002.13Q	2 ½" BSPT male screwed inlet, oblique type, low pressure	1366a/01
JS02.002.14Q	2 ½" BSPT male screwed inlet, oblique type, low pressure	1366a/02
JS02.002.16Q	DN65 flanged inlet, oblique type, low pressure	1366a/03
JS02.002.18Q	DN65 flanged inlet, right-angle type, low pressure	1366a/04
JS02.002.19Q	DN65 flanged inlet, horizontal type, low pressure	1366a/05
JS02.002.56	2 ½" BSPT female screwed inlet, oblique type, low pressure	1366a/06

WET LANDING VALVES

Shaoxing Shangyu Hongye Fire Protection Equipment Factory

No 56, West of Wucheyan National Road, Wucheyan Village, Huangjiabu Town, Yuyao City, China

Tel: +86 176823456868 • Alt Tel: +86 13858532457

E-mail: info@hongye-fire.com • Website: www.hongye-fire.com

Other

Foundry Address - Wushan Village, Xiaoyue Town, Shangyu District, Zhejiang, 312367, China

Certificate No: 1823b to BS 5041-1:1987

'HY FIRE' Landing Valves for Wet Risers

Product Name	Description	LPCB Ref. No.
HY001-002A1-00-QT-LPCB	DN65, oblique type, low pressure, flanged inlet, globe valve	1823b/01
HY001-006C8-00-QT-LPCB	2 ½", oblique type, low pressure, BSPT male threaded inlet, globe valve	1823b/02
HY001-002G1-00-QT-LPCB	2 ½", bib nosed type, low pressure, BSPT male threaded inlet, globe valve	1823b/04
HY001-001B-00B-QT-LPCB	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1823b/06
HY001-001-00B-QT-LPCB	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1823b/05
HY001-002G-00-QT-LPCB	DN65, bib nosed type, low pressure, flanged inlet, globe valve	1823b/03

The Viking Corporation

210 N Industrial Park, Hastings, Michigan 49058, USA

Tel: +1 269 945 9501

E-mail: techsvcs@vikingcorp.com • Website: www.vikingcorp.com

Certificate No: 1153Ke to BS 5041-1:1987

Viking Corp Fireking Wet Landing Valves

Product Name	Description	LPCB Ref. No.
FK-LV50F-O	DN50, oblique type, low pressure, flanged inlet, globe valve	1153Ke/01
FK-LV65F-O	DN65, oblique type, low pressure, flanged inlet, globe valve	1153Ke/02
FK-LV65TO-F	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1153Ke/03
FK-LV65TO-M	2 ½", oblique type, low pressure BSPT male threaded inlet, globe valve	1153Ke/04
FK-LV50F-R	DN50, right angle type, low pressure, flanged inlet, globe valve	1153Ke/05
FK-LV65F-R	DN65, right angle type, low pressure, flanged inlet, globe valve	1153Ke/06
FK-LV65TR-M	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	1153Ke/07
FK-LV65TS-M	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	1153Ke/08
FK-LV50F-S	DN50, horizontal type, low pressure, flanged inlet, globe valve	1153Ke/09
FK-LV65F-S	DN65, horizontal type, low pressure, flanged inlet, globe valve	1153Ke/10
FK-LV65TB-M	2 ½", bib nosed type, low pressure, BSPT male threaded inlet, globe valve	1153Ke/11
FK-LV50F-B	DN50, bib nosed type, low pressure, flanged inlet, globe valve	1153Ke/12
FK-LV65F-B	DN65, bib nosed type, low pressure, flanged inlet, globe valve	1153Ke/13
FK-PRV-F	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153Ke/15
FK-PRV-T	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1153Ke/16

Tianjin Pro Made Fire Equipment Company Limited

Room 1103, Zhengrong Technology Building 1, Hongqiao, Tianjin, 300131, China

Tel: +86 22 5889 2190

E-mail: info@tpmcsteel.com • Website: www.tpmcsteel.com

Certificate No: 1153Le to BS 5041-1:1987

'TPMC' Wet Landing Valves

Product Name	Description	LPCB Ref. No.
F21-50	DN50, oblique type, low pressure, flanged inlet, globe valve	1153Le/01
F21-65	DN65, oblique type, low pressure, flanged inlet, globe valve	1153Le/02
F22-65P	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1153Le/03
F22-65T	2 ½", oblique type, low pressure BSPT male threaded inlet, globe valve	1153Le/04
F25-50	DN50, right angle type, low pressure, flanged inlet, globe valve	1153Le/05
F25-65	DN65, right angle type, low pressure, flanged inlet, globe valve	1153Le/06
F26-65T	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	1153Le/07
F24-65T	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	1153Le/08
F23-50	DN50, horizontal type, low pressure, flanged inlet, globe valve	1153Le/09

WET LANDING VALVES

F23-65	DN65, horizontal type, low pressure, flanged inlet, globe valve	1153Le/10
F28-65T	2 ½", bib nosed type, low pressure, BSPT male threaded inlet, globe valve	1153Le/11
F27-50	DN50, bib nosed type, low pressure, flanged inlet, globe valve	1153Le/12
F27-65	DN65, bib nosed type, low pressure, flanged inlet, globe valve	1153Le/13
F29-50	DN50, bib nosed type, high pressure, flanged inlet, globe valve	1153Le/14
F29-65	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153Le/15
F30-65T	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1153Le/16

Walter Frank & Sons Ltd.

Saint Peg Lane, Cleckheaton, West Yorkshire, BD19 3SL, United Kingdom

Tel: +44 (0) 1274 873 366

E-mail: andrew.gallear@westleygroup.co.uk • Website: www.westleygroup.co.uk/walter-frank

Certificate No: 1695a to BS 5041-1:1987

Wet landing valves

Product Name	Description	LPCB Ref. No.
FRA5478G	Bib nosed pattern, low pressure, DN65, PN16, BS 4504 flanged inlet, diaphragm valve	1695a/01
FRA5498G	Horizontal pattern, low pressure, DN65, PN16, BS 4504 flanged inlet, diaphragm valve	1695a/02

Certificate No: 1695b to BS 5041-1:1987, with the exception of clause 10.

Wet landing valves

Product Name	Description	LPCB Ref. No.
FRA5477G	Bib nosed pattern, low pressure, DN65, 2.5 inch, ASME.B16.24 flanged inlet, diaphragm valve	1695b/01
FRA5476G	Bib nosed pattern, low pressure, DN65, 3 inch, ASME.B16.24 flanged inlet, diaphragm valve	1695b/02
FRA5497G	Horizontal pattern, low pressure, DN65, PN16, 2.5 inch, ASME.B16.24 flanged inlet, diaphragm valve	1695b/03
FRA5496G	Horizontal pattern, low pressure, DN65, PN16, 3 inch, ASME.B16.24 flanged inlet, diaphragm valve	1695b/04

