

LPCB Red Book



Part: 2

**Fire doors, shutters and installers
of fire and security doors**

bre

Introduction

BRE Global Ltd, based in the UK near London, is an independent third party organisation offering certification of fire, security and sustainability products and services to an international market. LPCB is the certification brand used for fire and security products and services. The LPCB mark is accepted worldwide. We have representative offices in China, India and Dubai. We are owned by the BRE Trust, a not-for-profit organisation.

LPCB listings can be accessed, free of charge, at www.redbooklive.com. BRE Global additionally carries out:

- Fire Investigation
- Fire Risk Assessment
- Fire Safety Engineering
- Research
- Training

LPCB Listings

Listings are given in sections which list related groups of products and services such as suppression, security and so on. Each section also summarises the technical basis for the certification of each product or service. The Red Book listings should always be used in conjunction with rules, regulations and design specifications required by the relevant Authority having jurisdiction.

Listings comprise:

- Fire detection and alarm products, systems, and cables
- Manual fire extinguishing equipment
- Automatic sprinkler, water spray and deluge systems
- Fixed fire fighting products and systems
- Watermist systems
- Related installers
- Passive fire protection products
- Security protection products
- Fire doors and shutters
- Smoke and fire ventilation systems
- SABRE
- Management Systems
- Construction products

Listings are given in the name of the manufacturer or service provider, in alphabetical order. They can be downloaded free of charge from our website at www.redbooklive.com

Updates

Certification of products and services are updated regularly. To ensure that you are using the most up to date information please refer to www.redbooklive.com.

What is Third Party Certification?

A frequent concern of stakeholders is in knowing whether a product will perform in accordance with the stated specifications. These concerns can involve such product attributes as safety, health or environmental impacts, durability, compatibility, suitability for intended purposes or for stated conditions, and other similar considerations. These issues can all be addressed through product certification.

Third party certification is a conformity assessment process, carried out by a body that is independent of both supplier and customer organisations. It provides confirmation that products and services have met and will continue to meet the requirements of specified standards and other normative documents.

FOR SPECIFIERS AND REGULATORS:

LPCB third party product certification schemes are quality assurance schemes and comprise initial type testing and technical evaluation, assessment and surveillance of the manufacturer's quality system and factory production procedures, regular audit testing, labelling and listing.

Similarly, LPCB schemes for suppliers of services (installers) are also quality assurance schemes comprising a technical assessment of an installer's capability, assessment and surveillance of the installer's quality system and production procedures, regular inspection of completed installations and listing.

Benefits of Third Party Certification

For specifiers, regulators, insurers, manufacturers and installers, the benefits of an LPCB approval are:

For specifiers and regulators:

- Risk reduction - specifying LPCB approved products and services demonstrates due-diligence and best endeavour and mitigates against possible accusations of negligence.
- Avoidance of costly mistakes - you can trust LPCB approved products and services to conform each and every time.
- Time - using Red Book Live to search for and assess products and services can save you time.

For manufacturers and installers:

- Increased global sales - LPCB approval is recognised and specified widely throughout the world. In some territories LPCB approval is a mandatory requirement.
- Added value of the product or service - LPCB approved products and services are recognised as providing added value given their ability to conform each and every time.
- Reduced liability - LPCB approved products and services demonstrate due-diligence which can reduce liability for both you and your customers.

What does LPCB Certification offer?

LPCB certification is carried out against Loss Prevention Standards (LPS's). These LPS's include reference to BS, EN or ISO standards as appropriate. LPCB certification are level 5 schemes as detailed in ISO/ IEC 17067 with the added requirement to have a quality system certificated to ISO 9001.

The technical requirements of LPCB schemes are given in the Loss Prevention Standards (LPSs). These documents are drafted by LPCB technical experts in conjunction with appropriate external experts. They are then peer reviewed by representatives from trade bodies, regulators, insurers, specifiers, manufacturers and other suppliers. Finally these documents are approved for use by the BRE Global Governing Body; the Body that oversees all of the certification activities of BRE Global.

Product schemes comprise:

- Initial type testing and evaluation of product.
- Approval and surveillance of the manufacturer's (or supplier's) quality management system to ISO 9001
- Assessment and surveillance of the manufacturer's (or supplier) factory production control system (FPC).
- Periodic audit testing of the product from either the factory or marketplace.
- Labelling or marking as appropriate.
- Listing on Red Book Live

Installer schemes comprise:

- Technical assessment of the installation contractor's capability.
- Approval and surveillance of the contractor's quality management system to ISO 9001 or assessment against the requirements of the relevant Loss Prevention Standard where ISO 9001

FOR SPECIFIERS AND REGULATORS:

- is not appropriate.
- Regular surveillance inspections of on-going installations.
- The issue of Certificates of Conformity by the installer to demonstrate compliance for each installation.
- Listing in the Red Book.

The LPCB Mark - the Mark you can trust

After certification of a product or service the manufacturer or service provider may place the LPCB certification mark, as shown below, on the product, packaging and literature etc.

Where LPCB holds accreditation through the United Kingdom Accreditation Service (UKAS), the certified company may include the UKAS symbol (the Crown and Tick) alongside the LPCB mark for certain applications e.g. promotional literature or material and stationery, as shown below.

(Full details of LPCB accreditation can be found on the UKAS website at www.ukas.com)

Where for reasons of space or cost the use of the above full mark is not practical, then the following simplified mark may be applied directly to the product (for some schemes only). The LPCB scheme rules define how and where the marks can be used.

Part 2

*Fire doors, shutters and
installers of fire and security
doors*

FIRE DOORS, SHUTTERS AND INSTALLERS OF FIRE AND SECURITY DOORS

INTRODUCTION

Fire doors and shutters contribute to the passive fire protection of buildings by maintaining the:

- fire separation of compartment walls, while allowing the passage of persons or objects
- fire separation in shafts or service ducts that penetrate compartment floors
- protection provided by walls forming protected routes for means of escape.

In addition to careful design and product selection, it is recommended that all products are installed and maintained by LPCB approved contractors who have demonstrated their competence.

Products

Doors and shutter assemblies are approved in accordance with: LPS 1056: *Test and Evaluation*

Requirements for the Approval and Listing of Fire Doorsets, Lift Landing Doors and Shutter Assemblies.

The fire testing element of this LPS is based on BS 476:Part 22 - *Fire Tests on Building Materials and Structures Part 22: Methods for Determination of the Fire Resistance of Non- Load bearing Elements of Construction*

EN 1634-1 *Fire resistance test for doors and shutter assemblies- Part 1: Fire doors and shutters* and EN 81-58 *Landing doors fire resistance test.*

LPS 1056 also includes requirements for the reliability testing of the door and shutter assemblies, and assessment procedures for doors and shutters that are too big to be directly fire tested.

Installation contractors

LPCB approved installation contractors are assessed in accordance with: LPS 1271: *Requirements for LPCB Approval and Listing of companies installing fire and security doors, doorsets, shutters and active fire/smoke barriers.*

Maintenance contractors

LPCB approved maintenance contractors who repair and maintain fire doors and shutters are approved in accordance with: LPS 1197: *Requirements for LPCB Approval and Listing of companies inspecting, repairing and maintaining fire and security doors, doorsets, shutters and active fire/smoke barriers.*

TABLE OF CONTENTS

Firebreak doors and shutters	2
Lift landing doors	6
LPS 1197 - Inspection, repair and maintenance of fire and security doors and shutters	12
LPS 1271 - Fire and security door and shutter installers	23

FIREBREAK DOORS AND SHUTTERS

This section lists firebreak doorsets and shutters approved to:-

- LPS 1056 *Test and Evaluation requirements for the LPCB Approval and Listing of Fire Doorsets, Lift Landing Doors and Shutter Assemblies*. LPS 1056 is based upon relevant BS or European test criteria and not only looks at the fire integrity and insulation (where applicable) but also includes reliability cyclic tests and grading, or
- EN 81-58 *Landing doors fire resistance test*, and/or
- EN 1634-1 *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware*. *Fire resistance test for door and shutter assemblies and openable windows*

For details of the specific fire resistance required for firebreak doors and shutters for different building types, see the *LPC Design Guide for the Fire Protection of Buildings:2000*.

Where insulation is marked as 0, this denotes that the insulation was not measured or that it could not be measured in accordance with the relevant standard.

Alufire Sp.Z o.o.Sp.K

Ul. Warszawka 64a, 87-148 Lysomice K. Torunia, Poland

Tel: +48 56 674 88 11

E-mail: biuro@alufire.pl • Website: <http://www.alufire.biz.pl/>

Certificate No: 1406b to LPS 1056

Product Name	LPCB Ref. No.
ALUFIRE EI30 single leaf	1406b/01
ALUFIRE EI30 double leaf	1406b/02
ALUFIRE EI60 single leaf	1406b/03
ALUFIRE EI60 double leaf	1406b/04

Clark Door Limited

Unit F Central, Kingmoor Park, Carlisle, Cumbria, CA6 4SD, United Kingdom

Tel: +44 (0)1228 522321

E-mail: mail@clarkdoor.com • Website: www.clarkdoor.com

Certificate No: 106a to LPS 1056 Issue 6

Fireman

Product Name	LPCB Ref. No.
Fireman Single leaf hinged doorset	106a/02
Fireman Double leaf hinged doorset	106a/03

Fort Engineering Ltd

Unit E, Bramingham Business Park, Enterprise Way, Luton, Beds, LU3 4BU, United Kingdom

Tel: +44 (0)1582 592541

E-mail: info@fortengineering.co.uk

Certificate No: 1607a to LPS 1056: Issue 6

Product Name	Leaf Type	Maximum Leaf Size Height (m)	Maximum Leaf Size Width (m)	Maximum Leaf Size Area (m²)	Filling/Glazing	Fire Resistance EN 1634-1 Classification to EN 13501-2	LPCB Ref. No.
Fort 001	Insulated, single, hinged, active leaf	2100	1000	2.10	No	EI230	1607a/01
Fort 002LP2S	Insulated, single, hinged, active leaf	2100	1000	2.10	No	EI230	1607a/02

FIREBREAK DOORS AND SHUTTERS

Hart Door Systems

Redburn Road, Westerhope Industrial Estate, Westerhope, Newcastle upon Tyne, NE5 1PJ, United Kingdom

Tel: +44 (0)191 214 0404

E-mail: info@hartdoors.com • Website: www.hartdoors.com

Certificate No: 016d to LPS 1056 Issue 6

Firebrand

Product Name	Door Type	Range of Roller Shutter Height (mm)	Range of Roller Shutter Width (mm)	Reliability (self closing durability ref LPS 1056 clause 3.6)	Fire Resistance (min) EN 1634-1 Integrity	LPCB Ref. No.
Firebrand	Face-fixed rolling shutter	3000	3000	No performance determined	30, 60, 120 and 240	016d/01
Firebrand	Face-fixed rolling shutter	4500	4151	No performance determined	30, 60, 120 and 240	016d/01
Firebrand	Face-fixed rolling shutter	4300	5251	No performance determined	30, 60, 120 and 240	016d/01
Firebrand	Face-fixed rolling shutter	5500	5900	No performance determined	30, 60, 120 and 240	016d/01
Firebrand	Face-fixed rolling shutter	7000	7000	No performance determined	30, 60, 120 and 240	016d/01
Firebrand	Face-fixed rolling shutter	3672	8000	No performance determined	30 and 60	016d/01
Firebrand	Face-fixed rolling shutter	3672	9000	No performance determined	30 and 60	016d/01
Firebrand	Face-fixed rolling shutter	3672	10000	No performance determined	30 and 60	016d/01
Firebrand	Face-fixed rolling shutter	1200	6000	No performance determined	30 and 60	016d/01

Hörmann KG Freisen

Bahnhofstrasse 43, D-66629 Freisen, Germany

Tel: +49 (0) 6855 9930

E-mail: k.schmitt.frs@hoermann.de • Website: www.hoermann.de

Certificate No: 655a to LPS 1056: Issue 6.2

Fire Doorsets, Lift landing doors and shutters

Product Name	Door Type	Vision Panel Glass Type	Maximum Leaf Size (see certificate note 11) Height (mm)	Maximum Leaf Size (see certificate note 11) Width (mm)	Maximum Leaf Size (see certificate note 11) Area (m²)	Vision Panel Max Clear View Height (mm)	Vision Panel Max Clear View Width (mm)	Vision Panel Max Clear View Area (m²)	Fire Resistance (min) BS 476 Part 22 Integrity / Insulation	LPCB Ref. No.
HBS 60 C-1	Single Leaf Hinged Door	6.5mm Georgian-wired	2487	1242	3.088	937	522	0.40	60 / 0	655a/07
HBS 60 C-2	Double Leaf Hinged Door	6.5mm Georgian-wired	2487	1242	3.088	937	522	0.40	60 / 0	655a/08
HBS 90 C-1	Single Leaf Hinged Door	6.5mm Georgian-wired	2487	1242	3.088	781	435	0.34	90 / 0	655a/09
HBS 90 C-2	Double Leaf Hinged Door	6.5mm Georgian-wired	2487	1242	3.088	781	435	0.34	90 / 0	655a/10
HBS 120 C-1	Single Leaf Hinged Door	6.0mm Pyran S	2487	1242	3.088	1002	264	0.22	120 / 0	655a/11
HBS 120 C-2	Double Leaf Hinged Door	6.0mm Pyran S	2487	1242	3.088	1002	264	0.22	120 / 0	655a/12
HBS 30 D-1	Single Leaf Hinged Door	Promaglas 90/35 Type 1.0	4225	1950	6.580	2085	1080	2.25	30 / 0	655a/13
HBS 60 D-1	Single Leaf Hinged Door	Promaglas 90/35 Type 1.0	4062	1875	6.330	2085	1080	2.25	60 / 0	655a/14
HBS	Single	Promaglas	3770	1740	5.850	2085	1080	2.25	90 / 0	655a/15

FIREBREAK DOORS AND SHUTTERS

90 D-1	Leaf Hinged Door	90/35 Type 1.0								
HBS 30 F-2	Double Leaf Hinged Door	-	4021	1841	6.16	-	-	-	30 / 30	655a/16
HBS 60 F-2	Double Leaf Hinged Door	-	4021	1841	6.16	-	-	-	60 / 30	655a/17
HBS 90 F-2	Double Leaf Hinged Door	-	3217	1473	4.74	-	-	-	90 / 30	655a/18
HBS 90 C-1	Single Leaf Hinged Door	6.0mm Pyran S	2487	1242	3.088	1002	264	022	90 / 30	655a/09

LBS Security Services Limited T/A LBS Group

Unit 6, Sterling Trading Estate, Rainham Road South, Dagenham, Essex, RM10 8TX, United Kingdom

Tel: +44 (0)208 526 8572

E-mail: sales@lbsgroup.co.uk • Website: www.lbsgroup.co.uk

Certificate No: 247b to LPS 1056 Issue 6.2

Fireguard

Product Name	Type	Maximum Clear Height (m)	Maximum Clear Width (m)	Maximum Area (m²)	Fire Resistance Integrity (Insulation min)	LPCB Ref. No.
Fireguard	Rolling Shutter	6	6	36	240	247b/01
Fireguard	Rolling Shutter	7	7	49	120	247b/01
Fireguard	Rolling Shutter	3.5	10	35	120	247b/01

Mercian Shutters Limited

Pearsall Drive, Brades Road Industrial Estate, Oldbury, West Midlands, B69 2RA, United Kingdom

Tel: +44 (0)121 544 6124

E-mail: info@merciandoors.co.uk; roger.gear@merciandoors.co.uk • Website: www.merciandoors.co.uk

Certificate No: 355b to LPS 1056: Issue 5 excluding installation

Fire rated shutters

Product Name	Spec.	Door Type	Max Height (m)	Max Width(m)	Max Area (m²)	Fire Resistance(min)BS 476: Part 22Integrity	Fire Resistance(min)BS 476: Part 22Insulation	LPCB Ref. No.
SF Series	4	Rolling shutter	7.00	7.00	49.00	60 & 120	0	355b/01

Notes:

1. SF series rolling shutters ref 355b/01 - Reference must be made to assessment report no CC242948 issue 2 dated 11 June 2008 to confirm component dimensions relevant to the system size and fire resistance required.

Premier SS Limited

Unit 2, 19-21 Roebuck Road, Hainault Business Park, Hainault, Essex, IG6 3TU, United Kingdom

Tel: +44 (0)20 8559 8295

E-mail: sales@premier-ssl.com • Website: www.premier-ssl.com

Certificate No: 1097f to LPS 1056 Issue 6

Premier Fire Rated

Product Name	Leaf Type	Maximum Opening Size Height (mm)	Maximum Opening Size Width (mm)	Maximum Opening Size Area (m²)	Filling/Glazing	Fire Resistance Classification to EN13501-2	LPCB Ref. No.
Premier Fire	Single active	2547	1311	3.03	One layer of 6mm-thick Hammerglass (902mm x 1962mm) and one layer of Pyrogard T-E160 33mm-thick fire-rated glass (905mm x 1965mm)	EI260-C0	1097f/01

FIREBREAK DOORS AND SHUTTERS

Rated Fully Glazed	leaf, hinged, glazed							
Premier Fire Rated Fully Glazed	Single active leaf, hinged, glazed	2547	1311	3.03	One layer of 6mm-thick Hammerglass (902mm x 1962mm) and one layer of Pyroguard T-E160 33mm-thick fire-rated glass (905mm x 1965mm)	E90-C0	1097f/01	
Premier Fire Rated Solid	Single active leaf, hinged, insulated	2490	1311	2.96	2mm steel sheet against the lip, two layers of 12.5mm Fermacell fire board, two layers of 10mm Fermacell fire board and a 1mm steel sheet	EI260-C0	1097f/02	
Premier Fire Rated Louvre 1	Single active leaf, hinged, louvred	2215	1140	2.53	A 1801mm x 891mm Premier Fire Grille ('Dufaylite Fireblock Ultra fire grille')	E60-C0	1097f/03	
Premier Fire Rated Louvre 2	Single active leaf, hinged, louvred	2490	1334	3.01	Two 600mm x 600mm x 38mm-deep Premier Fire Grille (Dufaylite Fireblock Ultra fire grille). The remaining opening between Premier Fire Grille is filled 2mm steel sheet against the lip, two sheets of 12.5mm Fermacell board and one sheet of 1mm steel fitted from the exposed face	E90-C0	1097f/04	

Technocover Limited (incorporating TechnoRail and Strataform)

Henfaes Lane, Welshpool, Powys, SY21 7BE, United Kingdom

Tel: +44 (0)1938 555511

E-mail: techadvice@technocover.co.uk • Website: www.technocover.co.uk

Certificate No: 450g to LPS 1056: Issue 6.2

Product Name	Door Type	Maximum Leaf Size (per leaf) Height (mm)	Maximum Leaf Size (per leaf) Width (mm)	Maximum Leaf Size (per leaf) (m ²)	Door Hardware Variations	BS 476: Part 22 Fire Resistance (minutes) Integrity/Insulation	Reliability (self closing Durability Ref LPS 1056 Clause 3.6)	LPCB Ref. No.
Sentinel UltraSecure	DS1/LV single leaf outward opening hinged doorset uninsulated	2200	940	2.06	SM(3), SM(4), SM(6), SM(7), SM(10), SM(13), SM(14), SM(16), SM(17), SM(20), SM(23), SM(24), SM(26), SM(27) & SM(30)	240 / 0	No performance determined	450g/01
Sentinel UltraSecure	DS1/LV single leaf outward opening hinged doorset uninsulated	2640	1128	2.58	SM(3), SM(4), SM(6), SM(7), SM(10), SM(13), SM(14), SM(16), SM(17), SM(20), SM(23), SM(24), SM(26), SM(27) & SM(30)	120 / 0	No performance determined	450g/01
Sentinel UltraSecure	DS2/LV double leaf outward opening hinged doorset uninsulated	2215	975	2.15	SM(3), SM(4), SM(6), SM(7), SM(10), SM(13), SM(14), SM(16), SM(17), SM(20), SM(23), SM(24), SM(26), SM(27) & SM(30)	240 / 0	No performance determined	450g/02
Sentinel UltraSecure	DS2/LV double leaf outward opening hinged doorset uninsulated	2768	1218	2.80	SM(3), SM(4), SM(6), SM(7), SM(10), SM(13), SM(14), SM(16), SM(17), SM(20), SM(23), SM(24), SM(26), SM(27) & SM(30)	120 / 0	No performance determined	450g/02

LIFT LANDING DOORS

This section lists lift landing doors approved to LPS 1056 *Test and Evaluation requirements for the LPCB Approval and Listing of Fire Doorsets, Lift Landing Doors and Shutter Assemblies*. LPS 1056 is based upon relevant BS or European test criteria and not only looks at the fire integrity and insulation (where applicable) but also includes reliability cyclic tests and grading.

Currently there are no products listed in this section.

Kone Corporation

Keilasatama 3, Espoo, 02150, Finland

Tel: +39 02 3395 2505

E-mail: roberto.zappa@kone.com • Website: www.kone.com

Certificate No: 1418a to EN81-58:2022

Lift Landing Doors

Product Name	Door Type (See Certificate Note 1)	Frame Type (See Certificate Note 9)	Supporting Construction	Minimum Opening Width (mm)	Maximum Opening Width (mm)	Maximum Opening Height (mm)	Fire Resistance (minutes) (EN81-58) (See Certificate Note 6) Integrity / Insulation / Radiation	Fire Resistance (minutes) (EN81-58) (See Certificate Note 6) Designed to Satisfy	LPCB Ref. No.
KES800 (non-insulated)	AMDL1	Narrow frame, frame, front	Masonry or concrete	700 (see note 8)	1300 (see note 8)	2760 (see note 8)	120/0/60	E120, EW60	1418a/01
KES800 (non-insulated)	AMDL1	Narrow frame, frame, front	Masonry or concrete	980	1500	3000	120/0/60	E120, EW60	1418a/01
KES800 (non-insulated)	AMDL1	Narrow frame	Masonry or concrete	980	1500	3450	60/0/0	E60	1418a/01
KES800 (non-insulated)	AMDL1	Narrow frame	Steel framed partition	840	1500	2875	90/0/60	E90, EW60	1418a/01
KES800 (non-insulated)	AMDL2	Narrow frame, frame, front	Masonry or concrete	700	1300	2760	120/0/60	E120, EW60	1418a/01
KES800 (non-insulated)	AMDL2	Narrow frame, frame, front	Masonry or concrete	840	1500	2875	120/0/60	E120, EW60	1418a/01
KES800 (non-insulated)	AMDL2	Narrow frame	Steel-framed partition	840	1500	2875	120/0/30	E120, EW30	1418a/01
KES800 (non-insulated)	AMDL3	Narrow frame, frame, front	Masonry or concrete	1200	1820	2800	120/0/60	E120, EW60	1418a/01
KES800 (non-insulated)	AMDL3	Narrow frame, frame, front	Masonry or concrete	1700	3000	3000	120/0/30	E120, EW30	1418a/01
KES800 (non-insulated)	AMDL3	Narrow frame, frame, front	Masonry or concrete	1700 (see note 5)	3000 (see note 5)	3000 (see note 5)	120/0/60 (see note 5)	E120, EW60	1418a/01
KES800 (non-insulated)	AMDL4	Narrow frame, frame, front	Masonry or concrete	900	1170	2760	120/0/60	E120, EW60	1418a/01
KES800 (non-insulated)	AMDL4	Narrow frame, frame, front	Masonry or concrete	1171	2106	2760	120/0/30	E120, EW30	1418a/01
KES800 (non-insulated)	AMDL5	Narrow frame	Masonry or concrete	1800	3000	3000	120/0/30	E120, EW30	1418a/01
KES800 (non-insulated)	AMDL1 Extra Heavy Duty (EHD)	Narrow frame, frame, front	Masonry or concrete	980	1820	2990	60/0/60	E60, EW60	1418a/01
KES800 (non-insulated)	AMDL2 Extra Heavy Duty (EHD)	Narrow frame, frame, front	Masonry or concrete	770	1430	2415	60/0/60	E60, EW60	1418a/01

LIFT LANDING DOORS

KES800 (non-insulated)	AMD L2 Extra Heavy Duty (EHD)	Narrow frame, frame, front	Masonry or concrete	840	1560	2875	60/0/30	E60, EW30	1418a/01
KES800 (non-insulated)	AMD L1	Narrow frame	Steel frame within masonry wall	700	1300	2760	60/0/60	E60, EW60	1418a/01
KES800 (non-insulated)	AMD L1	Narrow frame	CLT partition	700	1300	2760	60/0/60	E60, EW60	1418a/01
KES800 (non-insulated)	AMD L2	Narrow frame	CLT partition	840	1560	2875	60/0/60	E60, EW60	1418a/01
KES800 (non-insulated)	AMD L3	Narrow frame	Steel- framed partition	1400	1820	2760	90/0/30	E90, EW30	1418a/01
KES800 (non-insulated)	AMD L4	Narrow frame	Steel- framed partition	900	1170	2760	90/0/30	E90, EW30	1418a/01
KES800 (non-insulated)	AMD L5	Narrow frame	Steel- framed partition	1400	2600	2875	90/0/30	E90, EW30	1418a/01
KES800 (non-insulated)	AMD L3 Extra Heavy Duty	Narrow frame, frame, front	Masonry or concrete	980	1820	2760	60/0/60	E60, EW60	1418a/01
KES800 (non-insulated)	AMD L3 Extra Heavy Duty	Narrow frame, frame, front	Masonry or concrete	1260	2340	2415	60/0/60	E60, EW30	1418a/01

Certificate No: 1418b to EN-81-58: 2022

Lift Landing Doors

Product Name	Door Type (See Certificate Note 1)	Frame Type (See Certificate Note 6)	Maximum Door Width and Height (mm)	Glass Type	Glass Clear View Dimensions Width x Height (mm x mm)	Glass Location	Fire Resistance (Minutes) (EN81-58) (See Certificate Note 5) Integrity / Insulation / Radiation	Fire Resistance (Minutes) (EN81-58) (See Certificate Note 5) Designed to Satisfy	LPCB Ref. No.
KES800 (glazed)	AMD L1	Narrow frame, frame	1150x2400	17.3mm Pyrobel 16, 1.52mm plastic film, 5mm toughened glass	449x2180	Both door panels	30/30/30	E30; EI30; EW30	1418b/01
KES800 (glazed)	AMD L1	Narrow frame, frame	1270x2400	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	523x2198	Both door panels	60/0/30	E60; EW30	1418b/01
KES800 (glazed)	AMD L1	Narrow frame, frame	1430x2415	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	150x800	Left or right door leaf	120/0/60	EI20; EW60	1418b/01
KES800 (glazed)	AMD L1	Narrow frame, frame	1430x2415	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	150x800	Both door panels	120/0/60	EI20; EW60	1418b/01
KES800 (glazed)	AMD L2	Narrow frame, frame	1150x2400	17.3mm Pyrobel 16, 1.52mm plastic film, 5mm toughened glass	449x2180	Both door panels	30/30/30	E30; EI30; EW30	1418b/01
KES800 (glazed)	AMD L2	Narrow frame, frame	1270x2400	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	523x2198	Both door panels	60/0/30	E60; EW30	1418b/01
KES800 (glazed)	AMD L2	Narrow frame, frame	1300x2400	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	150x180	Fast or slow door leaf	120/0/60	EI20; EW60	1418b/01
KES800 (glazed)	AMD L2	Narrow frame, frame	1300x2400	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	150x180	Both door panels	120/0/60	EI20; EW60	1418b/01
KES800 (glazed)	AMD L3	Narrow frame, frame	1900x2400	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	363x2198	All four panels	60/0/0	E60	1418b/01
KES800 (glazed)	AMD L3	Narrow frame, frame	1800x2400	6mm Pyran S, 1.52mm plastic film, 4mm toughened glass	150x800	left or right fast panel	120/0/60	EI20; EW60	1418b/01
KES800 (glazed)	AMD L3	Narrow frame, frame	1800x2400	6mm Pyran S, 1.52mm plastic film, 4mm	150x800	Both fast panels	120/0/60	EI20; EW60	1418b/01

LIFT LANDING DOORS

toughened glass

Certificate No: 1418c to EN81-58:2022

Lift Landing Doors

Product Name	Door Type (See Certificate Note 1)	Frame Type (See Certificate Note 8)	Door Panel Insulation	Lintel Insulation	Side Posts/Side Panel Insulation	Fire Resistance (Minutes) (EN81-58) (See Certificate Note 7) Integrity / Insulation	Fire Resistance (Minutes) (EN81-58) (See Certificate Note 7) Designed to Satisfy	LPCB Ref. No.
KES800 (insulated)	AMDL1	Narrow Frame	16mm Gipsbifire K	None	None	30/30	EI30	1418c/01
KES800 (insulated)	AMDL1	Narrow Frame	20mm Microtherm	None	None	60/60	EI60	1418c/01
KES800 (insulated)	AMDL1	Narrow Frame	18mm Liftbifire	None	None	60/60	EI60	1418c/01
KES800 (insulated)	AMDL1	Narrow Frame	26mm Liftbifire	None	None	120/120	EI120	1418c/01
KES800 (insulated)	AMDL1	Frame	16mm Gipsbifire K	40mm Paroc Slab	25mm Paroc Slab	30/30	EI30	1418c/01
KES800 (insulated)	AMDL1	Frame	20mm Microtherm	40mm Paroc Slab	25mm Paroc Slab	60/60	EI60	1418c/01
KES800 (insulated)	AMDL1	Frame	18mm Liftbifire	40mm Paroc Slab	25mm Paroc Slab	60/60	EI60	1418c/01
KES800 (insulated)	AMDL1	Front	16mm Gipsbifire K	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	16mm Gipsbifire K	30/30	EI30	1418c/01
KES800 (insulated)	AMDL1	Front	20mm Microtherm	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	20mm Microtherm	60/60	EI60	1418c/01
KES800 (insulated)	AMDL1	Front	18mm Liftbifire	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	18mm Liftbifire	60/60	EI60	1418c/01
KES800 (insulated)	AMDL2	Narrow Frame	16mm Gipsbifire K	None	None	30/30	EI30	1418c/01
KES800 (insulated)	AMDL2	Narrow Frame	20mm Microtherm	None	None	60/60	EI60	1418c/01
KES800 (insulated)	AMDL2	Narrow Frame	18mm Liftbifire	None	None	60/60	EI60	1418c/01
KES800 (insulated)	AMDL2	Narrow Frame	26mm Liftbifire	None	None	120/120	EI120	1418c/01
KES800 (insulated)	AMDL2	Frame	16mm Gipsbifire K	40mm Paroc Slab	25mm Paroc Slab (trailing) 25mm/30mm Paroc Slab (slam)	30/30	EI30	1418c/01
KES800 (insulated)	AMDL2	Frame	20mm Microtherm	40mm Paroc Slab	25mm Paroc Slab (trailing) 25mm/30mm Paroc Slab (slam)	60/60	EI60	1418c/01
KES800 (insulated)	AMDL2	Frame	18mm Liftbifire	40mm Paroc Slab	25mm Paroc Slab (trailing) 25mm/30mm Paroc Slab (slam)	60/60	EI60	1418c/01
KES800 (insulated)	AMDL2	Front	16mm Gipsbifire K	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	16mm Gipsbifire K (trailing) 25mm/30mm Paroc Slab (slam)	30/30	EI30	1418c/01
KES800 (insulated)	AMDL2	Front	20mm Microtherm	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	20mm Microtherm (trailing) 25mm/30mm Paroc Slab (slam)	60/60	EI60	1418c/01
KES800 (insulated)	AMDL2	Front	18mm Liftbifire	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	20mm Microtherm (trailing) 25mm/30mm Paroc Slab (slam)	60/60	EI60	1418c/01
KES800 (insulated)	AMDL3	Narrow Frame	16mm Gipsbifire K	None	None	30/30	EI30	1418c/01
KES800 (insulated)	AMDL3	Narrow Frame	20mm Microtherm	None	None	60/60	EI60	1418c/01

LIFT LANDING DOORS

KES800 (insulated)	AMDL3	Narrow Frame	18mm Liftbifire	None	None	60/60	EI60	1418c/01
KES800 (insulated)	AMDL3	Narrow Frame	26mm Liftbifire	None	None	120/120	EI120	1418c/01
KES800 (insulated)	AMDL3	Frame	16mm Gipsbifire K	40mm Paroc Slab	25mm Paroc Slab	30/30	EI30	1418c/01
KES800 (insulated)	AMDL3	Frame	20mm Microtherm	40mm Paroc Slab	25mm Paroc Slab	60/60	EI60	1418c/01
KES800 (insulated)	AMDL3	Frame	18mm Liftbifire	40mm Paroc Slab	25mm Paroc Slab	60/60	EI60	1418c/01
KES800 (insulated)	AMDL3	Front	16mm Gipsbifire K	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	16mm Gipsbifire K	30/30	EI30	1418c/01
KES800 (insulated)	AMDL3	Front	20mm Microtherm	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	20mm Microtherm	60/60	EI60	1418c/01
KES800 (insulated)	AMDL3	Front	18mm Liftbifire	40mm Paroc Slab for lintel heights up to 195mm, 25mm Insulfrax + 25mm Paroc Slab for lintel heights over 195mm	18mm Liftbifire	60/60	EI60	1418c/01
KES800 (insulated)	AMDL1	Narrow frame	26mm Safeinsul SP180	None	None	120/120	EI120	1418c/01
KES800 (insulated)	AMDL2	Narrow frame	26mm Safeinsul SP180	None	None	120/120	EI120	1418c/01
KES800 (insulated)	AMDL3	Narrow frame	26mm Safeinsul SP180	None	None	120/120	EI120	1418c/01

Certificate No: 1418d to EN81-58:2022 EN1634-3:2004

Lift Landing Doors

Product Name	Product Name	Door Type (see certificate note 1)	Frame Type (see certificate note 8)	Maximum Door Width and Height (mm)	Fire Resistance (minutes) (EN81-58) (see certificate note 5) Integrity/Insulation/Radiation	Fire Resistance (minutes) (EN81-58) (see certificate note 5) Designed to Satisfy	Smoke Control Test Pressure (Pa) to EN1634- 3 (see certificate note 9) Test Pressure (Pa)	LPCB Ref. No.
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	120/0/0	E120	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	60/0/60	EW60	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	30/30/0	EI30	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	60/60/0	EI60	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	120/120/0	EI120	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Front/Full Front	1100 x 2300	120/0/0	E120	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Front/Full Front	1100 x 2300	60/0/60	EW60	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Front/Full Front	1100 x 2300	30/30/0	EI30	-	1418d/02
KES202	KES202 (AMDL/V2.0)	AMDL1 (centre opening) /	Front/Full Front	1100 x 2300	60/60/0	EI60	-	1418d/02

LIFT LANDING DOORS

		AMDL2 (side opening)						
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	120/0/0	E120	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	60/0/60	EW60	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	30/30/0	EI30	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	60/60/0	EI60	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Frameless/Narrow Frame/Frame	1300 x 2300	120/120/0	EI120	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Front/Full Front	1100 x 2300	120/0/0	E120	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Front/Full Front	1100 x 2300	60/0/60	EW60	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Front/Full Front	1100 x 2300	30/30/0	EI30	-	1418d/04
KES602	KES602 (AMDL/V2.0)	AMDL1 (centre opening) / AMDL2 (side opening)	Front/Full Front	1100 x 2300	60/60/0	EI60	-	1418d/04

Certificate No: 1418e to EN81-58:2022

Lift Landing Doors

Product Name	Door Type	Frame Type (see certificate note 9)	Door Panel Insulation	Lintel Insulation	Side Posts/Side Panel Insulation	Fire Resistance (minutes) (EN51-58) Integrity/Insulation/Radiation	LPCB Ref. No.
KES100	AMDSL3	Frame	None	40mm (25mm + 15mm) Paroc Slab	None	120/-/60	1418e/01
KES100	AMDSL3	Frame	16mm Gipsbifire K	40mm (25mm + 15mm) Paroc Slab	None for widths up to 99.5mm, 25mm Paroc Slab for widths over 100mm	120/30/60	1418e/01
KES100	AMDSL3	Frame	20mm Microtherm	40mm (25mm + 15mm) Paroc Slab	None for widths up to 99.5mm, 25mm Paroc Slab for widths over 100mm	120/60/60	1418e/01
KES100	AMDSL3	Front	None	40mm (25mm + 15mm) Paroc Slab	None for widths up to 1600mm* 25mm Paroc Slab for widths over 1600mm*	120/-/60	1418e/01
KES100	AMDSL3	Front	16mm Gipsbifire K	40mm (25mm + 15mm) Paroc Slab for widths up to 299mm 16mm Gipsbifire K for widths over 300mm	25mm Paroc Slab for widths up to 299mm, 16mm Gipsbifire K for widths over 300mm	120/30/60	1418e/01
KES100	AMDSL3	Front	20mm Microtherm	40mm (25mm + 15mm) Paroc Slab for widths up to 299mm 20mm Gipsbifire K for widths over 300mm	25mm Paroc Slab for widths up to 299mm, 20mm Gipsbifire K for widths over 300mm	120/60/60	1418e/01
KES100	AMDSL4	Frame	None	40mm (25mm + 15mm) Paroc Slab	None	120/-/60	1418e/01
KES100	AMDSL4	Frame	16mm Gipsbifire K	40mm (25mm + 15mm) Paroc Slab	None for widths up to 99.5mm, 25mm Paroc Slab for widths over 100mm; 25mm/35mm for slam post widths over 100mm	120/30/60	1418e/01
KES100	AMDSL4	Frame	20mm Microtherm	40mm (25mm + 15mm) Paroc Slab	None for widths up to 99.5mm, 25mm Paroc Slab for widths over 100mm; 25mm/35mm for slam post widths over 100mm	120/60/60	1418e/01
KES100	AMDSL4	Front	None	40mm (25mm + 15mm)	None for door widths up to 1600mm; 25mm	120/-/60	1418e/01

LIFT LANDING DOORS

				Paroc Slab	Paroc Slab for side post of doors with widths over 1600mm* 25mm/35mm Paroc Slab for slam post of door with widths over 1600mm*		
KES100	AMDSL4	Front	16mm Gipsbifire K 300mm	40mm (25mm + 15mm) Paroc Slab for widths up to 299mm, 16mm Gipsbifire K for widths over 300mm	25mm Paroc Slab for widths up to 299mm, 25mm/35mm Paroc Slab for slam posts widths up to 299mm, 16mm Gipsbifire K for widths over 300mm	120/30/60	1418e/01
KES100	AMDSL4	Front	20mm Microtherm	40mm (25mm + 15mm) Paroc Slab for widths up to 299mm, 20mm Microtherm for widths over 300mm	25mm Paroc Slab for widths up to 299mm, 25mm/35mm Paroc Slab for slam posts widths up to 299mm, 20mm Microtherm for widths over 300mm	120/60/60	1418e/01

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

This section lists companies approved to LPS 1197 *Requirements for LPCB Approval and Listing of companies inspecting, repairing and maintaining fire and security doors, doorsets, shutter and active smoke/fire barriers.*

The long term performance of products covered in this standard is dependent upon regular inspection, repair and maintenance in accordance with the manufacturers recommendations. Companies approved to LPS 1197 have demonstrated their ability to carry out this work effectively. The listings include the geographical areas and products covered by the companies and the level of service provided.

123 Fire (a division of MB Plant Limited)

F16, Raise Business Centre , Tom Pudding Way , Goole, Derbyshire, DN14 6BS, United Kingdom

Tel: 0114 360 3213

E-mail: andrewbell@123fire.co.uk • Website: www.123fire.co.uk

Certificate No: 1133Pla to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

Adaptive Fire Protection Limited

136 Boden Street, Glasgow, G40 3PX, United Kingdom

Tel: 0141 556 7720

E-mail: steven.elliott@adaptivefpltd.com

Certificate No: 1316PIb to LPS 1197: Issue 4

Company assessed and approved for:

- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

Hinged and pivoted steel doorsets

Ascot Doors (Service) Ltd

Britannia Way Industrial Park, Union Road, Bolton, BL2 2HE, United Kingdom

Tel: +44 (0)1204 545801

E-mail: sales@ascotdoors.co.uk • Website: www.ascotdoors.co.uk

Certificate No: 1562Pla to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Security doors

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

Security shutters
Product groups:
Hinged and pivoted steel doorsets
Steel rolling shutters

Assured Fire Safety Consultancy Ltd

Centaur House, Ancells Business Park, Ancells Road, Fleet, Hampshire, GU51 2UJ, United Kingdom
Tel: 07487 774 714
E-mail: Jfrench@assuredfds.com • Website: www.assuredfds.com

Certificate No: 1593PI to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection

Product groups:

Hinged and pivoted steel doorsets

Hinged and pivoted timber doorsets

Avert Fire (UK) Ltd

Dawes lane, Scunthorpe, North Lincolnshire, DN16 1DW, United Kingdom
Tel: +44 (0)1724 853712
E-mail: admin@avertfire.co.uk • Website: www.avertfire.co.uk

Certificate No: 850PIb to LPS 1197: Issue 4

Approved installer of certified fire doors and doorsets.

Company assessed and approved for:

- Inspection

- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted steel doorsets

Hinged and pivoted timber doorsets

Capital Maintenance Ltd

207 Regent Street, London, W1B 4ND, United Kingdom
Tel: 0207 6295100
E-mail: ross@capitalmaintenanceltd.com • Website: www.capitalmaintenanceltd.com

Certificate No: 1675PI to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection, maintenance services and repair, term contracts

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted steel doorsets

Hinged and pivoted timber doorsets

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

Hinged and pivoted glass doorsets

Checkmate Fire Solutions Ltd

2nd Floor, Rosemount House, Rosemount Estate, Huddersfield Road, Elland, West Yorkshire, HX5 0EE, United Kingdom

Tel: +44 (0) 1422 376436

E-mail: info@checkmatefire.com • Website: www.checkmatefire.com

Certificate No: 860Pla to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

Hinged and pivoted steel doorsets

Checkmate Fire Solutions Ltd

Cambridge House, Cambridge Road, Harlow, Essex, CM20 2EQ, United Kingdom

Tel: +44 (0) 1279 850021

E-mail: info@checkmatefire.com • Website: www.checkmatefire.com

Certificate No: 860Pla to LPS 1197 : Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Hinged and pivoted timber doorsets

Hinged and pivoted steel doorsets

Churches Fire Security Limited

Fire House, Mayflower Close, Chandlers Ford, Eastleigh, Hampshire, SO53 4AR, United Kingdom

Tel: 0370 608 4350

E-mail: sales@churchesfire.com • Website: www.churchesfire.com

Certificate No: 1557PI to LPS 1197: Issue 4

Company assessed and approved for:

- Maintenance services and 'one off' general repair
- Inspection

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

Security Doors

DoorCheck Limited

192b Balfour Road, Ilford, Essex, IG1 4JA, United Kingdom
Tel: 0208 553 3307
E-mail: info@door-check.co.uk • Website: www.door-check.co.uk

Certificate No: 1119PI to LPS 1197: Issue 4

General servicing and maintenance of fire doors and fire doorsets

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

Ductclean (UK) Limited

1 Woodfield Road, Welwyn Garden City, Hertfordshire, AL7 1JQ, United Kingdom
Tel: 0870 1129196
E-mail: jamie.carraher@dcukfm.com • Website: www.ductclean.co.uk

Certificate No: 1276PIc to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection, maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

Fire Risk Management Associates Limited

Townsend Farm, 11 High Street, Upwood, Cambridgeshire, PE26 2QE, United Kingdom
Tel: 0800 9992244
E-mail: joe.ruane@frmaltld.com • Website: www.frmaltld.co.uk

Certificate No: 1412PIb to LPS 1197: Issue 4

Company assessed and approved for the inspection of the products listed below:

- Fire Resistant Doors and Doorsets
 - Hinged and Pivoted Timber Doorsets
-

General Electronic Access Ltd T/A GEA Automation

14 Nordic Enterprise Park, Knockgriffin, Middleton, Cork, Ireland, PS5Y 037, Ireland
Tel: +353214613830
E-mail: r.gill@gea.ie • Website: <https://gea.ie/>

Certificate No: 1839PIa to LPS 1197 Issue 4

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

the company is assessed and approved for :

- Inspection
- Inspection, maintenance services and repair, term contracts

Product Groups :

- Hinged and pivoted steel doorsets
- Hinged and pivoted timber doorsets
- Steel rolling shutters
- Operable fabric curtains

Golden Thread Fire Delay Ltd

Unit 6 Everik Business Centre, Prospect Way, Hutton, Essex, CM13 1XG, United Kingdom

Tel: 01277 263944

E-mail: info@goldenthreadfiredelay.com • Website: www.goldenthreadfiredelay.com

Certificate No: 1579PIb to LPS 1197: Issue 4

Company assessed and approved for:

Inspection, maintenance services and repair, term contracts

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted steel doorsets

Hinged and pivoted timber doorsets

- Inspection, maintenance services and repair, term contracts

GSH (South West Consultancy) Ltd

Unit 17 Bridgwater Court, Oldmixon Crescent, Weston Super Mare, BS24 9AY, United Kingdom

Tel: 0333 456 4646

E-mail: info@gshprojects.co.uk • Website: www.gshprojects.co.uk

Certificate No: C1561PIb to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection, maintenance services and repair, term contracts

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

Konecranes Demag UK Ltd

Unit 1, Charter Point, Coalfield Way, Ashby Business Park, Ashby De La Zouch, Leicestershire, LE65 1NF, United Kingdom

Tel: 0844 5611 007

E-mail: scott.wright@konecranes.com • Website: www.konecranes.com

Certificate No: 908a to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection, maintenance services and 'one off' general repair, inspection maintenance services and repair, term contracts of the products listed below

Of:

Fire and Security Doors and Shutters

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

LBS Security Services Limited T/A LBS Group

Unit 6, Sterling Trading Estate, Rainham Road South, Dagenham, Essex, RM10 8TX, United Kingdom

Tel: +44 (0)208 526 8572

E-mail: sales@lbsgroup.co.uk • Website: www.lbsgroup.co.uk

Certificate No: 247a to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair
- Inspection, maintenance services and repair, term contracts
- Emergency repair and response services

Of:

Fire resistant shutters

Product groups:

Steel rolling shutters

Mercian Shutters Limited

Pearsall Drive, Brades Road Industrial Estate, Oldbury, West Midlands, B69 2RA, United Kingdom

Tel: +44 (0)121 544 6124

E-mail: info@merciandoors.co.uk; roger.gear@merciandoors.co.uk • Website: www.merciandoors.co.uk

Certificate No: 355a to LPS 1197: Issue 4

Company assessed and approved for maintenance services and general repair, inspection maintenance services and repair, term contracts and emergency repair and response services of the products listed below:

Fire Products:

- Steel rolling shutters

Security Products:

- Shutters

On site within 4 hours of call in Hereford and Worcestershire, Shropshire, Staffordshire, Warwickshire and West Midlands.

Neo Property Solutions Limited

Neo Court, Knowsthorpe Lane, Cross Green Industrial Estate, Leeds, West Yorkshire, LS9 0PF, United Kingdom

Tel: 08434554455

Certificate No: 1539PIb to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

OMNI Interior Solutions Ltd

Lawmuir Road, Law, ML8 5JB, United Kingdom

Tel: 0845 450 1601

E-mail: rcowan@omni-interiors.co.uk • Website: www.omni-interiors.co.uk/

Certificate No: 1627Pla to

Company assessed and approved for:

- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Pacific Security Systems Ltd

Unit 4 Stag Enterprise Park , Leacon Road , Ashford , Kent , TN23 4TW , United Kingdom

Tel: 0870 8508404

E-mail: Alan@pacific-uk.co.uk • Website: www.pacific-uk.co.uk

Certificate No: 1838PI to LPS 1197 Issue 4, LPS 1197

the company is assessed and approved for :

- Inspection
- Maintenance services and one off general repair
- Inspection, maintenance services and repair, term contracts

Of :

- Fire resistant doors and doorsets

Product Groups :

- Hinged and pivoted steel doorsets
- Hinged and pivoted timber doorsets

PB Services (London) Ltd

Brick Lane, Stanmore, HA7 1RE, United Kingdom

Tel: 0208 952 8282

E-mail: peter@pbserviceslondon.com

Certificate No: 1651Pla to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Product groups:

Hinged and pivoted timber doorsets

Prestige Fire Door Services trading as Sunray Timber Doors Division

Unit 6 Wotton Trading Estate, Wotton Road, Ashford, Kent, TN23 6LL, United Kingdom

Tel: +44 (0)1233 639039

E-mail: sales@prestigefiredoorservices.com • Website: www.prestigefiredoorservices.com

Certificate No: 1066PIb to LPS 1197: Issue 4

Company assessed and approved for inspection, maintenance services and repair, terms contracts of the products listed below:

- Fire Resistant Doors and Doorsets
- Hinged and Pivoted Steel Doorsets
- Hinged and Pivoted Timber Doorsets

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

Prospect Fire Ltd

Unit 1 Woodgate's Farm, Woodgate's End, Dunmow, CM6 2BN, United Kingdom

Tel: 01279 354988

E-mail: info@prospectfire.co.uk • Website: www.prospectfire.co.uk

Certificate No: 1631PIa to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection, Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted steel doorsets

Hinged and pivoted timber doorsets

Openable timber framed windows

Hinged and pivoted glass doorsets

Hinged and pivoted, metal framed, glazed doorsets and openable windows

Openable windows

R Lewis & Co. (UK) Ltd

Unit 7 Llandough Trading Estate, Cardiff, CF11 8RR, United Kingdom

Tel: +44 (0) 2920 215716

E-mail: craig.cleveland@rlewisfire.com • Website: www.rlewisandcoukltd.com

Certificate No: 1006PIb to LPS 1197: Issue 4

Company assessed and approved for inspection, maintenance services and "one off" general repair of the products listed below:

Fire resistant doors and doorsets

-Hinged and pivoted steel doorsets

-Hinged and pivoted timber doorsets

-Sliding timber doorsets

Rite Industrial Doors Ltd

9H Longbrooks, Knowle Road, Brenchley, Kent, TN12 7DJ, United Kingdom

Tel: 01892 7251000

E-mail: ray@ritedoors.co.uk • Website: www.ritedoors.co.uk

Certificate No: 1306PI to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection, maintenance services and repair, term contracts

Of:

Fire resistant shutters

Product groups:

Steel rolling shutters

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

Stanair Industrial Door Services Limited

2 Henson Way, Telford Way Industrial Estate, Kettering, Northamptonshire, NN16 8PX, United Kingdom

Tel: +44 (0)1536 482187

E-mail: info@stanair.co.uk • Website: www.stanair.co.uk

Certificate No: 141a to LPS 1197: Issue 4

Company assessed and approved for:

- Maintenance services and 'one off' general repair
- Inspection, maintenance services and repair, term contracts
- Emergency repair and response services

Of:

Fire resistant shutters

Product groups:

Steel rolling shutters

Strategic Fire Protection Ltd

Department , Leeds Dock 4 The Boulevard, Leeds, West Yorkshire, LS10 1PZ, United Kingdom

Tel: 07831 982129

E-mail: andy@strategicfireprotection.co.uk

Certificate No: 1753PIb to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection
- Maintenance services and 'one off' general repair

Of:

Fire resistant doors and doorsets

Sunray Engineering Limited

Kingsnorth Industrial Estate, Wotton Road, Ashford, Kent, TN23 6LL, United Kingdom

Tel: +44 (0)1233 639039

E-mail: sales@sunraydoors.co.uk • Website: www.sunraydoors.co.uk

Certificate No: 234j to LPS 1197: Issue 4

Product Groups: Fire

-Hinged and Pivoted Steel Doorsets

Product Groups: Security

-Shutters

TEK Interiors Limited

Unit 10A Beehive Business Centre, Beehive Lane, Great Baddow, Chelmsford, Essex, CM2 9TE, United Kingdom

Tel: 01245 250657

E-mail: Neil@tekfiredoorservices.co.uk • Website: www.tekfiredoorservices.co.uk

Certificate No: 1300PIa to LPS 1197: Issue 4

Company assessed and approved for:

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

- Inspection, maintenance services and repair, term contracts

Of:

Fire resistant doors and doorsets

Product groups:

Hinged and pivoted timber doorsets

Thameside Fire Protection Co. Limited

Unit 4, Sovereign Park, Cranes Farm Road, Basildon, Essex, SS14 3JD, United Kingdom

Tel: +44 (0)1268 597999

E-mail: darko.petrovic@thamesidefire.co.uk • Website: www.thamesidefire.co.uk

Certificate No: 269PIb to LPS 1197: Issue 4

Inspection, maintenance services and "one off" general repair of:

-Hinged and pivoted steel doorsets

-Hinged and pivoted timber doorsets

The Blue Rose Group Ltd

10 Kings Avenue , Poole , Dorset, BH14 9QF, United Kingdom

Tel: 07481123138

E-mail: bill.charles@theblurosegroupp.co.uk • Website: www.blurosegroupp.co.uk

Certificate No: 1810PI to LPS 1197: Issue 4

the company is assessed and approved for :

- Inspection

Of :

- Fire resistant doors and doorsets

Product Groups :

- Hinged and pivoted timber doorsets

Total Protection (Fire & Sealing) Solutions Ltd

The Coach House, West Hanningfield Road, Baddow Park, Chelmsford, Essex, CM2 7SY, United Kingdom

Tel: 01277 841415

E-mail: Ross@totalprotection.co.uk • Website: www.totalprotection.co.uk

Certificate No: 1375PIa to LPS 1197: Issue 4

Company assessed and approved for:

- Inspection, maintenance services and repair, term contracts

Product groups:

Hinged and pivoted steel doorsets

Hinged and pivoted timber doorsets

Tyco Fire and Integrated Solutions (the trading company for Tyco Fire and Integrated Solutions (UK) Limited and Tyco Fire and Integrated Solutions (Ireland) Limited)

Tyco Park, Grimshaw Lane, Newton Heath, Manchester, M40 2WL, United Kingdom

Tel: +44 (0)161 205 2321

Website: www.tycofis.com

Certificate No: 014c to LPS 1197: Issue 4

the company is assessed and approved for :

- Inspection

LPS 1197 - INSPECTION, REPAIR AND MAINTENANCE OF FIRE AND SECURITY DOORS AND SHUTTERS

- Maintenance services and one off general repair
- Inspection, maintenance services and repair, term contracts
- Emergency repair and response services

Of :

- Fire resistant doors and doorsets

Product Groups :

- Hinged and pivoted steel doorsets
 - Hinged and pivoted timber doorsets
-

Vanguard Fire Protection Limited

6-7 Clock Park , Shripney Road , Bognor Regis , PO22 9NH, United Kingdom

Tel: 0333 339 7225

E-mail: Dan@vanguardfireprotection.co.uk • Website: www.vanguardfireprotection.co.uk

Certificate No: C1857-01 to LPS 1197 Issue 4

the company is assessed and approved for :

- Inspection

Of :

- Fire resistant doors and doorsets

Product Groups :

- Hinged and pivoted timber doorsets
-

LPS 1271 - FIRE AND SECURITY DOOR AND SHUTTER INSTALLERS

This section lists companies approved to LPS 1271 *Requirements for LPCB Approval and Listing of companies installing fire and security doors, doorsets, shutters and smoke/fire barriers*. This standard was developed to ensure that the product performance is not compromised by poor installation of the fire or security door or shutter. This section includes manufacturers installing doors and independent installation companies.

Information regarding the security of doors is available in Security Doorsets section.

Absolute Fire Safety Ltd

Colmworth Business Park, 4 Eaton Ct, Saint Neots, PE19 8ER, United Kingdom

Tel: 07500 598 527

E-mail: josh@absolutefiresafety.co.uk • Website: www.absolutefiresafety.co.uk

Certificate No: 1594Pla to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Adaptive Fire Protection Limited

136 Boden Street, Glasgow, G40 3PX, United Kingdom

Tel: 0141 556 7720

E-mail: steven.elliott@adaptivepltd.com

Certificate No: 1316Pla to LPS 1271: Issue 2

Company assessed and approved for installation of passive fire protection products under the following scope.

Appendix 2 - Fire Doors & Doorsets

Ascot Doors Limited

Britannia Way Industrial Park, Union Road, Bolton, BL2 2HE, United Kingdom

Tel: +44 (0)1204 545801

E-mail: sales@ascotdoors.co.uk • Website: www.ascotdoors.co.uk

Certificate No: 1562PI to LPS 1271: Issue 2

Approved installer of:

- Security Doors and Shutters

- Fire Doors and Doorsets

- Fire Rated Shutters

Assured Fire Safety Consultancy Ltd

Centaur House, Ancells Business Park, Ancells Road, Fleet, Hampshire, GU51 2UJ, United Kingdom

Tel: 07487 774 714

E-mail: Jfrench@assuredfds.com • Website: www.assuredfds.com

Certificate No: 1593Pla to LPS 1271 Issue 2

Approved installer of:

Appendices :

- Appendix 2 - Fire doors & doorsets

Avert Fire (UK) Ltd

Dawes lane, Scunthorpe, North Lincolnshire, DN16 1DW, United Kingdom

Tel: +44 (0)1724 853712

E-mail: admin@avertfire.co.uk • Website: www.avertfire.co.uk

Certificate No: 850Pla to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

C&S Facilities Management T/A C&S Group

351 Main Street, Blantyre, Scotland, G72 0DJ, United Kingdom

Tel: 0844 3351466

E-mail: kevincunning@c-s.org.uk • Website: www.c-s.org.uk

Certificate No: 1723Pla to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Capital Maintenance Ltd

207 Regent Street, London, W1B 4ND, United Kingdom

Tel: 0207 6295100

E-mail: ross@capitalmaintenanceltd.com • Website: www.capitalmaintenanceltd.com

Certificate No: 1675Pla to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Checkmate Fire Solutions Ltd

2nd Floor, Rosemount House, Rosemount Estate, Huddersfield Road, Elland, West Yorkshire, HX5 0EE, United Kingdom

Tel: +44 (0) 1422 376436

E-mail: info@checkmatefire.com • Website: www.checkmatefire.com

Certificate No: 860Plb to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Checkmate Fire Solutions Ltd

Cambridge House, Cambridge Road, Harlow, Essex, CM20 2EQ, United Kingdom

Tel: +44 (0) 1279 850021

E-mail: info@checkmatefire.com • Website: www.checkmatefire.com

Certificate No: 860Plb to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Clark Door Limited

Unit F Central, Kingmoor Park, Carlisle, Cumbria, CA6 4SD, United Kingdom
Tel: +44 (0)1228 522321
E-mail: mail@clarkdoor.com • Website: www.clarkdoor.com

Certificate No: 106b to LPS 1271: Issue 2

Appendix 2 - Fire doors and doorsets

Cold Clad Limited

Sarnia House, Green Lane, Newtown Trading Estate, Tewkesbury, Gloucestershire, GL20 8HD, United Kingdom
Tel: 01684 438190
E-mail: info@coldclad.com • Website: www.coldclad.com

Certificate No: 1169PIc to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Ductclean (UK) Limited

1 Woodfield Road, Welwyn Garden City, Hertfordshire, AL7 1JQ, United Kingdom
Tel: 0870 1129196
E-mail: jamie.carraher@dcukfm.com • Website: www.ductclean.co.uk

Certificate No: 1276PI to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Fortis Protect Limited

2 Long Tens Way , Newton Aycliffe, Durhan, DL5 6AP, United Kingdom
Tel: 01206 481199
E-mail: Dylan.Bradley@fortisprotect.co.uk

Certificate No: 1782PI to LPS 1271: Issue 2

Appendices :

- Appendix 2 - Fire doors & doorsets

G & A Fire Protection Ltd

Old Farm Office, 6 Back Street, Buckminster, Grantham, NG33 5RS, United Kingdom
Tel: 01476 500 250
E-mail: buckminster@ga-group.com • Website: www.ga-group.com

Certificate No: 1602PI to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

General Electronic Access Ltd T/A GEA Automation

14 Nordic Enterprise Park , Knockgriffin, Middleton , Cork, Ireland, PS5Y 037, Ireland
Tel: +353214613830
E-mail: r.gill@gea.ie • Website: https://gea.ie/

Certificate No: 1839PI to LPS 1271

Appendices :

- Appendix 2 - Fire doors & doorsets
- Appendix 3 - Fire rated shutters

Golden Thread Fire Delay Ltd

Unit 6 Everik Business Centre, Prospect Way, Hutton, Essex, CM13 1XG, United Kingdom

Tel: 01277 263944

E-mail: info@goldenthreadfiredelay.com • Website: www.goldenthreadfiredelay.com

Certificate No: 1579PIa to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

GSH (South West Consultancy) Ltd

Unit 17 Bridgwater Court, Oldmixon Crescent, Weston Super Mare, BS24 9AY, United Kingdom

Tel: 0333 456 4646

E-mail: info@gshprojects.co.uk • Website: www.gshprojects.co.uk

Certificate No: 1561PI to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Hart Door Systems

Redburn Road, Westerhope Industrial Estate, Westerhope, Newcastle upon Tyne, NE5 1PJ, United Kingdom

Tel: +44 (0)191 214 0404

E-mail: info@hartdoors.com • Website: www.hartdoors.com

Certificate No: 016b to

Approved installer of Firebrand fire rated rolling shutters.

J W Murray Interiors

Unit C 25 Finlas Steet, Glasgow, Scotland, G22 5DU, United Kingdom

Tel: 07792 340908

E-mail: info@jwmurrayinteriors.co.uk

Certificate No: 1801PIa to LPS 1271: Issue 2

Appendices :

- Appendix 2 - Fire doors & doorsets

Jodam Construction Ltd

Unit 11 Building 2 Innovation Way, Wilthorpe, Barnsley, S75 1JL, United Kingdom

Tel: 01226 652066 / 07565205273 / 07500113329

E-mail: A.wake@jodamconstruction.co.uk / J.wake@jodamconstruction.co.uk • Website: jodamconstruction.co.uk

Certificate No: 1679PIa to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Manning Construction Limited

Brodawel, Coychurch, Bridgend, CF35 5BU, United Kingdom

Tel: 01656 862333

E-mail: seuston@manning-online.com • Website: www.manning-online.com

Certificate No: 1141PI to LPS 1271: Issue 2

Appendix 2 - Fire doors and doorsets

Mercian Shutters Limited

Pearsall Drive, Brades Road Industrial Estate, Oldbury, West Midlands, B69 2RA, United Kingdom

Tel: +44 (0)121 544 6124

E-mail: info@merciandoors.co.uk; roger.gear@merciandoors.co.uk • Website: www.merciandoors.co.uk

Certificate No: 355c to LPS 1271: Issue 2

Approved installer of SF series of fire rated rolling shutters.

Neo Property Solutions Limited

Neo Court, Knowsthorpe Lane, Cross Green Industrial Estate, Leeds, West Yorkshire, LS9 0PF, United Kingdom

Tel: 08434554455

Certificate No: 1539PI to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

OMNI Interior Solutions Ltd

Lawmuir Road, Law, ML8 5JB, United Kingdom

Tel: 0845 450 1601

E-mail: rcowan@omni-interiors.co.uk • Website: www.omni-interiors.co.uk/

Certificate No: 1627PI to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

P&P Building and Roofing Contractors Ltd

Unit 12A, , Gilchrist Thomas Ind. Est. , Blaenavon , Pontypool , NP4 9RL , United Kingdom

Tel: 01495 792 278

E-mail: Info@pp-builders.co.uk • Website: www.pp-builders.co.uk/

Certificate No: 1789PIa to LPS 1271: Issue 2

Company assessed and approved for installation of passive fire protection products under the following scope.

Appendices :

- Appendix 2 - Fire doors & doorsets

PB Services (London) Ltd

Brick Lane, Stanmore, HA7 1RE, United Kingdom

Tel: 0208 952 8282

E-mail: peter@pbserviceslondon.com

Certificate No: 1651PI to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Planet Contracting Ltd

Radii Planet House, Edward Way, Burgees Hill, West Sussex, RH15 9TZ, United Kingdom

Tel: 01444 247933

E-mail: info@planetpartitioning.co.uk • Website: www.radiiplanetgroup.com

Certificate No: 1717Pla to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Prestige Fire Door Services trading as Sunray Timber Doors Division

Unit 6 Wotton Trading Estate, Wotton Road, Ashford, Kent, TN23 6LL, United Kingdom

Tel: +44 (0)1233 639039

E-mail: sales@prestigefiredoorservices.com • Website: www.prestigefiredoorservices.com

Certificate No: 1066PI to LPS 1271: Issue 2

Approved Installer of certified fire doors and doorsets

Prospect Fire Ltd

Unit 1 Woodgate's Farm, Woodgate's End, Dunmow, CM6 2BN, United Kingdom

Tel: 01279 354988

E-mail: info@prospectfire.co.uk • Website: www.prospectfire.co.uk

Certificate No: 1631PIb to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

R Lewis & Co. (UK) Ltd

Unit 7 Llandough Trading Estate, Cardiff, CF11 8RR, United Kingdom

Tel: +44 (0) 2920 215716

E-mail: craig.cleveland@rlewisfire.com • Website: www.rlewisandcoukltd.com

Certificate No: 1006Pla to LPS 1271: Issue 2

Company assessed and approved for installation of passive fire protection products under the following scope.

Appendix 2 - Fire Doors & Doorsets

Radii Partitioning Ltd

31 Harbour Exchange Square, Canary Wharf, London, E14 9GE, United Kingdom

Tel: 020 7952 4830

E-mail: info@radiipartitioning.co.uk • Website: www.radiipartitioning.com

Certificate No: 1694PI to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Strategic Fire Protection Ltd

Department , Leeds Dock 4 The Boulevard, Leeds, West Yorkshire, LS10 1PZ, United Kingdom
Tel: 07831 982129
E-mail: andy@strategicfireprotection.co.uk

Certificate No: 1753Pla to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Sunray Engineering Limited

Kingsnorth Industrial Estate, Wotton Road, Ashford, Kent, TN23 6LL, United Kingdom
Tel: +44 (0)1233 639039
E-mail: sales@sunraydoors.co.uk • Website: www.sunraydoors.co.uk

Certificate No: 234e to LPS 1271: Issue 1

Approved Installers of:

Appendices :

- Appendix 1 - Security doors & shutters
 - Appendix 2 - Fire doors & doorsets
-

TEK Interiors Limited

Unit 10A Beehive Business Centre, Beehive Lane, Great Baddow, Chelmsford, Essex, CM2 9TE, United Kingdom
Tel: 01245 250657
E-mail: Neil@tekfiredoorservices.co.uk • Website: www.tekfiredoorservices.co.uk

Certificate No: 1300PIb to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets

Thameside Fire Protection Co. Limited

Unit 4, Sovereign Park, Cranes Farm Road, Basildon, Essex, SS14 3JD, United Kingdom
Tel: +44 (0)1268 597999
E-mail: darko.petrovic@thamesidefire.co.uk • Website: www.thamesidefire.co.uk

Certificate No: 269Pla to LPS 1271: Issue 2

Appendix 2 - Fire doors and doorsets

Total Protection (Fire & Sealing) Solutions Ltd

The Coach House, West Hanningfield Road, Baddow Park, Chelmsford, Essex, CM2 7SY, United Kingdom
Tel: 01277 841415
E-mail: Ross@totalprotection.co.uk • Website: www.totalprotection.co.uk

Certificate No: 1375PIb to LPS 1271: Issue 2

Approved installer of:

- Fire Doors and Doorsets
