
LPCB Red Book



1

Part: 2

Manual fire extinguishing equipment

bre

Introduction

BRE Global Ltd, based in the UK near London, is an independent third party organisation offering certification of fire, security and sustainability products and services to an international market. LPCB is the certification brand used for fire and security products and services. The LPCB mark is accepted worldwide. We have representative offices in China, India and Dubai. We are owned by the BRE Trust, a not-for-profit organisation.

LPCB listings can be accessed, free of charge, at www.redbooklive.com or via apps from Apple, Google and Windows.

BRE Global Ltd is also a Notified Certification Body and Notified Test Laboratory for:-

- Construction Products Regulation
- Pressure Equipment Directive
- Marine Equipment Directive
- Transport Pressure Equipment Directive

BRE Global additionally carries out:

- Fire Investigation
- Fire Risk Assessment
- Fire Safety Engineering
- Research
- Training

LPCB Listings

Listings are given in sections which list related groups of products and services such as suppression, security and so on. Each section also summarises the technical basis for the certification of each product or service. The Red Book listings should always be used in conjunction with rules, regulations and design specifications required by the relevant Authority having jurisdiction.

Listings comprise:

Volume 1: (This Volume)

- **Fire detection and alarm products, systems, and cables**
- **Manual fire extinguishing equipment**
- **Automatic sprinkler, water spray and deluge systems**
- **Fixed fire fighting products and systems**
- **Watermist systems**
- **Related installers**

Volume 2:

- Passive fire protection products
- Security protection products
- Fire doors and shutters
- Smoke and fire ventilation systems
- Security Assessments - SABRE
- Related installers
- Management Systems
- Construction products

Listings are given in the name of the manufacturer or service provider, in alphabetical order. They can be downloaded free of charge from our website at www.redbooklive.com and also via an App that is available free from Apple iStore (for iPhone and iPad), from Google Play, (for Android phones and tablets) and Windows Store (for Windows 8 phones).

Updates

Certification of products and services are updated regularly. To ensure that you are using the most up to date information please refer to www.redbooklive.com or download from the App from the website home page.



What is Third Party Certification?

A frequent concern of stakeholders is in knowing whether a product will perform in accordance with the stated specifications. These concerns can involve such product attributes as safety, health or environmental impacts, durability, compatibility, suitability for intended purposes or for stated conditions, and other similar considerations. These issues can all be addressed through product certification.

Third party certification is a conformity assessment process, carried out by a body that is independent of both supplier and customer organisations. It provides confirmation that products and services have met and will continue to meet the requirements of specified standards and other normative documents.

LPCB third party product certification schemes are quality assurance schemes and comprise initial type testing and technical evaluation, assessment and surveillance of the manufacturer's quality system and factory production procedures, regular audit testing, labelling and listing.

Similarly, LPCB schemes for suppliers of services (installers) are also quality assurance schemes comprising a technical assessment of an installer's capability, assessment and surveillance of the installer's quality system and production procedures, regular inspection of completed installations and listing.

Benefits of Third Party Certification

For specifiers, regulators, insurers, manufacturers and installers, the benefits of an LPCB approval are:

For specifiers and regulators:

- Risk reduction - specifying LPCB approved products and services demonstrates due-diligence and best endeavour and mitigates against possible accusations of negligence.
- Avoidance of costly mistakes - you can trust LPCB approved products and services to conform each and every time.
- Time - using Red Book Live to search for and assess products and services can save you time.

For manufacturers and installers:

- Increased global sales - LPCB approval is recognised and specified widely throughout the world. In some territories LPCB approval is a mandatory requirement.
- Added value of the product or service - LPCB approved products and services are recognised as providing added value given their ability to conform each and every time.
- Reduced liability - LPCB approved products and services demonstrate due-diligence which can reduce liability for both you and your customers.

What does LPCB Certification offer?

LPCB certification is carried out against Loss Prevention Standards (LPS's). These LPS's include reference to BS, EN or ISO standards as appropriate. LPCB certification are level 5 schemes as detailed in ISO/ IEC 17067 with the added requirement to have a quality system certificated to ISO 9001.

VOLUME 1 LIST OF APPROVED PRODUCTS AND SERVICES

The technical requirements of LPCB schemes are given in the Loss Prevention Standards (LPSs). These documents are drafted by LPCB technical experts in conjunction with appropriate external experts. They are then peer reviewed by representatives from trade bodies, regulators, insurers, specifiers, manufacturers and other suppliers. Finally these documents are approved for use by the BRE Global Governing Body; the Body that oversees all of the certification activities of BRE Global.

Product schemes comprise:

- Initial type testing and evaluation of product.
- Approval and surveillance of the manufacturer's (or supplier's) quality management system to ISO 9001
- Assessment and surveillance of the manufacturer's (or supplier) factory production control system (FPC).
- Periodic audit testing of the product from either the factory or marketplace.
- Labelling or marking as appropriate.
- Listing on Red Book Live

Installer schemes comprise:

- Technical assessment of the installation contractor's capability.
- Approval and surveillance of the contractor's quality management system to ISO 9001 or assessment against the requirements of the relevant Loss Prevention Standard where ISO 9001 is not appropriate.
- Regular surveillance inspections of on-going installations.
- The issue of Certificates of Conformity by the installer to demonstrate compliance for each installation.
- Listing in the Red Book.

The LPCB Mark - the Mark you can trust

After certification of a product or service the manufacturer or service provider may place the LPCB certification mark, as shown below, on the product, packaging and literature etc.



Where LPCB holds accreditation through the United Kingdom Accreditation Service (UKAS), the certified company may include the UKAS symbol (the Crown and Tick) alongside the LPCB mark for certain applications e.g. promotional literature or material and stationery, as shown below.



(Full details of LPCB accreditation can be found on the UKAS website at www.ukas.com)

Where for reasons of space or cost the use of the above full mark is not practical, then the following simplified mark may be applied directly to the product (for some schemes only). The LPCB scheme rules define how and where the marks can be used.



CONTENTS

| | |
|---|----------|
| 2 Manual fire extinguishing equipment | 1 |
| SECTION 1 Portable fire extinguishers | 3 |
| SECTION 3 Fire hose reels | 17 |
| SECTION 4 Fire blankets | 46 |
| SECTION 5 Fire hydrant systems | 49 |
| SECTION 5.1 Landing valves | 50 |
| SECTION 5.1.1 Wet landing valves | 51 |
| SECTION 5.1.2 Dry landing valves | 55 |
| SECTION 5.2 Inlet breechings | 56 |
| SECTION 5.3 Semi rigid hoses | 59 |
| SECTION 5.4 Layflat hoses | 61 |
| SECTION 5.5 Boxes for dry riser inlets | 63 |
| SECTION 5.6 Pillar fire hydrants | 64 |
| SECTION 5.7 Gate valves | 68 |
| SECTION 5.8 Fire hose couplings and ancillary equipment | 69 |
| SECTION 6 Mobile fire extinguishers | 71 |
| SECTION 7 Hand-held Branchpipes | 78 |

| | | | |
|---|--|--|--|
| A | | | |
| A1 Fire Fighting | 17 | | |
| Al Tahadi Security And Safety Equipment Trading | 18 | | |
| Ampac Safety Pty Ltd. | 18 | | |
| Angus Fire Ltd. | 18 | | |
| Asiatic Fire System Pte Ltd. | 19 | | |
| Associated Enterprises (S) Pte Ltd. | 4, 72 | | |
| B | | | |
| Beijing Synergy Technology Company, Ltd. | 19 | | |
| BETA Corporation s.r.o | 19 | | |
| BGS nv | 20 | | |
| Bristol Fire Engineering LLC | 20 | | |
| Britannia Fire Ltd. | 5 | | |
| C | | | |
| Ceasefire Industries Pvt. Ltd | 5 | | |
| Changshu Jiangnan Glass Fiber Co., Ltd. | 46 | | |
| COFFCO | 6, 21, 72 | | |
| Crico Engineering | 22 | | |
| D | | | |
| Dafoos Fire Protection Equipment Trading Est. | 22, 51, 56 | | |
| E | | | |
| EMACO GLOBAL LLC | 22 | | |
| Emirates Fire Fighting Equipment Factory L.L.C. (FIREX) | 6, 23, 46, 51, 56, 64 | | |
| EUROFEU | 24, 73 | | |
| Eurotech Fire Protection Ltd, in collaboration with Firetec Systems Ltd | 24 | | |
| Eversafe Extinguisher Sdn Bhd | 24, 47 | | |
| Exon For Fire Protection Inc. | 25, 64 | | |
| F | | | |
| Falck Teknik | 7 | | |
| Fire Fighter CO Security and Safety Equipment Trading LLC | 26 | | |
| Fireguard Safety Equipment Co Ltd | 26 | | |
| Firekill LLP | 7, 73 | | |
| Firemark Ltd. | 8 | | |
| Flamex Fire & Safety Equip | 27 | | |
| Fullblaze Middle East | 8, 27 | | |
| G | | | |
| Global Factory For Production of Fire Fighting Equipment | 28 | | |
| I | | | |
| Intelligent Safety & Security Technology Ltd. | 28 | | |
| J | | | |
| Jactone Products Limited | 9 | | |
| Jewel Saffire Products Ltd | 9 | | |
| Jordan Experts Fire Fighting Equipment Manufacturers (JOFFEX) | 28 | | |
| L | | | |
| Lingjack Engineering Works PTE Ltd | 9, 29, 51, 56, 73 | | |
| M | | | |
| MOBIK S.A. | 30, 52, 57, 68, 69, 78 | | |
| Monsher Fire Protection Systems (P) Ltd. | 31 | | |
| N | | | |
| NAFFCO FZ Co | 10, 31, 47, 52, 57, 59, 61, 63, 64, 74 | | |
| Nasr Awwadeh Factory for Fire Fighting & Safety Equipment | 11, 34, 75 | | |
| National Factory for Security & Safety Equipment LLC | 34, 65 | | |
| Ningbo Jintian Fire Fighting Industrial Co., Ltd. | 34, 52, 57, 68, 70, 79 | | |
| Ningbo Siterwell Electronics Co., Ltd. | 47 | | |
| NOHA Norway AS | 35 | | |
| NORD PROTECTION SARL | 35 | | |
| P | | | |
| Power Saints Ltd. | 36 | | |
| Q | | | |
| Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO | 11, 36, 48, 53, 58, 59, 61, 65, 75 | | |
| R | | | |
| Rapidrop Global Limited | 37 | | |
| Ras Al Khaimah Fire Fighting Equipment Factory Fire King L.L.C | 12, 37, 75 | | |
| Resil Commercial Industrial Ltda | 12 | | |
| S | | | |
| Sanal Srl | 38 | | |
| Saudi Factory for Fire Equipment Co. | 13 | | |
| Saudi Factory for Fire Equipment FZCO | 66 | | |
| Sentura Group (including FireDepot) | 13, 38, 76 | | |
| Shanghai Firetech Co. Ltd. | 53, 58 | | |
| Shanghai Huiying Industry Co Ltd | 38 | | |
| Shanghai Iron Man Fire Fighting Equipment Co., Ltd. | 39 | | |
| Shaoxing Hongrun Fire Control Equipment Co., Ltd. | 59 | | |
| Shaoxing Jia Sheng Fire Fighting Equipment Co. Limited | 54, 58 | | |
| Somati FIE NV | 40 | | |
| Suzhou HLC Plastics Industry Co. Ltd | 40, 60 | | |
| T | | | |
| The Viking Corporation | 66 | | |
| U | | | |
| UNIFIRE MIDDLE EAST FZC | 41 | | |
| Unisafe Fire Protection Specialists LLC | 14, 42, 76 | | |
| V | | | |
| VALMECA MAROC S.A.R.L. | 42 | | |
| W | | | |
| Watania For Advanced Systems | 42 | | |
| Watania For Modern Industries | 43 | | |
| Watex Pumps Industries | 43 | | |
| Y | | | |
| Yuyao Tianbo Fire Fighting Equipment Co., Ltd. | 14, 43, 76 | | |
| Yuyao Tianning Fire Control Equipment Co., Ltd. | 44, 60 | | |
| Z | | | |
| Zener Security & Safety Equipments | 44 | | |
| Zhejiang Flametech Industries Co Limited | 67 | | |
| Zhejiang Orientx Fire Safety Equipment Co., Ltd. | 15 | | |
| Zhejiang Ruihua Machinery Co. Ltd | 16, 77 | | |

Part

2

MANUAL FIRE EXTINGUISHING EQUIPMENT

PART 2: MANUAL FIRE EXTINGUISHING EQUIPMENT

INTRODUCTION

Listings in this section include:

Products

- Portable fire extinguishers
- Hose reels
- Blankets
- Hydrant systems
- Wet landing valves
- Dry landing valves
- Inlet breechings
- Semi rigid hoses
- Lay flat hoses
- Boxes for dry riser inlets
- Pillar fire hydrants
- Mobile fire extinguishers

Products are approved in accordance with various standards. The details of these standards are given at the front of each section relevant to the product.

Contractors

- Portable fire extinguisher service and maintenance contractors

Contractors are approved in accordance with BS 5306. Further details are given in section 2.

Portable fire extinguishers are manufactured to suit different types of fires and should be selected, sited, serviced and maintained in accordance with the relevant code of practice. Third party approval of the portable fire extinguisher will help to ensure that they will function correctly if properly maintained, it will also demonstrate due diligence in supporting risk assessed based legislation.

LPCB approval helps to ensure that fire extinguishers meet and continue to meet appropriate standards. LPCB approval includes testing of the individual component parts of the fire extinguisher, pressure safety of the vessel, correct labelling and operation instructions and the satisfactory performance of the extinguisher when tested to the relevant fire test. These elements are continuously monitored during regular factory production control (fpc) surveillance audits.

CE marking may be found on a portable fire extinguisher as required by the European Union - Pressure Equipment Directive (PED) but should not be confused with LPCB approval. This directive has been published for products that are to be sold within the European Union (EU) and it requires proof of safety of the pressure vessel. The CE mark placed on a fire extinguisher demonstrates conformance with this pressure safety requirement and fire testing is not carried out as part of this directive.

Caution: To be sure of reliable, proven, performance of the fire extinguisher in fire conditions, the extinguisher should carry independent proof of performance, such as the LPCB mark, and if it is to be supplied into the EU the additional CE mark will also be required as defined by the PED.

Generally the test standards used by the LPCB for certification of portable fire extinguishers are:

| |
|---|
| EN 3 - Part 7 + A1:2007 - <i>Characteristics, performance requirements and test methods</i> |
| EN 3 - Part 8 - <i>Additional requirements to EN 3-7 for the construction, resistance to pressure and mechanical tests for extinguishers with a maximum allowable pressure equal to or lower than 30 bar</i> |
| EN 3 - Part 9 - <i>Additional requirements to EN 3-7 for pressure resistance of CO₂ extinguishers</i> |
| EN 3 - Part 10 - <i>Provisions for evaluating the conformity of a portable fire extinguisher to EN 3-7</i> |
| BS 7867 - <i>Specification for portable fire extinguishers for use in aircraft</i> |
| BS 6165 : <i>Specification for small disposable fire extinguishers of the aerosol type</i> |

Notes re changes to standards:

EN 3 Parts 1, 2, 4 and 5 were replaced by the publication of EN 3 - 7:2004 + A1:2007. - *Characteristics, performance requirements and test methods.*
 EN 3 Part 3 was replaced by publication of EN 3 Parts 8 and 9.
 EN 3 Part 6 was replaced by publication of EN 3 Part 10
 BS 7937 - Specification for portable fire extinguishers for use on cooking oil fires (class F) was replaced by publication of EN 3-7:2004 + A1:2007.

Abbreviations used for LPCB listing of portable fire extinguishers

LPCB use the following abbreviations in the Red Book listings for portable fire extinguishers.

| | |
|--------------------------------|--|
| Extinguishing Agent | |
| W - Water | WB - Water based (water plus additive) |
| ABC or BC - Dry Powder | CO ₂ - Carbon Dioxide |
| CA - Clean Agent | WC - Wet Chemical |
| Method of Actuation | |
| SP - Stored pressure actuation | GC - Gas cartridge actuation |
| Units or "Capacity" | |
| kg - kilogram | l - litre |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

Labelling

A requirement of EN 3 is that each portable fire extinguisher must be clearly labelled to identify the classes of fire for which they have demonstrated satisfactory performance as defined in EN 3. In summary:

| | |
|------------------|--|
| Class A : | for use on flammable solid materials, for example wood, paper, coal, straw, cloth etc. |
| Class B : | for use on fires involving flammable liquids or liquefiable solids. |
| Class C : | for fires involving gases. |
| Class D : | for fires involving metals for example magnesium, sodium, cadmium, manganese. |
| Class F : | for use on cooking oil fires. |

Colour Coding

EN 3-Part 7 permits a zone of colour of up to 10% of the external area of the extinguisher body to be used to identify the extinguishing agent in accordance with national specifications.

Colour coding of portable fire extinguishers is not mandatory in the UK, however BS 7863: *Recommendations for Colour coding to indicate the extinguishing medium contained in portable fire extinguishers*, was published to provide a consistent approach where colour coding is used.

CE MARKING

As described earlier CE Marking should be affixed to portable fire extinguishers under the Pressure Equipment Directive (PED). The CE Mark (in this instance) indicates that the fire extinguisher meets certain pressure safety requirements and has been assessed by a Notified Body (such as LPCB). Please see cautionary information at the start of this section.

Marine Equipment Directive

The Marine Equipment Directive (MED) was adopted into UK Law and became mandatory on the 5 August 1999. The MED covers any ship (or lifeboat) flying a flag of an EEA member state. The MED covers a vast array of equipment, covering all aspects of a ship's safety, including portable fire extinguishers. Conformity assessment is through a Notified Body, such as LPCB, and the compliance mark is the Wheel-mark.

Associated Enterprises (S) Pte Ltd.

Block 28, Sin Ming Drive, #01-173 575702, Singapore

Tel: +65-64550555 • Fax: +65-64550505

E-mail: enquiry@aespl.com.sg • Website: www.aespl.com.sg

Certificate No: 1092Aa to EN3 Parts 7,8 and 9

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-------------------|----------|--------------|---------------|
| PRO-2-CD-AL | CO ₂ | 2 kg | 34B | 1092Aa/30 |
| PRO-2-CD | CO ₂ | 2 kg | 34B | 1092Aa/31 |
| PRO-5-CD-AL | CO ₂ | 5 kg | 70B | 1092Aa/32 |
| PRO-5-CD | CO ₂ | 5 kg | 70B | 1092Aa/33 |
| PRO-2-FOAM | Foam (SP) | 2 litre | 8A/55B | 1092Aa/14 |
| PRO-6-FOAM | Foam (SP) | 6 litre | 21A/144B | 1092Aa/17 |
| PRO-9-FOAM | Foam (SP) | 9 litre | 27A/233B | 1092Aa/19 |
| PRO-1-DC | ABC Powder (SP) | 1 kg | 8A/34B | 1092Aa/01 |
| PRO-2-DC | ABC Powder (SP) | 2 kg | 13A/89B | 1092Aa/05 |
| PRO-3-DC | ABC Powder (SP) | 3 kg | 21A/113B | 1093Aa/07 |
| PRO-4-DC | ABC Powder (SP) | 4 kg | 27A/144B | 1092Aa/08 |
| PRO-6-DC | ABC Powder (SP) | 6 kg | 43A/233B | 1092Aa/09 |
| PRO-9-DC | ABC Powder (SP) | 9 kg | 55A/233B | 1092Aa/11 |
| PRO-12-DC | ABC Powder (SP) | 12 kg | 55A/233B | 1092Aa/12 |
| PRO-6-W | Water (SP) | 6 litre | 13A | 1092Aa/24 |
| PRO-9-W | Water (SP) | 9 litre | 21A | 1092Aa/25 |
| PRO-2-WC | Wet Chemical (SP) | 2 litre | 8A/34B/25F | 1092Aa/21 |
| PRO-3-WC | Wet Chemical (SP) | 3 litre | 13A/70B/40F | 1092Aa/22 |
| PRO-6-WC | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 1092Aa/23 |

Britannia Fire Ltd.

Ashwellthorpe Industrial Estate, Ashwellthorpe, Norwich, Norfolk NR16 1ER, United Kingdom
Tel: +44 (0)1508 488416 • Fax: +44 (0)1508 481753
E-mail: sales@britannia-fire.co.uk • Website: www.britannia-fire.co.uk

Certificate No: 1193a to EN3 part 7

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| P50F | Foam (SP) | 6 litre | 27A/183B | 1193a/01 |
| P50P | ABC Powder (SP) | 6 kg | 34A/183B | 1193a/02 |

Ceasefire Industries Pvt. Ltd

2nd Floor, Plot No. 4, Sector-135, Noida, Uttar Pradesh 201301, India
Tel: +91 120 4255800 • Fax: +91 120 4255801
E-mail: amit@ceasefire.in • Website: www.ceasefire.in

Certificate No: 1329b to EN 3-7:2004+A1:2007, EN 3-8:2006 & EN 3-9:2006

'CEASEFIRE' Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|--------------------|----------|------------------|---------------|
| CF-000700 | CO ₂ | 2 kg | 34B | 1329b/32 |
| CF-000702 | CO ₂ | 2 kg | 34B | 1329b/33 |
| CF-000701 | CO ₂ | 5 kg | 70B | 1329b/34 |
| CF-000703 | CO ₂ | 5 kg | 70B | 1329b/35 |
| CF-000705 | Clean Agent (SP) | 2 kg | 21B | 1329b/36 |
| CF-000849 | Clean Agent (SP) | 2 kg | 21B | 1329b/37 |
| CF-000706 | Clean Agent (SP) | 4 kg | 34B | 1329b/07 |
| CF-000850 | Clean Agent (SP) | 4 kg | 21B | 1329b/38 |
| CF-000707 | Clean Agent (SP) | 6 kg | 34B | 1329b/08 |
| CF-000851 | Clean Agent (SP) | 6 kg | 34B | 1329b/39 |
| CF-000708 | Clean Agent (SP) | 9 kg | 55B | 1329b/40 |
| CF-000852 | Clean Agent (SP) | 9 kg | 55B | 1329b/41 |
| CF-000779 | Foam (SP) | 3 litre | 8A / 89B | 1329b/09 |
| CF-000805 | Foam (SP) | 3 litre | 8A / 89B | 1329b/10 |
| CF-000715 | Foam (SP) | 6 litre | 13A / 144B | 1329b/11 |
| CF-000806 | Foam (SP) | 6 litre | 13A / 144B | 1329b/12 |
| CF-000716 | Foam (SP) | 9 litre | 21A / 233B | 1329b/13 |
| CF-000807 | Foam (SP) | 9 litre | 21A / 233B | 1329b/14 |
| CF-000838 | Foam Mist (SP) | 2 litre | 5A / 34B / 25F | 1329b/15 |
| CF-000696 | Foam Mist (SP) | 2 litre | 5A / 55B / 25F | 1329b/16 |
| CF-000839 | Foam Mist (SP) | 6 litre | 13A / 113B / 40F | 1329b/17 |
| CF-000698 | Foam Mist (SP) | 6 litre | 13A / 144B / 40F | 1329b/18 |
| CF-000730 | ABC 50 Powder (SP) | 1 kg | 5A / 34B | 1329b/42 |
| CF-000803 | ABC 50 Powder (SP) | 1 kg | 5A / 34B | 1329b/43 |
| CF-000731 | ABC 50 Powder (SP) | 2 kg | 8A / 70B | 1329b/44 |
| CF-000804 | ABC 50 Powder (SP) | 2 kg | 8A / 70B | 1329b/45 |
| CF-000732 | ABC 50 Powder (SP) | 4 kg | 21A / 144B | 1329b/19 |
| CF-000733 | ABC 50 Powder (SP) | 6 kg | 27A / 183B | 1329b/20 |
| CF-000734 | ABC 50 Powder (SP) | 9 kg | 43A / 233B | 1329b/21 |
| CF-000721 | ABC 90 Powder (SP) | 1 kg | 5A / 21B | 1329b/46 |
| CF-000722 | ABC 90 Powder (SP) | 2 kg | 13A / 55B | 1329b/01 |
| CF-000723 | ABC 90 Powder (SP) | 4 kg | 21A / 144B | 1329b/02 |
| CF-000724 | ABC 90 Powder (SP) | 6 kg | 27A / 183B | 1329b/03 |
| CF-000725 | ABC 90 Powder (SP) | 9 kg | 43A / 233B | 1329b/04 |
| CF-000736 | BC Powder (SP) | 2 kg | 89B | 1329b/47 |
| CF-000737 | BC Powder (SP) | 4 kg | 233B | 1329b/05 |
| CF-000738 | BC Powder (SP) | 6 kg | 233B | 1329b/06 |
| CF-000739 | BC Powder (SP) | 9 kg | 233B | 1329b/48 |
| CF-000717 | Water (SP) | 6 litre | 13A | 1329b/22 |
| CF-000798 | Water (SP) | 6 litre | 13A | 1329b/23 |
| CF-000718 | Water (SP) | 9 litre | 21A | 1329b/24 |
| CF-000709 | Water Mist (SP) | 2 litre | 5A / 25F | 1329b/25 |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|-------------------|-----------------|--------------------|----------------------|
| CF-000710 | Water Mist (SP) | 3 litre | 8A / 25F | 1329b/26 |
| CF-000711 | Water Mist (SP) | 6 litre | 13A / 75F | 1329b/27 |
| CF-000712 | Water Mist (SP) | 9 litre | 21A / 75F | 1329b/28 |
| CF-000780 | Wet Chemical (SP) | 3 litre | 8A / 40F | 1329b/29 |
| CF-000800 | Wet Chemical (SP) | 3 litre | 8A / 40F | 1329b/49 |
| CF-000719 | Wet Chemical (SP) | 6 litre | 13A / 75F | 1329b/30 |
| CF-000801 | Wet Chemical (SP) | 6 litre | 13A / 75F | 1329b/50 |
| CF-000720 | Wet Chemical (SP) | 9 litre | 21A / 75F | 1329b/31 |
| CF-000802 | Wet Chemical (SP) | 9 litre | 21A / 75F | 1329b/51 |

COFFCO

PO Box 5, Pincode - 678002, India

Tel: +914912908940 • Fax: +914912554695

E-mail: coffco@eth.net • Website: www.coffcofire.com

Certificate No: 1092Ha to EN 3 parts 7, 8 & 9

COFFCO Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|---------------------|-----------------|--------------------|----------------------|
| CFCOA2 | CO ₂ | 2 kg | 34B | 1092Ha/30 |
| CFCO2 | CO ₂ | 2 kg | 34B | 1092Ha/31 |
| CFCOA5 | CO ₂ | 5 kg | 70B | 1092Ha/32 |
| CFCO5 | CO ₂ | 5 kg | 70B | 1092Ha/33 |
| CFF2 | Foam (SP) | 2 litre | 8A/55B | 1092Ha/14 |
| CFF3 | Foam (SP) | 3 litre | 13A/89B | 1092Ha/16 |
| CFF6 | Foam (SP) | 6 litre | 21A/144B | 1092Ha/17 |
| CFFR6 | Foam (SP) | 6 litre | 27A/183B | 1092Ha/18 |
| CFF9 | Foam (SP) | 9 litre | 27A/233B | 1092Ha/19 |
| CFDPE1 | ABC Powder (SP) | 1 kg | 8A/34B | 1092Ha/01 |
| CFDPA1 | ABC Powder (SP) | 1 kg | 8A/34B | 1092Ha/02 |
| CFDPD1 | ABC Powder (SP) | 1 kg | 8A/34B | 1092Ha/03 |
| CFDP1 | ABC Powder (SP) | 1 kg | 8A/55B | 1092Ha/04 |
| CFDP2 | ABC Powder (SP) | 2 kg | 13A/89B | 1092Ha/05 |
| CFDP3 | ABC Powder (SP) | 3 kg | 21A/113B | 1092Ha/07 |
| CFDP4 | ABC Powder (SP) | 4 kg | 27A/144B | 1092Ha/08 |
| CFDP6 | ABC Powder (SP) | 6 kg | 43A/233B | 1092Ha/09 |
| CFDPRS6 | ABC Powder (SP) | 6 kg | 55A/233B | 1092Ha/10 |
| CFDP9 | ABC Powder (SP) | 9 kg | 55A/233B | 1092Ha/11 |
| CFDPD12 | ABC Powder (SP) | 12 kg | 55A/233B | 1092Ha/12 |
| CFW6 | Water (SP) | 6 litre | 13A | 1092Ha/24 |
| CFW9 | Water (SP) | 9 litre | 21A | 1092Ha/25 |
| CFWA3 | Water Additive (SP) | 3 litre | 13A | 1092Ha/28 |
| CFWA6 | Water Additive (SP) | 6 litre | 27A | 1092Ha/29 |
| CFWC2 | Wet Chemical (SP) | 2 litre | 8A/34B/25F | 1092Ha/21 |
| CFWC3 | Wet Chemical (SP) | 3 litre | 13A/70B/40F | 1092Ha/22 |
| CFWC6 | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 1092Ha/23 |

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300 • Fax: +971 6 5340090

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 867Ba to EN3 Parts 7, 8 and 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|---------------------|-----------------|-----------------|--------------------|----------------------|
| FCD2 | CO ₂ | 2 kg | 34B | 867Ba/10 |
| FCD5 | CO ₂ | 5 kg | 89B | 867Ba/11 |
| FF6L | Foam (SP) | 6 litre | 21A / 183B | 867Ba/12 |
| F6EP | Foam (SP) | 6 litre | 34A / 183B | 867Ba/20 |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|---------------------|----------|------------------|---------------|
| FF9L | Foam (SP) | 9 litre | 27A/233B | 867Ba/13 |
| FDP1 | ABC Powder (SP) | 1 kg | 8A/55B | 867Ba/04 |
| FDP2 | ABC Powder (SP) | 2 kg | 13A/89B | 867Ba/01 |
| FF2P | ABC Powder (SP) | 2 kg | 13A / 89B | 867Ba/15 |
| FDP3 | ABC Powder (SP) | 3 kg | 21A/144B | 867Ba/05 |
| FDP4 | ABC Powder (SP) | 4 kg | 27A/233B | 867Ba/07 |
| FDP6 | ABC Powder (SP) | 6 kg | 43A/233B | 867Ba/02 |
| FDP9 | ABC Powder (SP) | 9 kg | 55A/233B | 867Ba/08 |
| FDP12 | ABC Powder (SP) | 12 kg | 55A/233B | 867Ba/03 |
| FW6L | Water (SP) | 6 litre | 13A | 867Ba/17 |
| FW9L | Water (SP) | 9 litre | 21A | 867Ba/09 |
| FW6LP | Water Additive (SP) | 6 litre | 21A | 867Ba/19 |
| WC6L | Wet Chemical (SP) | 6 litre | 21A / 113B / 75F | 867Ba/16 |

Notes:

The above products are placed on the market under the following brand names: Aquaplus, Fire Bell, Fire Bird, Fire Tech, First, Guard, Joffco, Omega, Power, SOS International, Torando, Tri Star, Firex, Firex 1, Best, Safety First, Recomp, Unix- UAE.

Falck Teknik

Meterbuen 14-16, Skovlunde 2740, Denmark

Tel: +45 44576175 • Fax: +45 44848998

E-mail: bokn@falck.dk • Website: www.falckteknik.dk

Certificate No: 867Ea to EN3 Parts 7, 8 and 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-----------------|----------|--------------|---------------|
| 2557 | CO ₂ | 2 kg | 34B | 867Ea/10 |
| 2558 | CO ₂ | 5 kg | 89B | 867Ea/11 |
| 2593 | Foam (SP) | 6 litre | 21A/183B | 867Ea/12 |
| 2594 | Foam (SP) | 9 litre | 27A/233B | 867Ea/13 |
| 2600 | ABC Powder (SP) | 1 kg | 8A/55B | 867Ea/04 |
| 2581 | ABC Powder (SP) | 2 kg | 13A/89B | 867Ea/01 |
| 2583 | ABC Powder (SP) | 6 kg | 43A/233B | 867Ea/02 |
| 2585 | ABC Powder (SP) | 12 kg | 55A/233B | 867Ea/03 |
| 2601 | Water (SP) | 6 litre | 13A | 867Ea/17 |
| 2539 | Water (SP) | 9 litre | 21A | 867Ea/09 |
| 2575 | Wet Chem (SP) | 6 litre | 21A/113B/75F | 867Ea/16 |

Firekill LLP

14 Hanover Street, London W1S 1YH, United Kingdom

Tel: +44 (0)207 3170 663 • Fax: +44 (0)207 3170 610

E-mail: firekill@firekill.uk.com • Website: www.firekill.uk.com

Certificate No: 867Ha to EN3 Parts 7,8 and 9

FireKill Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| FK-C-5 | CO ₂ | 5 kg | 89B | 867Ha/11 |
| FK-P-6 | ABC Powder (SP) | 6 kg | 43A/233B | 867Ha/02 |
| FK-P-9 | ABC Powder (SP) | 9 kg | 55A/233B | 867Ha/08 |
| FK-W-9 | Water (SP) | 9 litre | 21A | 867Ha/09 |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

Firemark Ltd.

BFF Business Park, Bath Road, Bridgwater, Somerset TA6 4NZ, United Kingdom

Tel: +44 (0)1278 727460

E-mail: sales@firemark-ltd.co.uk • Website: www.firemark-ltd.co.uk

Certificate No: 867Ca to EN 3 Parts 7, 8 and 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|---------------------|---------------------|-----------------|--------------------|----------------------|
| C2/1S | CO ₂ | 2 kg | 34B | 867Ca/10 |
| C5/1S | CO ₂ | 5 kg | 89B | 867Ca/11 |
| F2/1 | Foam (SP) | 2 litre | 8A / 55B | 867Ca/21 |
| F6/1 | Foam (SP) | 6 litre | 21A/183B | 867Ca/12 |
| F6/2 | Foam (SP) | 6 litre | 34A / 183B | 867Ca/20 |
| F9/1 | Foam (SP) | 9 litre | 27A/233B | 867Ca/13 |
| P1/1 | ABC Powder (SP) | 1 kg | 8A/55B | 867Ca/04 |
| P2/1 | ABC Powder (SP) | 2 kg | 13A/89B | 867Ca/01 |
| P4/1 | ABC Powder (SP) | 4 kg | 27A/233B | 867Ca/07 |
| P6/1 | ABC Powder (SP) | 6 kg | 43A/233B | 867Ca/02 |
| P9/1 | ABC Powder (SP) | 9 kg | 55A/233B | 867Ca/08 |
| W6/1 | Water (SP) | 6 litre | 13A | 867Ca/17 |
| W9/1 | Water (SP) | 9 litre | 21A | 867Ca/09 |
| WA6/2 | Water Additive (SP) | 6 litre | 21A | 867Ca/19 |
| WC6/1 | Wet Chemical (SP) | 6 litre | 21A/ 113B/ 75F | 867Ca/16 |

Fullblaze Middle East

Zarqa Free Zone, New Expansionist Area, P.O.Box 922054, Amman 11192, Jordan

Tel: +962 6 489 3373 • Fax: +962 6 489 3372

E-mail: info@fullblaze-me.com • Website: www.fullblaze-me.com

Certificate No: 1092Ea to EN 3 parts 7, 8 & 9

Fullblaze Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|-------------------|-----------------|--------------------|----------------------|
| FBCD2 | CO ₂ | 2 kg | 34B | 1092Ea/31 |
| FBCD5 | CO ₂ | 5 kg | 70B | 1092Ea/33 |
| FBFM3S | Foam (SP) | 3 litre | 13A/89B | 1092Ea/16 |
| FBFM6S | Foam (SP) | 6 litre | 21A/144B | 1092Ea/17 |
| FBFM9S | Foam (SP) | 9 litre | 27A/233B | 1092Ea/19 |
| FBPD1E | ABC Powder (SP) | 1 kg | 8A/34B | 1092Ea/01 |
| FBPD2S | ABC Powder (SP) | 2 kg | 13A/89B | 1092Ea/05 |
| FBPD3S | ABC Powder (SP) | 3 kg | 21A/113B | 1092Ea/07 |
| FBPD4S | ABC Powder (SP) | 4 kg | 27A/144B | 1092Ea/08 |
| FBPD6S | ABC Powder (SP) | 6 kg | 43A/233B | 1092Ea/09 |
| FBPD9S | ABC Powder (SP) | 9 kg | 55A/233B | 1092Ea/11 |
| FBPD12 | ABC Powder (SP) | 12 kg | 55A/233B | 1092Ea/12 |
| FBWT6 | Water (SP) | 6 litre | 13A | 1092Ea/24 |
| FBWT9 | Water (SP) | 9 litre | 21A | 1092Ea/25 |
| FBWC3 | Wet Chemical (SP) | 3 litre | 13A/70B/40F | 1092Ea/22 |
| FBWC6 | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 1092Ea/23 |

Jactone Products Limited

Springvale Business Park, Springvale Avenue, Bilston, West Midlands WV14 0QL, United Kingdom
Tel: +44 (0)1902 357777 • Fax: +44 (0)1902 357711
E-mail: sales@jactone.com • Website: www.jactone.com

Certificate No: 783b to BS EN 3 Part 7

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| EFS6 PLUS | Foam (SP) | 6 litre | 34A/183B | 783b/01 |
| EC2 | CO ₂ | 2 kg | 34B | 783b/02 |
| EC2F | CO ₂ | 2 kg | 55B | 783b/03 |
| EC5 | CO ₂ | 5 kg | 70B | 783b/04 |

Certificate No: 783a to BS EN 3 Parts 7 & 8

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|--------------|----------|-------------|---------------|
| EWCS3 | F Class (SP) | 3 litre | 8A/25F | 783a/01 |
| EWCS6 | F Class (SP) | 6 litre | 13A/75F | 783a/02 |

Jewel Sapphire Products Ltd

Denby Way, Hellaby Industrial Estate, Rotherham S66 8HR, United Kingdom
Tel: 0845 33065406 • Fax: 0845 3305 5407
E-mail: sales@jewelsapphire.co.uk • Website: http://www.jewelsapphire.co.uk

Certificate No: 1094b to Technical Approval based upon BS EN 3 Part 7

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|------------|----------|-------------|---------------|
| ESYS1L2LCEX | Water Mist | 1 litre | 5F | 1094b/01 |

1 litre is not one of the specified nominal charges specified in EN3-7 clause 6.1 Nominal Charges

Certificate No: 1094a to BS EN 3 Part 7

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|------------|----------|-------------|---------------|
| ESYS3L6LCEX | Water mist | 3 litre | 8A/25F | 1094a/01 |
| ESYS6L9LCEX | Water mist | 6 litre | 13A/75F | 1094a/02 |

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building 738471, Singapore
Tel: +65 6759 4163 • Fax: +65 6758 7513
E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501a to EN 3 Parts 7,8 and 9

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|----------------|----------|-------------|---------------|
| C-2CSEC (1) | Carbon dioxide | 2 kg | 34B | 501a/14 |
| C-5CSEC (1) | Carbon dioxide | 5 kg | 55B | 501a/15 |
| C-6FSE (1) | Foam | 6 litre | 8A/113B | 501a/07 |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|---------------------|----------|-------------|---------------|
| C-9FSE (1) | Foam | 9 litre | 13A/233B | 501a/08 |
| C-9FCE (1) | Foam (GC) | 9 litre | 34A/233B | 501a/11 |
| C-1ASE (1) | ABC Powder (SP) | 1kg | 5A/55B | 501a/01 |
| C-2ASE (1) | ABC Powder (SP) | 2kg | 13A/55B | 501a/02 |
| C-3ASE (1) | ABC Powder (SP) | 3kg | 13A/55B | 501a/03 |
| C-4ASE (1) | ABC Powder (SP) | 4kg | 21A/144B | 501a/04 |
| C-6ASE (1) | ABC Powder (SP) | 6kg | 34A/233B | 501a/05 |
| C-9ASE (1) | ABC Powder (SP) | 9kg | 43A/233B | 501a/06 |
| C-6ACE (1) | ABC Powder (GC) | 6 kg | 27A/233B | 501a/16 |
| C-9ACE (1) | ABC Powder (GC) | 9 kg | 43A/233B | 501a/17 |
| C-12ACE (1) | ABC Powder (GC) | 12 kg | 55A/233B | 501a/18 |
| C-6WSE (1) | Water (SP) | 6 litre | 8A | 501a/09 |
| C-9WSE (1) | Water (SP) | 9 litre | 13A | 501a/10 |
| C-9WSEA (1) | Water additive (SP) | 9 litre | 21A | 501a/12 |
| C-9WCEA (1) | Water additive (GC) | 9 litre | 21A | 501a/13 |
| Q-2CSEC (2) | Carbon dioxide | 2 kg | 34B | 501a/14 |
| Q-5CSEC (2) | Carbon dioxide | 5 kg | 55B | 501a/15 |
| Q-6SF (2) | Foam | 6 litre | 8A/113B | 501a/07 |
| Q-9SF (2) | Foam | 9 litre | 13A/183B | 501a/08 |
| Q-9CF (2) | Foam (GC) | 9 litre | 34A/233B | 501a/11 |
| Q-1SP (2) | ABC Powder (SP) | 1 kg | 5A/55B | 501a/01 |
| Q-2SP (2) | ABC Powder (SP) | 2 kg | 13A/55B | 501a/02 |
| Q-3SP (2) | ABC Powder (SP) | 3 kg | 13A/55B | 501a/03 |
| Q-4SP (2) | ABC Powder (SP) | 4 kg | 21A/144B | 501a/04 |
| Q-6SP (2) | ABC Powder (SP) | 6 kg | 34A/233B | 501a/05 |
| Q-9SP (2) | ABC Powder (SP) | 9 kg | 43A/233B | 501a/06 |
| Q-6CP (2) | ABC Powder (GC) | 6 kg | 27A/233B | 501a/16 |
| Q-9CP (2) | ABC Powder (GC) | 9 kg | 43A/233B | 501a/17 |
| Q-12CP (2) | ABC Powder (GC) | 12 kg | 55A/233B | 501a/18 |
| Q-6SW (2) | Water (SP) | 6 litre | 8A | 501a/09 |
| Q-9SW (2) | Water (SP) | 9 litre | 13A | 501a/10 |
| Q-9WSEA (2) | Water additive (SP) | 9 litre | 21A | 501a/12 |
| Q-9WCEA (2) | Water additive (GC) | 9 litre | 21A | 501a/13 |

Notes:

- 1) Brand name of extinguisher is "Combat"
- 2) Brand name of extinguisher is "Q-Fire"

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates
 Tel: +971 4815111 • Fax: +971 48151222
 E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463a to EN 3: Parts 7, 8 & 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|---------------------|----------|--------------|---------------|
| NHFC4 | Clean Agent (SP) | 4 kg | 34B | 463a/33 |
| NHFC6 | Clean Agent (SP) | 6 kg | 5A/55B | 463a/34 |
| NHFC9 | Clean Agent (SP) | 9 kg | 8A/70B | 463a/35 |
| NHFC12 | Clean Agent (SP) | 12 kg | 13A/70B | 463a/36 |
| NC2 | CO ₂ | 2 kg | 34B | 463a/01 |
| NCS2 | CO ₂ | 2 kg | 34B | 463a/06 |
| NCZ2 | CO ₂ | 2 kg | 55B | 463a/07 |
| NC5 | CO ₂ | 5 kg | 55B | 463a/02 |
| NC5X | CO ₂ | 5 kg | 70B | 463a/15 |
| NCA5X | CO ₂ | 5 kg | 70B | 463a/16 |
| NF 2EB | Eco Barid Foam (SP) | 2 litre | 8A/89B/5F | 463a/39 |
| NF 3EB | Eco Barid Foam (SP) | 3 litre | 8A/113B/25F | 463a/40 |
| NF 6EB | Eco Barid Foam (SP) | 6 litre | 21A/183B/40F | 463a/41 |
| NF 9EB | Eco Barid Foam (SP) | 9 litre | 27A/183B/40F | 463a/42 |
| NF3 | Foam (SP) | 3 litre | 8A/70B | 463a/17 |
| NF3X | Foam (SP) | 3 litre | 8A/70B | 463a/18 |
| NF6 | Foam (SP) | 6 litre | 21A/144B | 463a/08 |
| NF6X | Foam (SP) | 6 litre | 27A/144B | 463a/19 |
| NF9 | Foam (SP) | 9 litre | 21A/183B | 463a/09 |
| NF9X | Foam (SP) | 9 litre | 27A/233B | 463a/20 |

PART 2: SECTION 1
PORTABLE FIRE EXTINGUISHERS

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| NFA9 | Foam (SP) | 9 litre | 21A/183B | 463a/21 |
| NFC6X | Foam (GC) | 6 litre | 27A/144B | 463a/26 |
| NFC9X | Foam (GC) | 9 litre | 34A/233B | 463a/27 |
| NP1 | ABC Powder (SP) | 1 kg | 8A/34B | 463a/05 |
| NP2 | ABC Powder (SP) | 2 kg | 13A/89B | 463a/37 |
| NP3 | ABC Powder (SP) | 3 kg | 21A/89B | 463a/28 |
| NP4 | ABC Powder (SP) | 4 kg | 21A/113B | 463a/10 |
| NP6 | ABC Powder (SP) | 6 kg | 43A/233B | 463a/38 |
| NP9 | ABC Powder (SP) | 9 kg | 43A/233B | 463a/03 |
| NP12 | ABC Powder (SP) | 12 kg | 55A/233B | 463a/04 |
| NW6 | Water (SP) | 6 litre | 13A | 463a/11 |
| NW6X | Water (SP) | 6 litre | 13A | 463a/22 |
| NW9 | Water (SP) | 9 litre | 21A | 463a/12 |
| NW9X | Water (SP) | 9 litre | 21A | 463a/23 |
| NWC6X | Water (SP) | 6 litre | 13A | 463a/29 |
| NWC9X | Water (SP) | 9 litre | 21A | 463a/30 |
| NWA9 | Water (SP) | 9 litre | 21A | 463a/24 |
| NWN6 | Water (SP) | 6 litre | 13A | 463a/13 |
| NWN9 | Water (SP) | 9 litre | 13A | 463a/14 |
| NKE2 | Wet Chemical | 2 litre | 5F | 463a/31 |
| NKE3X | Wet Chemical | 3 litre | 8A/25F | 463a/32 |
| NKE6 | Wet Chemical | 6 litre | 13A/75F | 463a/25 |

Nasr Awwadeh Factory for Fire Fighting & Safety Equipment

Building No. 7, Mohammed Al Khodary Street, P.O. Box 330339, Marka 11134, Amman, Jordan

Tel: +962 6 488 1999 • Fax: +962 6 488 8861

E-mail: info@naffire.com • Website: www.naffire.com

Certificate No: 10921a to EN 3 Parts 7, 8 & 9

'NAF' Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| NCD5 | CO ₂ | 5 kg | 70B | 10921a/33 |
| NPD2S | ABC Powder (SP) | 2 kg | 13A/89B | 10921a/05 |
| NPD6S | ABC Powder (SP) | 6 kg | 43A/233B | 10921a/09 |

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar

Tel: +974 4402 5888 • Fax: +974 4411 4630

E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346a to EN 3 Parts 7, 8 & 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| NQC2 | CO ₂ | 2 kg | 34B | 1346a/01 |
| NQC5 | CO ₂ | 5 kg | 55B | 1346a/02 |
| NQF6 | Foam (SP) | 6 litre | 21A/144B | 1346a/03 |
| NQF9 | Foam (SP) | 9 litre | 21A/183B | 1346a/04 |
| NQP1 | ABC Powder (SP) | 1 kg | 8A/34B | 1346a/05 |
| NQP2 | ABC Powder (SP) | 2 kg | 13A/89B | 1346a/06 |
| NQP4 | ABC Powder (SP) | 4 kg | 21A/113B | 1346a/07 |
| NQP6 | ABC Powder (SP) | 6 kg | 43A/233B | 1346a/08 |
| NQP9 | ABC Powder (SP) | 9 kg | 43A/233B | 1346a/09 |
| NQP12 | ABC Powder (SP) | 12 kg | 55A/233B | 1346a/10 |
| NQW6 | Water (SP) | 6 litre | 13A | 1346a/11 |
| NQW9 | Water (SP) | 9 litre | 21A | 1346a/12 |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

Certificate No: 1346e to EN 3: Parts 7, 8 & 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|------------------|-----------------|--------------------|----------------------|
| NQHFC4 | Clean Agent (SP) | 4 kg | 34B | 1346e/01 |
| NQHFC6 | Clean Agent (SP) | 6 kg | 5A/55B | 1346e/02 |
| NQHFC9 | Clean Agent (SP) | 9 kg | 8A/70B | 1346e/03 |
| NQHFC12 | Clean Agent (SP) | 12 kg | 13A/70B | 1346e/04 |
| NQKE3X | Wet Chemical | 3 litre | 8A/25F | 1346e/05 |
| NQKE6 | Wet Chemical | 6 litre | 13A/75F | 1346e/06 |

Ras Al Khaimah Fire Fighting Equipment Factory Fire King L.L.C

Wiz 07/12 Rakia Warehouse, Industrial Zone, Al Jazeera Al Hamra, Ras Al Khaimah, United Arab Emirates

Tel: +97172437050 • Fax: +97172437040

E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1092Fa to EN 3 Parts 7, 8 and 9

FIRE KING Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|-------------------|-----------------|--------------------|----------------------|
| FKCD2 | CO ₂ | 2 kg | 34B | 1092Fa/31 |
| FKCD5 | CO ₂ | 5 kg | 70B | 1092Fa/33 |
| FKFM6 | Foam (SP) | 6 litre | 21A/144B | 1092Fa/17 |
| FKFM9 | Foam (SP) | 9 litre | 27A/233B | 1092Fa/19 |
| FKPD1 | ABC Powder (SP) | 1 kg | 8A/34B | 1092Fa/01 |
| FKPD2 | ABC Powder (SP) | 2 kg | 13A/89B | 1092Fa/05 |
| FKPD4 | ABC Powder (SP) | 4 kg | 27A/144B | 1092Fa/08 |
| FKPD6 | ABC Powder (SP) | 6 kg | 43A/233B | 1092Fa/09 |
| FKPD9 | ABC Powder (SP) | 9 kg | 55A/233B | 1092Fa/11 |
| FKPD12 | ABC Powder (SP) | 12 kg | 55A/233B | 1092Fa/12 |
| FKWT6 | Water (SP) | 6 litre | 13A | 1092Fa/24 |
| FKWT9 | Water (SP) | 9 litre | 21A | 1092Fa/25 |
| FKWC3 | Wet Chemical (SP) | 3 litre | 13A/70B/40F | 1092Fa/22 |
| FKWC6 | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 1092Fa/23 |

Resil Commercial Industrial Ltda

Av. Prestes Maia 791, Diadema 09930-900, Sao Paulo, Brazil

Tel: +55 11 2178 8071 • Fax: +55 11 2178 8078

E-mail: aline.silva@resil.com.br • Website: www.resil.com.br

Certificate No: 880Aa to BS EN 3 Parts 7 and 8

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|---------------------|-----------------|-----------------|--------------------|----------------------|
| R966 | Foam (SP) | 2 litres | 5A/34B | 880Aa/01 |
| R964 | ABC Powder (SP) | 1 kg | 5A/34B | 880Aa/02 |
| R955 | ABC Powder (SP) | 2 kg | 8A/55B | 880Aa/03 |
| R968 | BC Powder (SP) | 1 kg | 34B | 880Aa/04 |

Certificate No: 880Ab to Technical Approval based upon EN3 Part 7

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|---------------------|----------------|-----------------|--------------------|----------------------|
| R910 | BC Powder (SP) | 800g | 21B | 880Ab/01 |
| R911 | BC Powder (SP) | 800g | 21B | 880Ab/02 |

Note 1. Reference models R910 and R911, 800 g is not one of the specified nominal charges specified in EN 3-7 clause 6.1 Nominal charges.

Saudi Factory for Fire Equipment Co.

Al-Kharj Road, 2nd Industrial Area, PO Box 4441, Riyadh 14334, Kingdom of Saudi Arabia
Tel: +966 1 265 0070 • Fax: +966 1 265 2190
E-mail: qa@sffeco.com.sa • Website: www.sffeco.com

Certificate No: 403a to EN 3: Parts 1 to 6

| Product Name | Type | Capacity | Fire Rating | Operating Temp Range (°C) | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------------------|---------------|
| PD1 | ABC(SP) | 1kg | 8A/34B | -20 to +60 | 403a/05 |
| PD2 | ABC(SP) | 2kg | 13A/70B | -20 to +60 | 403a/01 |
| PD6 | ABC(SP) | 6kg | 34A/183B | -20 to +60 | 403a/02 |
| PD9 | ABC(SP) | 9kg | 43A/233B | -20 to +60 | 403a/03 |
| PD12 | ABC(SP) | 12kg | 55A/233B | -20 to +60 | 403a/04 |
| CD2G | CO ₂ | 2kg | 21B | -20 to +60 | 463a/01 |
| CD5G | CO ₂ | 5kg | 55B | -20 to +60 | 463a/02 |
| FX6 | Foam (SP) | 6 l | 21A/144B | +5 to +60 | 403a/06 |
| FX6MAX | Foam (SP) | 6 l | 27A/183B | +5 to +60 | 403a/07 |
| FX9 | Foam (SP) | 9 l | 21A/183B | +5 to +60 | 403a/08 |
| WH600J | Water (SP) | 6 l | 13A | +5 to +60 | 403a/09 |
| WH900J | Water (SP) | 9 l | 13A | +5 to +60 | 403a/10 |
| WH600S | Water (SP) | 6 l | 13A | +5 to +60 | 403a/11 |
| WH900S | Water (SP) | 9 l | 21A | +5 to +60 | 403a/12 |

Sentura Group (including FireDepot)

Sentura House, 3 Lands End Way, Oakham, Rutland LE15 6RB, United Kingdom
Tel: +44 (0)330 999 22 33 • Fax: +44 (0)1572 770133
E-mail: sales@firedepot.co.uk • Website: www.firedepot.co.uk

Certificate No: 1093b to EN 3-7:2004+A1:2007

FIRECHIEF FM Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| FMP600 | ABC Powder (SP) | 0.6 kg | 5A/21B | 1093b/01 |
| FMP800 | ABC Powder (SP) | 0.8 kg | 5A/34B | 1093b/03 |

Note: 0.6kg and 0.8kg powder are not nominal charges specified in EN 3-7:2004+A1:2007 clause 6.1 - Nominal Charges

Certificate No: 1093a to EN 3 Parts 7, 8 & 9

FIRECHIEF FM, XTR, POWERPLUS & ECOSPRAY Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| FXCD2 | CO ₂ | 2 kg | 34B | 1093a/30 |
| FXCD2S | CO ₂ | 2 kg | 34B | 1093a/31 |
| FXCD5 | CO ₂ | 5 kg | 70B | 1093a/32 |
| FXCD5S | CO ₂ | 5 kg | 70B | 1093a/33 |
| FMF2 | Foam (SP) | 2 litre | 8A/55B | 1093a/14 |
| FXF2 | Foam (SP) | 2 litre | 8A/55B | 1093a/15 |
| FXF3 | Foam (SP) | 3 litre | 13A/89B | 1093a/16 |
| FXF6 | Foam (SP) | 6 litre | 21A/144B | 1093a/17 |
| PPF6 | Foam (SP) | 6 litre | 27A/183B | 1093a/18 |
| FXF9 | Foam (SP) | 9 litre | 27A/233B | 1093a/19 |
| FMP1 | ABC Powder (SP) | 1 kg | 8A/34B | 1093a/01 |
| FMPA1 | ABC Powder (SP) | 1 kg | 8A/34B | 1093a/02 |
| FXP1 | ABC Powder (SP) | 1 kg | 8A/34B | 1093a/03 |
| PPP1 | ABC Powder (SP) | 1 kg | 8A/55B | 1093a/04 |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|---------------------|---------------------|-----------------|--------------------|----------------------|
| FMP2 | ABC Powder (SP) | 2 kg | 13A/89B | 1093a/05 |
| FXP2 | ABC Powder (SP) | 2 kg | 13A/89B | 1093a/06 |
| FXP3 | ABC Powder (SP) | 3 kg | 21A/113B | 1093a/07 |
| FXP4 | ABC Powder (SP) | 4 kg | 27A/144B | 1093a/08 |
| FXP6 | ABC Powder (SP) | 6 kg | 43A/233B | 1093a/09 |
| PPP6 | ABC Powder (SP) | 6 kg | 55A/233B | 1093a/10 |
| FXP9 | ABC Powder (SP) | 9 kg | 55A/233B | 1093a/11 |
| FXP12 | ABC Powder (SP) | 12 kg | 55A/233B | 1093a/12 |
| FXW6 | Water (SP) | 6 litre | 13A | 1093a/24 |
| FXW9 | Water (SP) | 9 litre | 21A | 1093a/25 |
| ESW3 | Water Additive (SP) | 3 litre | 13A | 1093a/28 |
| ESW6 | Water Additive (SP) | 6 litre | 27A | 1093a/29 |
| FMABF2 | Wet Chemical (SP) | 2 litre | 8A/34B/25F | 1093a/20 |
| FXWC2 | Wet Chemical (SP) | 2 litre | 8A/34B/25F | 1093a/21 |
| FXWC3 | Wet Chemical (SP) | 3 litre | 13A/70B/40F | 1093a/22 |
| FXWC6 | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 1093a/23 |

Unisafe Fire Protection Specialists LLC

P.O.Box 117579, Ras Al Khor, Al Aweer Industrial Estate, Dubai, United Arab Emirates

Tel: +971 4 3339977 • Fax: +971 4 3339358

Website: www.unisafedxb.com

Certificate No: 1092Da to EN3 Parts 7, 8 and 9

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|---------------------|---------------------|-----------------|--------------------|----------------------|
| UCE2A | CO ₂ | 2 kg | 34B | 1092Da/30 |
| UCE2 | CO ₂ | 2 kg | 34B | 1092Da/31 |
| UCE5A | CO ₂ | 5 kg | 70B | 1092Da/32 |
| UCE5 | CO ₂ | 5 kg | 70B | 1092Da/33 |
| UFE2 | Foam (SP) | 2 litre | 8A/55B | 1092Da/14 |
| UFE3 | Foam (SP) | 3 litre | 13A/89B | 1092Da/16 |
| UFE6 | Foam (SP) | 6 litre | 21A/144B | 1092Da/17 |
| UFE6X | Foam (SP) | 6 litre | 27A/183B | 1092Da/18 |
| UFE9 | Foam (SP) | 9 litre | 27A/233B | 1092Da/19 |
| UPE1E | ABC Powder (SP) | 1 kg | 8A/34B | 1092Da/01 |
| UPE1A | ABC Powder (SP) | 1 kg | 8A/34B | 1092Da/02 |
| UPE1 | ABC Powder (SP) | 1 kg | 8A/34B | 1092Da/03 |
| UPE1S | ABC Powder (SP) | 1 kg | 8A/55B | 1092Da/04 |
| UPE2S | ABC Powder (SP) | 2 kg | 13A/89B | 1092Da/05 |
| UPE3S | ABC Powder (SP) | 3 kg | 21A/113B | 1092Da/07 |
| UPE4S | ABC Powder (SP) | 4 kg | 27A/144B | 1092Da/08 |
| UPE6S | ABC Powder (SP) | 6 kg | 43A/233B | 1092Da/09 |
| UPE6X | ABC Powder (SP) | 6 kg | 55A/233B | 1092Da/10 |
| UPE9S | ABC Powder (SP) | 9 kg | 55A/233B | 1092Da/11 |
| UPE12 | ABC Powder (SP) | 12 kg | 55A/233B | 1092Da/12 |
| UWE6 | Water (SP) | 6 litre | 13A | 1092Da/24 |
| UWE9 | Water (SP) | 9 litre | 21A | 1092Da/25 |
| UWAE3 | Water Additive (SP) | 3 litre | 13A | 1092Da/28 |
| UWAE6 | Water Additive (SP) | 6 litre | 27A | 1092Da/29 |
| UWCE2 | Wet Chemical (SP) | 2 litre | 8A/34B/25F | 1092Da/21 |
| UWCE3 | Wet Chemical (SP) | 3 litre | 13A/70B/40F | 1092Da/22 |
| UWCE6 | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 1092Da/23 |

Yuyao Tianbo Fire Fighting Equipment Co., Ltd.

Baishuicong Industrial Park, Lianglong Town, Yuyao City, Zhejiang, China

Tel: +86-21-61602389 • Fax: +86-21-61602389 ext. 805

E-mail: export@yvtianbo.cn • Website: www.yvtianbo.cn

Certificate No: 1092a to EN 3 Parts 7,8 & 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|---------------------|----------|--------------|---------------|
| TMCD2A | CO ₂ | 2 kg | 34B | 1092a/30 |
| TMCD2 | CO ₂ | 2 kg | 34B | 1092a/31 |
| TMCD5A | CO ₂ | 5 kg | 70B | 1092a/32 |
| TMCD5 | CO ₂ | 5 kg | 70B | 1092a/33 |
| TMFM2S | Foam (SP) | 2 litre | 8A/55B | 1092a/14 |
| TMFM3S | Foam (SP) | 3 litre | 13A/89B | 1092a/16 |
| TMFM6S | Foam (SP) | 6 litre | 21A/144B | 1092a/17 |
| TMFM6RS | Foam (SP) | 6 litre | 27A/183B | 1092a/18 |
| TMFM9S | Foam (SP) | 9 litre | 27A/233B | 1092a/19 |
| TMPD1E | ABC Powder (SP) | 1 kg | 8A/34B | 1092a/01 |
| TMPD1A | ABC Powder (SP) | 1 kg | 8A/34B | 1092a/02 |
| TMPD1 | ABC Powder (SP) | 1 kg | 8A/34B | 1092a/03 |
| TMPD1S | ABC Powder (SP) | 1 kg | 8A/55B | 1092a/04 |
| TMPD2S | ABC Powder (SP) | 2 kg | 13A/89B | 1092a/05 |
| TMPD3S | ABC Powder (SP) | 3 kg | 21A/113B | 1092a/07 |
| TMPD4S | ABC Powder (SP) | 4 kg | 27A/144B | 1092a/08 |
| TMPD6S | ABC Powder (SP) | 6 kg | 43A/233B | 1092a/09 |
| TMPD6RS | ABC Powder (SP) | 6 kg | 55A/233B | 1092a/10 |
| TMPD9S | ABC Powder (SP) | 9 kg | 55A/233B | 1092a/11 |
| TMPD12 | ABC Powder (SP) | 12 kg | 55A/233B | 1092a/12 |
| TMWT6 | Water (SP) | 6 litre | 13A | 1092a/24 |
| TMWT9 | Water (SP) | 9 litre | 21A | 1092a/25 |
| TMWT3A | Water Additive (SP) | 3 litre | 13A | 1092a/28 |
| TMWT6A | Water Additive (SP) | 6 litre | 27A | 1092a/29 |
| TMWC2 | Wet Chemical (SP) | 2 litre | 8A/34B/25F | 1092a/21 |
| TMWC3 | Wet Chemical (SP) | 3 litre | 13A/70B/40F | 1092a/22 |
| TMWC6 | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 1092a/23 |

Notes:

1. Available as brand name – 'TIANBO'
2. Available as brand name – 'MEGA SAFETY'

Certificate No: 1092b to Technical Approval based upon EN 3-7:2004+A1:2007

'TIANBO' Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| PD600 | ABC Powder (SP) | 0.6 kg | 5A/21B | 1092b/01 |
| PD800 | ABC Powder (SP) | 0.8 kg | 5A/34B | 1092b/03 |

Note: 0.6kg and 0.8kg powder are not nominal charges specified in EN 3 Part 7 clause 6.1 - Nominal Charges

Zhejiang Orientx Fire Safety Equipment Co., Ltd.

Wucheyan, Huangjiabu Town, Yuyao City, Zhejiang 315466, China

Tel: 0086-574-62003908 • Fax: 0086-574-62003933

E-mail: chendian@orientxfire.com • Website: <http://www.orientxfire.com>

Certificate No: 1327a to EN 3-7:2004+A1:2007 & EN 3-9:2006

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|-----------------|----------|-------------|---------------|
| OCE2-LWB117 | CO ₂ | 2 kg | 34B | 1327a/01 |
| OCE5-LWB152 | CO ₂ | 5 kg | 70B | 1327a/02 |

PART 2: SECTION 1

PORTABLE FIRE EXTINGUISHERS

Zhejiang Ruihua Machinery Co. Ltd

No. 1 Fengqixi Road, Western Industrial Zone, Linshan Town, Yuyao, Zhejiang 315460, China

Tel: 0086 1350 578 4280 • Fax: 0086 574 6200 3570

E-mail: jingxingli@ruihuafire.com

Certificate No: 867a to EN 3 Parts 7, 8 and 9

Portable Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|---------------------|---------------------|-----------------|--------------------|----------------------|
| K2S (1) | CO ₂ | 2 kg | 34B | 867a/10 |
| K5S (1) | CO ₂ | 5 kg | 89B | 867a/11 |
| S2 Eco (1) | Foam (SP) | 2 litre | 8A / 55B | 867a/21 |
| S6 Eco (1,2) | Foam (SP) | 6 litre | 21A / 183B | 867a/12 |
| S6 Eco Plus | Foam (SP) | 6 litre | 34A/183B | 867a/20 |
| S9 Eco (1,2) | Foam (SP) | 9 litre | 27A/233B | 867a/13 |
| P1GS (1,2) | ABC Powder (SP) | 1 kg | 8A/55B | 867a/04 |
| PG2/P2GS (1,2) | ABC Powder (SP) | 2 kg | 13A/89B | 867a/01 |
| P2P | ABC Powder (SP) | 2 kg | 13A/89B | 867a/15 |
| PG3/P3GS | ABC Powder (SP) | 3 kg | 21A/144B | 867a/05 |
| PG4/P4GS (1) | ABC Powder (SP) | 4 kg | 27A/233B | 867a/07 |
| P6GS (1,2) | ABC Powder (SP) | 6 kg | 43A/233B | 867a/02 |
| PG9/P9GS (1,2) | ABC Powder (SP) | 9 kg | 55A/233B | 867a/08 |
| PG12/P12GS | ABC Powder (SP) | 12 kg | 55A/233B | 867a/03 |
| W6 (1) | Water (SP) | 6 litre | 13A | 867a/17 |
| W9 (1) | Water (SP) | 9 litre | 21A | 867a/09 |
| WA6 | Water Additive (SP) | 6 litre | 21A | 867a/19 |
| F6 (1) | Wet Chemical (SP) | 6 litre | 21A/113B/75F | 867a/16 |

Notes:

(1) Additional Brand Name - Jackson

(2) Additional Brand Name - Evertuff

Fire Hose Reels should be selected, sited, serviced and maintained in accordance with the relevant code of practice. Hose reels are manufactured in fixed, swinging, recessed and concealed versions with automatic or manual water supply valves. They are normally located in a protective easily accessible approved cabinet to give protection from un-authorized interference, dust, rubbish etc.

A fully extended semi rigid fire hose is up to 30 meters long, red in colour and round in section and is intended to provide a controlled supply of water to combat a potential fire risk quickly without having to set up lengths of lay flat hose from another source. This is achieved via a control nozzle attached to the end of the hose which enables a single operator to control the direction and flow of water to the fire. Its semi rigid construction is flexible and durable, which helps to prevent kinks that would restrict the water supply.

Hose reels help to ensure that escape routes can be maintained and are often located in larger areas or corridors where a fire extinguisher does not provide sufficient cover. If appropriate to the risk the hose reel may also be used to fight the fire in its early stages. Hose reels may also be found in other higher risk locations, such as in a petrochemical environment when used in conjunction with a suitable approved foam attachment.

In some countries layflat hose (which has a larger bore than semi rigid hose) may also be used in a similar manner to a conventional hose reel. The layflat hose, typically 30 metres in length, is located in a cupboard containing a hanging rack and a manual or automatic valve connection to a suitable water supply. The layflat hose system is installed in a fixed location within a building, ensuring a fast and easily available source of larger quantities of water. A branch or nozzle is also supplied to control the water distribution.

This section lists products approved in accordance with:

- EN 671-1 *Fixed firefighting systems - Hose systems: Part 1 Hose reels with semi-rigid hose*; and
- EN 671-2 *Fixed firefighting systems - Hose systems: Part 2 Hose systems with lay-flat hose*

All LPCB approved and listed hose reels carry the LPCB mark and certificate number.

A1 Fire Fighting

P.O.Box 97316, Obaid Warehouse #8, Qusais Ind Area 5, Dubai, United Arab Emirates

Tel: +971 4883 7662 • Fax: +971 4320 9378

E-mail: info@a1firefighting.com • Website: www.a1firefighting.com

Certificate No: 1153Ha to EN 671-1:2012

'A1 FIRE FIGHTING' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---------------------------------------|-------------------------------|--------------------------------|---------------------------|----------------------|
| A1-HRA | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ha/01 |
| A1-HRM-B | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ha/05 |
| A1-HRM-P | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ha/10 |

PART 2: SECTION 3

FIRE HOSE REELS

Al Tahadi Security And Safety Equipment Trading

PO Box 45668, Ind. Area 11, Sharjah, United Arab Emirates

Tel: +971 5 0868 4543 • Fax: +971 6535 9220

E-mail: Sharqawi61@yahoo.com • Website: www.tahadi-fire.com

Certificate No: 1038Ra to EN 671-1

Tahadi Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|--|-------------------------------|--------------------------------|--|----------------------|
| TSS-08-A | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ra/01 |
| TSS-07-B | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ra/02 |
| TSS-06-B | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ra/04 |

Ampac Safety Pty Ltd.

7 Ledgar Road, Balcatta 6021, Australia

Tel: +68 8 9200 2100 • Fax: +61 8 9200 2101

E-mail: nweiss@ampacsafety.net • Website: www.ampacsafety.net

Certificate No: 1153Da to EN 671-1

FlameSAFE Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------------|----------------------|
| 2005-1006 | Automatic, swinging arm, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Da/01 |
| 2005-1002 | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Da/02 |
| 2005-1005 | Automatic, swinging arm, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Da/03 |
| 2005-1001 | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Da/04 |
| 2005-1004 | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Da/05 |
| 2005-1003 | Manual, swinging arm, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Da/06 |

Angus Fire Ltd.

Station Road, Bentham, Lancaster LA2 7NA, United Kingdom

Tel: +44 (0)1524 264000 • Fax: +44 (0)1524 264180

E-mail: general.enquiries@angusuk.co.uk • Website: www.angusfire.co.uk

Certificate No: 1153Ea to EN 671-1:2012

TARTAN Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---------------------------------------|-------------------------------|--------------------------------|---------------------------|----------------------|
| MT-HR002 | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ea/01 |
| MT-HR001 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ea/05 |

Asiatic Fire System Pte Ltd.

65 Joo Koon Circle 629078, Singapore

Tel: +65 6863 0188 • Fax: +65 6897 9220

E-mail: asiatic@asiatic.com.sg • Website: www.asiaticfire.com.sg

Certificate No: 1038ADa to EN 671-1:2012

KILLFIRE Fire Hose Reel

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| KHS-1E-C | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038ADa/14 |

Beijing Synergy Technology Company, Ltd.

B-606, Tian Yuan Gang, No. 2 Dongsanhuan North, Chaoyang, Beijing 100027, China

Tel: +86 10 64680818 • Fax: +86 10 64680816

E-mail: raysun@synergyindustry.com • Website: www.synergyindustry.com

Certificate No: 1038AJa to EN 671-1:2012

'SNG' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| SNG07-03A | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/01 |
| SNG07-03B | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/02 |
| SNG07-03C | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/03 |
| SNG07-03D | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/04 |
| SNG07-02D | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038AJa/05 |
| SNG07-04A | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/06 |
| SNG07-04B | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/07 |
| SNG07-02C | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/12 |
| SNG07-02A | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/13 |
| SNG07-02B | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AJa/14 |

BETA Corporation s.r.o

Slavojova 579/9, Prague 2, Nusle 128 00, Czech Republic

Tel: +420 721 554 641

E-mail: info@betacorporation.eu • Website: www.betacorporation.eu

Certificate No: 1038Xa to EN 671-1:2012

PART 2: SECTION 3

FIRE HOSE REELS

BETA Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| BETA-01 | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Xa/01 |
| BETA-02 | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Xa/02 |
| BETA-03 | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038Xa/05 |

BGS nv

Bleyveld 10, Hoegaarden 3320, Belgium
Tel: +32 16 76 08 87 • Fax: +32 16 76 08 90
E-mail: bgsb@bgs.be • Website: www.bgs.be

Certificate No: 1038AHa to EN 671-1:2012

'BGS' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| HAS20ZN | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AHa/01 |
| HAS30ZN | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AHa/02 |
| HAS20VN | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AHa/06 |
| HAS30VN | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AHa/07 |

Bristol Fire Engineering LLC

Al Quoz Industrial Area 3, P.O.Box 74582, Dubai, United Arab Emirates
Tel: +971 4 347 2426 • Fax: +971 4 347 2363
E-mail: sami@bristol-fire.com • Website: www.bristol-fire.com

Certificate No: 1226a to EN 671-1

Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|--|-------------------------------|--------------------------------|---------------------------|----------------------|
| BF-MS-003 | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Rotary operated jet/spray | 1226a/01 |
| BF-MS-001 | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Rotary operated jet/spray | 1226a/02 |
| BF-AS-004 | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Rotary operated jet/spray | 1226a/03 |
| BF-AS-002 | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Rotary operated jet/spray | 1226a/04 |

Certificate No: 1226a to EN 671-1

Single Door Cabinets

| Product Name | Description | LPCB Ref. No. |
|---------------------|---|----------------------|
| BF-SRM-MS1 | 700x700x300 single cabinet, recessed, full MS | 1226a/05 |
| BF-SRS-SH1 | 700x700x300 single cabinet, recessed, full SS hairline-finish | |
| BF-SRS-SM1 | 700x700x300 single cabinet, recessed, full SS mirror-finish | |
| BF-SRM-SH1 | 700x700x300 single cabinet, recessed, MS back box with SS hairline-finish | |
| BF-SRM-SM1 | 700x700x300 single cabinet, recessed, MS back box with SS mirror-finish | |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| BF-SSM-MS1 | 700x700x300 single cabinet, surface mounted, full MS | |
| BF-SSS-SH1 | 700x700x300 single cabinet, surface mounted, full SS hairline-finish | |
| BF-SSS-SM1 | 700x700x300 single cabinet, surface mounted, full SS mirror-finish | |
| BF-SRM-MS2 | 800x800x300 single cabinet, recessed, full MS | |
| BF-SRS-SH2 | 800x800x300 single cabinet, recessed, full SS hairline-finish | |
| BF-SRS-SM2 | 800x800x300 single cabinet, recessed, full SS mirror-finish | |
| BF-SRM-SH2 | 800x800x300 single cabinet, recessed, MS back box with SS hairline-finish | |
| BF-SRM-SM2 | 800x800x300 single cabinet, recessed, MS back box with SS mirror-finish | |
| BF-SSM-MS2 | 800x800x300 single cabinet, surface mounted, full MS | |
| BF-SSS-SH2 | 800x800x300 single cabinet, surface mounted, full SS hairline-finish | |
| BF-SSS-SM2 | 800x800x300 single cabinet, surface mounted, full SS mirror-finish | |
| BF-SFM-MS1 | 700x700x300 free-standing single cabinet, full MS | |
| BF-SFS-SH1 | 700x700x300 free-standing single cabinet, full SS hairline-finish | |
| BF-SFS-SM1 | 700x700x300 free-standing single cabinet, full SS mirror-finish | |
| BF-SFM-MS2 | 800x800x300 free-standing single cabinet, full MS | |
| BF-SFS-SH2 | 800x800x300 free-standing single cabinet, full SS hairline-finish | |
| BF-SFS-SM2 | 800x800x300 free-standing single cabinet, full SS mirror-finish | |

Certificate No: 1226a to EN 671-1

Double Door Cabinets

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| BF-DRM-MS1 | 1400x700x300 double cabinet, recessed, full MS | 1226a/06 |
| BF-DRS-SH1 | 1400x700x300 double cabinet, recessed, full SS hairline-finish | |
| BF-DRS-SM1 | 1400x700x300 double cabinet, recessed, full SS mirror-finish | |
| BF-DRM-SH1 | 1400x700x300 double cabinet, recessed, MS back box with SS hairline-finish | |
| BF-DRM-SM1 | 1400x700x300 double cabinet, recessed, MS back box with SS mirror-finish | |
| BF-DSM-MS1 | 1400x700x300 double cabinet, surface mounted, full MS | |
| BF-DSS-SH1 | 1400x700x300 double cabinet, surface mounted, full SS hairline-finish | |
| BF-DSS-SM1 | 1400x700x300 double cabinet, surface mounted, full SS mirror-finish | |
| BF-DRM-MS2 | 1600x800x300 double cabinet, recessed, full MS | |
| BF-DRS-SH2 | 1600x800x300 double cabinet, recessed, full SS hairline-finish | |
| BF-DRS-SM2 | 1600x800x300 double cabinet, recessed, full SS mirror-finish | |
| BF-DRM-SH2 | 1600x800x300 double cabinet, recessed, MS back box with SS hairline-finish | |
| BF-DRM-SM2 | 1600x800x300 double cabinet, recessed, MS back box with SS mirror-finish | |
| BF-DSM-MS2 | 1600x800x300 double cabinet, surface mounted, full MS | |
| BF-DSS-SH2 | 1600x800x300 double cabinet, surface mounted, full SS hairline-finish | |
| BF-DSS-SM2 | 1600x800x300 double cabinet, surface mounted, full SS mirror-finish | |
| BF-DFM-MS1 | 1400x700x300 free-standing double cabinet, full MS | |
| BF-DFS-SH1 | 1400x700x300 free-standing double cabinet, full SS hairline-finish | |
| BF-DFS-SM1 | 1400x700x300 free-standing double cabinet, full SS mirror-finish | |
| BF-DFM-MS2 | 1600x800x300 free-standing double cabinet, full MS | |
| BF-DFS-SH2 | 1600x800x300 free-standing double cabinet, full SS hairline-finish | |
| BF-DFS-SM2 | 1600x800x300 free-standing double cabinet, full SS mirror-finish | |

COFFCO

PO Box 5, Pincode - 678002, India

Tel: +914912908940 • Fax: +914912554695

E-mail: coffco@eth.net • Website: www.coffcofire.com

Certificate No: 1092Hd to EN 671-1

COFFCO Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|-----------------------------------|------------------------|-------------------------|-----------------------|---------------|
| CFFHRA19 | Fixed, automatic, wall mounted | 19 | 30 | Rotary operated spray | 1092Hd/01 |
| CFHFRM19 | Fixed, manual, wall mounted | 19 | 30 | Rotary operated spray | 1092Hd/02 |
| CFHRS19 | Swinging, automatic, wall mounted | 19 | 30 | Rotary operated spray | 1092Hd/03 |
| CFHRS19 | Swinging, manual, wall mounted | 19 | 30 | Rotary operated spray | 1092Hd/04 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|-----------------------------------|-------------------------------|--------------------------------|-----------------------|----------------------|
| CFFHRFA25 | Fixed, automatic, wall mounted | 25 | 30 | Rotary operated spray | 1092Hd/05 |
| CFFHRFM25 | Fixed, manual, wall mounted | 25 | 30 | Rotary operated spray | 1092Hd/06 |
| CFFHRSA25 | Swinging, automatic, wall mounted | 25 | 30 | Rotary operated spray | 1092Hd/07 |
| CFFHRSM25 | Swinging, manual, wall mounted | 25 | 30 | Rotary operated spray | 1092Hd/08 |

Crico Engineering

Zuiddijk 10, 8340 Damme, Belgium

Tel: +32 (0)475 834 835

E-mail: info@crico-engineering.com • Website: www.crico.be

Certificate No: 1038Wa to EN 671-1:2012

Crico Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| AQUASPRAY 20S | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Wa/01 |
| AQUASPRAY 30S | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Wa/02 |
| AQUASPRAY 20F | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Wa/06 |
| AQUASPRAY 30F | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Wa/07 |

Dafoos Fire Protection Equipment Trading Est.

PO Box 50891, Warehouse No. 51, Al Quoz 4, Dubai, United Arab Emirates

Tel: +971-43402020 • Fax: +971-43471390

E-mail: dafoos@dafoos.com • Website: www.dafoos.com

Certificate No: 1153Ga to EN 671-1:2012

'SPARTAN' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---------------------------------------|-------------------------------|--------------------------------|---------------------------|----------------------|
| DFP-FHA-025 | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ga/01 |
| DFP-FHM-025 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ga/05 |

EMACO GLOBAL LLC

985 Kendall Drive Suite #A-230, San Bernardino CA 92407, USA

Tel: +1-909-907-9492 • Fax: +1-909-907-9492

E-mail: info@emacoglobal.com • Website: www.emacoglobal.com

Certificate No: 1038ALa to EN 671-1:2012

'EMACO' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| E0161-08-A | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038ALa/01 |
| E0161-07-B | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038ALa/02 |

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300 • Fax: +971 6 5340090

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Single door cabinets

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| FXHRMS | Single surface mounted | 863c/03 |
| FXHRRMS | Single, recessed | |
| FXHRSSBS | Single, surface mounted, stainless steel brush finish | 863c/03 |
| FXHRRSBS | Single, recessed, stainless steel brush finish | |
| FXHRSSMS | Single, surface mounted, stainless steel mirror finish | 863c/03 |
| FXHRRSMS | Single, recessed, stainless steel mirror finish | |
| FXHRRSBMS | Single, recessed, door & architrave stainless steel brush finish | 863c/03 |
| FXHRRSMMS | Single, recessed, door & architrave stainless steel mirror finish | |
| FXHRMSG | Single, surface mounted, glazed door | 863c/03 |
| FXHRRMSG | Single, recessed, glazed door | |
| FXHRSSBSG | Single, surface mounted, stainless steel brush finish, glazed door | 863c/03 |
| FXHRRSBSG | Single, recessed, stainless steel brush finish, glazed door | |
| FXHRSSMSG | Single, surface mounted, stainless steel mirror finish, glazed door | 863c/03 |
| FXHRRMSG | Single, recessed, stainless steel mirror finish, glazed door | |
| FXHRRSBMSG | Single, recessed, door & architrave stainless steel brush finish, glazed door | 863c/03 |
| FXHRRSMMSG | Single, recessed, door & architrave stainless steel mirror finish, glazed door | |

Double door cabinets

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| FXHRESMD | Double, surface mounted | 863c/04 |
| FXHRERMD | Double, recessed | |
| FXHRESSBD | Double, surface mounted, stainless steel brush finish | 863c/04 |
| FXHRERSBD | Double, recessed, stainless steel brush finish | |
| FXHRESMD | Double, surface mounted, stainless steel mirror finish | 863c/04 |
| FXHRERSMD | Double, recessed, stainless steel mirror finish | |
| FXHRERSBMD | Double, recessed, door & architrave stainless steel brush finish | 863c/04 |
| FXHRERSMMD | Double, recessed, door & architrave stainless steel mirror finish | |
| FXHRESMDG | Double, surface mounted, glazed doors | 863c/04 |
| FXHRERMDG | Double, recessed, glazed doors | |
| FXHRESSBDG | Double, surface mounted, stainless steel brush finish, glazed doors | 863c/04 |
| FXHRERSBDG | Double, recessed, stainless steel brush finish, glazed doors | |
| FXHRESSMDG | Double, surface mounted, stainless steel mirror finish, glazed doors | 863c/04 |
| FXHRERSMDG | Double, recessed, stainless steel mirror finish, glazed doors | |
| FXHRERSBMDG | Double, recessed, door & architrave stainless steel brush finish, glazed doors | 863c/04 |
| FXHRERSMMDG | Double, recessed, door & architrave stainless steel mirror finish, glazed door | |

Certificate No: 863c to BS EN671-1

Fire Hose Reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|-------------|---------------|
| FX/HR/A25 | Automatic, swinging arm, wall mounted, twist jet brass/chrome nozzle | 25 | 30 | Jet/spray | 863c/01 |
| FX/HR/M25 | Manual, swinging arm, wall mounted, twist jet brass/chrome nozzle | 25 | 30 | Jet/spray | 863c/02 |

PART 2: SECTION 3

FIRE HOSE REELS

EUROFEU

12 Rue Albert Remy, Senonches 28250, France
Tel: +33 82090 1818 • Fax: +33 23737 9196
Website: www.eurofeu.fr

Certificate No: 1127Aa to EN 671-1:2012

'EUROFEU' Fire Hose Reel

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|---|---------------|
| ERF3330P | Manual, swinging arm, pillar or wall mounted | 33 | 30 | Rotary operated jet/spray or lever operated jet/spray | 1127Aa/07 |

Eurotech Fire Protection Ltd, in collaboration with Firetec Systems Ltd

Unit 6, The Business Centre, Molly Millars Lane, Wokingham, Berkshire RG41 2QZ, United Kingdom
Tel: +44 1252 860606 • Fax: +44 1252 860606
E-mail: keith.goodall@EurotechFP.com • Website: www.firetec-systems.com

Certificate No: 10380a to BS EN 671-1

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| EFPFHRM01 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 10380a/01 |
| EFPFHRM02 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 10380a/02 |
| EFPFHRA01 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 10380a/03 |
| EFPFHRA02 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 10380a/04 |

Eversafe Extinguisher Sdn Bhd

Lot 878, Jalan Subang 9, Taman Perindustrian Subang, 47500 Subang Jaya, Selangor Darul Ehsan, Malaysia
Tel: +603 8024 9898 • Fax: +603 8024 7878
E-mail: info@eversafe.net • Website: www.eversafe.net

Certificate No: 734a to BS EN 671-1

Fire Hose Reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| EE-CSJR-08 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/01 |
| EE-CSJR-07 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/02 |

PART 2: SECTION 3**FIRE HOSE REELS**

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| EE-CSJR-10 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/03 |
| EE-CSJR-06 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/04 |
| EE-CSJR-01 | Manual, swinging arm, wall mounted, rotary operated nozzle | 33 | 30 | Rotary operated jet/spray | 734a/05 |
| FS-CSJR-08 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/06 |
| FS-CSJR-07 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/07 |
| FS-CSJR-10 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/08 |
| FS-CSJR-06 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/09 |
| FS-CSJR-01 | Manual, swinging arm, wall mounted, rotary operated nozzle | 33 | 30 | Rotary operated jet/spray | 734a/10 |
| RP-CSJR-08 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/11 |
| RP-CSJR-07 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/12 |
| RP-CSJR-10 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/13 |
| RP-CSJR-06 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 734a/14 |
| RP-CSJR-01 | Manual, swinging arm, wall mounted, rotary operated nozzle | 33 | 30 | Rotary operated jet/spray | 734a/15 |

Notes:

- 1) Prefix EE are branded "EVERSAFE"
- 2) Prefix FS are branded "FireSafe"
- 3) Prefix RP are branded "Red Panther"

Exon For Fire Protection Inc.

615 Remnor Ave, Ottawa, Ontario K2T 0A6, Canada

Tel: +613 276 7755

E-mail: ahmed.shalaby@exonfire.com • Website: www.exonfire.com

Certificate No: 1153Fa to EN 671-1:2012

EZULA Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---------------------------------------|------------------------|-------------------------|---------------------------|---------------|
| EX06-172-00 | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Fa/01 |
| EX06-173-00 | Manual, fixed, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Fa/02 |
| EX06-173B-00 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Fa/05 |

PART 2: SECTION 3

FIRE HOSE REELS

Fire Fighter CO Security and Safety Equipment Trading LLC

Al Qusais Industry Area 4, P O Box 84926, Dubai, UAE, United Arab Emirates

Tel: 00971-4-2554494

E-mail: mutasem@firefighterco1.ae

Certificate No: 1038AGa to EN 671-1:2012

'FST' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|--|-------------------------------|--------------------------------|--|----------------------|
| FST-08 | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AGa/01 |
| FST-07 | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AGa/02 |
| FST-10 | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AGa/03 |
| FST-06 | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AGa/04 |

Fireguard Safety Equipment Co Ltd

2nd Floor, 145-147 St John Street, London EC1V 4PY, United Kingdom

Tel: +44 (0)8450 751042 • Fax: +44 (0)845 2991039

E-mail: info@fireguard-uk.com • Website: www.fireguard-uk.com

Certificate No: 1038Ba to BS EN 671-1

Fire Hose Reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|--|-------------------------------|--------------------------------|--|----------------------|
| FGHR 1930M | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/01 |
| FGHR 2530M | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/02 |
| FGHR 1930A | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/03 |
| FGHR 2530A | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/04 |
| Pulsor 1930M | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/05 |
| Pulsor 2530M | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/06 |
| Pulsor 1930A | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/07 |
| Pulsor 2530A | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ba/08 |

Flamex Fire & Safety Equip

Office No. 11, 4th Industrial Road, Sharjah Industrial Area No. 12, P.O.Box 28817, Sharjah, United Arab Emirates

Tel: +971 6 5442033 • Fax: +971 6 5442032

E-mail: flamex@eim.ae • Website: <http://www.flamexperts.com>

Certificate No: 1153Ba to EN 671-1:2012

SAVER Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---------------------------------------|------------------------|-------------------------|---------------------------|---------------|
| KX06-172-00 | Automatic, swinging arm, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Ba/01 |
| KX06-173-00 | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Ba/02 |
| KX06-172A-00 | Automatic, swinging arm, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Ba/03 |
| KX06-173A-00 | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Ba/04 |
| KX06-173B-00 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ba/05 |
| KX06-173C-00 | Manual, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153Ba/06 |
| KX06-216A-00 | Manual, fixed, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153Ba/07 |
| KX06-216-00 | Manual, fixed, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ba/08 |
| KX06-217A-00 | Manual, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153Ba/09 |
| KX06-217-00 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ba/10 |
| KX06-218A-00 | Automatic, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153Ba/11 |
| KX06-218-00 | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153Ba/12 |

Fullblaze Middle East

Zarqa Free Zone, New Expansionist Area, P.O.Box 922054, Amman 11192, Jordan

Tel: +962 6 489 3373 • Fax: +962 6 489 3372

E-mail: info@fullblaze-me.com • Website: www.fullblaze-me.com

Certificate No: 1092Ed to EN 671-1:2012

Fullblaze Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|-----------------------|---------------|
| FB-SA19 | Swinging, automatic, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092Ed/03 |
| FB-SM19 | Swinging, manual, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092Ed/04 |
| FB-SA25 | Swinging, automatic, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092Ed/07 |
| FB-SM25 | Swinging, manual, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092Ed/08 |

PART 2: SECTION 3

FIRE HOSE REELS

Global Factory For Production of Fire Fighting Equipment

P.O. Box 1236, Doha, Qatar

Tel: +974 44427171 • Fax: +974 4442443

E-mail: info@security-qatar.com • Website: www.security-qatar.com

Certificate No: 1127Ba to EN 671-1:2012

'GF' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---------------------------------------|-------------------------------|--------------------------------|---------------------------|----------------------|
| QD/HR/A25 | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1127Ba/01 |
| QD/HR/M25 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1127Ba/02 |
| QD/HR/A19 | Automatic, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1127Ba/04 |
| QD/HR/M19 | Manual, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1127Ba/05 |

Intelligent Safety & Security Technology Ltd.

Fourth Floor, 30 - 31 Furnival Street, London EC4A 1JQ, United Kingdom

Tel: +44 845 116 2945 • Fax:

E-mail: info@isst-uk.com • Website: www.isst-uk.com

Certificate No: 1038Ja to BS EN 671-1

Fire Hose Reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| HRM-01 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ja/01 |
| HRM-02 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ja/02 |
| HRA-01 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ja/03 |
| HRA-02 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ja/04 |

Jordan Experts Fire Fighting Equipment Manufacturers (JOFFEX)

P.O Box 950299, Zarqa Free Zone, Zarqa City 11195, Jordan

Tel: +962 5382 5550 • Fax: +962 5382 5559

E-mail: sales@joffex.com • Website: www.joffex.com

Certificate No: 1038Ua to EN 671-1:2012

JOFFEX Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| JXR-1 | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ua/02 |

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building 738471, Singapore

Tel: +65 6759 4163 • Fax: +65 6758 7513

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501b to BS EN 671-1

'Combat' Fire Hose Reels

| Product Name | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle Type | LPCB Ref. No. |
|--|------------------------|-------------------------|-------------|---------------|
| 'Combat' model HR-19AS automatic swinging slim hose reel | 19 | 30 | Jet | 501b/03 |
| 'Combat' model HR-1AF automatic fixed slim hose reel | 25 | 30 | Jet | 501b/04 |
| 'Combat' model HR-1AS automatic swinging slim hose reel | 25 | 30 | Jet | 501b/05 |
| 'Combat' model HR-1ASF automatic fixed super slim hose reel | 25 | 30 | Jet | 501b/06 |
| 'Combat' model AHR-1SW automatic universal swinging hose reel | 25 | 30 | Jet | 501b/02 |
| 'Combat' model HR-1MF manual fixed slim hose reel | 25 | 30 | Jet | 501b/07 |
| 'Combat' model HR-1MS manual swinging slim hose reel | 25 | 30 | Jet | 501b/08 |
| 'Combat' model HR-1MSF manual fixed super slim hose reel | 25 | 30 | Jet | 501b/09 |
| 'Combat' model HR-1SSW manual swinging slim hose reel | 25 | 30 | Jet | 501b/10 |
| 'Combat' model HR-1SW manual swinging hose reel | 25 | 30 | Jet | 501b/01 |
| 'Combat' model HR-1SWS manual swinging hose reel | 25 | 30 | Jet | 501b/11 |
| 'Combat' model HR0287 manual, titanium valve, stainless steel drum and swing arm hose reel | 25 | 30 | Jet, spray | 501b/12 |
| 'Combat' model HR0288 manual, titanium valve, stainless steel drum and swing arm hose reel | 33 | 30 | Jet, spray | 501b/13 |
| 'Combat' model HR0279 manual, bronze valve, stainless steel drum and swing arm hose reel | 25 | 30 | Jet, spray | 501b/14 |
| 'Combat' model HR0281 manual, bronze valve, stainless steel drum and swing arm hose reel | 33 | 30 | Jet, spray | 501b/15 |
| 'Combat' model HR0278 manual, bronze valve, mild steel drum and swing arm hose reel | 25 | 30 | Jet, spray | 501b/16 |
| 'Combat' model HR0280 manual, bronze valve, mild steel drum and swing arm hose reel | 33 | 30 | Jet, spray | 501b/17 |

Certificate No: 501b to BS EN 671-1

'Q Fire' Fire Hose Reels

| Product Name | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle Type | LPCB Ref. No. |
|---|------------------------|-------------------------|-------------|---------------|
| 'Q Fire' model QF-19AS automatic swinging slim hose reel | 19 | 30 | Jet | 501b/03 |
| 'Q Fire' model QF-1AF automatic fixed slim hose reel | 25 | 30 | Jet | 501b/04 |
| 'Q Fire' model QF-1AS automatic swinging slim hose reel | 25 | 30 | Jet | 501b/05 |
| 'Q Fire' model QF-1ASF automatic fixed super slim hose reel | 25 | 30 | Jet | 501b/06 |
| 'Q Fire' model AQF-1SW automatic universal swinging hose reel | 25 | 30 | Jet | 501b/02 |
| 'Q Fire' model QF-1MF manual fixed slim hose reel | 25 | 30 | Jet | 501b/07 |
| 'Q Fire' model QF-1MS manual swinging slim hose reel | 25 | 30 | Jet | 501b/08 |
| 'Q Fire' model QF-1MSF manual fixed super slim hose reel | 25 | 30 | Jet | 501b/09 |
| 'Q Fire' model QF-1SSW manual swinging slim hose reel | 25 | 30 | Jet | 501b/10 |
| 'Q Fire' model QF-1SW manual swinging hose reel | 25 | 30 | Jet | 501b/01 |
| 'Q Fire' model QF-1SWS manual swinging hose reel | 25 | 30 | Jet | 501b/11 |

Certificate No: 501b to BS EN 671-1

'Will' Fire Hose Reels

| Product Name | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle Type | LPCB Ref. No. |
|---|------------------------|-------------------------|-------------|---------------|
| 'Will' model WEN-19AS automatic swinging slim hose reel | 19 | 30 | Jet | 501b/03 |
| 'Will' model WEN-1AF automatic fixed slim hose reel | 25 | 30 | Jet | 501b/04 |
| 'Will' model WEN-1AS automatic swinging slim hose reel | 25 | 30 | Jet | 501b/05 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle Type | LPCB Ref. No. |
|---|------------------------|-------------------------|-------------|---------------|
| 'Will' model WEN-1ASF automatic fixed super slim hose reel | 25 | 30 | Jet | 501b/06 |
| 'Will' model WEN1-04 automatic universal swinging hose reel | 25 | 30 | Jet | 501b/02 |
| 'Will' model WEN-1MF manual fixed slim hose reel | 25 | 30 | Jet | 501b/07 |
| 'Will' model WEN-1MS manual swinging slim hose reel | 25 | 30 | Jet | 501b/08 |
| 'Will' model WEN-1MSF manual fixed super slim hose reel | 25 | 30 | Jet | 501b/09 |
| 'Will' model WEN-1SSW manual swinging slim hose reel | 25 | 30 | Jet | 501b/10 |
| 'Will' model WEN-1SW manual swinging hose reel | 25 | 30 | Jet | 501b/01 |
| 'Will' model WEN-1SWS manual swinging hose reel | 25 | 30 | Jet | 501b/11 |

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete 73136, Greece

Tel: +30 282 10 63222 • Fax: +30 282 10 66260

E-mail: sales@mobiak.gr • Website: <http://www.mobiak.gr>

Certificate No: 1038Sa to EN 671-1

Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------|---|------------------------|-------------------------|--|---------------|
| MBK14-SJR-08A | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/01 |
| MBK10-SJR-07B | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/02 |
| MBK14-SJR-10B | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/03 |
| MBK10-SJR-06B | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/04 |
| MBK10-SJR-01B | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038Sa/05 |
| MBK10-SJR-02A | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/06 |
| MBK10-SJR-02B | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/07 |
| MBK14-SJR-12A | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/08 |
| MBK14-SJR-13A | Automatic, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/09 |
| MBK14-SJR-14A | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/10 |
| MBK14-SJR-15A | Automatic, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/11 |
| MBK14-SJR-01A | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/12 |
| MBK10-SJR-04A | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/13 |
| MBK14-SJR-04B | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Sa/14 |

Certificate No: 1038Ac to EN 671-1:2012

'Altech' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------------|--|------------------------|-------------------------|---------------------------|---------------|
| MBK15-25BD NRF-9202501 | Manual, swinging door, cabinet mounted | 19 | 25 | Rotary operated jet/spray | 1038Ac/01 |
| MBK15-30BD NRF-9202502 | Manual, swinging door, cabinet mounted | 19 | 30 | Rotary operated jet/spray | |

Monsher Fire Protection Systems (P) Ltd.

403 Tantia Jogani Estate, Off N.M Joshi Road, Lower Parel (East), Mumbai 400011, India

Tel: +91 22 4051 2000 • Fax: +91 22 4051 2025

E-mail: info@monsher.com • Website: www.monsher.com

Certificate No: 1038Pa to EN 671-1

Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| BF-MS-003 | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Pa/01 |

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111 • Fax: +971 48151222

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463d to EN 671-1

Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle Type | LPCB Ref. No. |
|-----------------|--|------------------------|-------------------------|-------------|---------------|
| 19HFH-020A | swinging arm, automatic, plastic rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/01 |
| 19HFH-020AB | swinging arm, automatic, brass rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/15 |
| 19HFH-020A/SS | swinging arm, automatic, plastic rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/16 |
| 19HFH-020A/SS-B | swinging arm, automatic, brass rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/17 |
| 19HFH-030A | swinging pipe, automatic, plastic rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/02 |
| 19HFH-030AB | swinging pipe, automatic, brass rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/18 |
| 19HFH-030A/SS | swinging pipe, automatic, plastic rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/19 |
| 19HFH-030A/SS-B | swinging pipe, automatic, brass rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/20 |
| 19HFH-040A | fixed, automatic, plastic rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/03 |
| 19HFH-040AB | fixed, automatic, brass rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/21 |
| 19HFH-040A/SS | fixed, automatic, plastic rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/22 |
| 19HFH-040A/SS-B | fixed, automatic, brass rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/23 |
| 19HFH-020M | swinging arm, manual, plastic rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/04 |
| 19HFH-020MB | swinging arm, manual, brass rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/24 |
| 19HFH-020M/SS | swinging arm, manual, plastic rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/25 |
| 19HFH-020M/SS-B | swinging arm, manual, brass rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/26 |
| 19HFH-030M | swinging pipe, manual, plastic rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/05 |
| 19HFH-030MB | swinging pipe, manual, brass rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/27 |
| 19HFH-030M/SS | swinging pipe, manual, plastic rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/28 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle Type | LPCB Ref. No. |
|-----------------|--|------------------------|-------------------------|-------------|---------------|
| 19HFH-030M/SS-B | swinging pipe, manual, brass rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/29 |
| 19HFH-040M | fixed, manual, plastic rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/06 |
| 19HFH-040MB | fixed, manual, brass rotary nozzle, mild steel reels | 19 | 30 | jet/spray | 463d/30 |
| 19HFH-040M/SS | fixed, manual, plastic rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/31 |
| 19HFH-040M/SS-B | fixed, manual, brass rotary nozzle, stainless steel reels | 19 | 30 | jet/spray | 463d/32 |
| 25HFH-020A | swinging arm, automatic, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/07 |
| 25HFH-020AB | swinging arm, automatic, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/33 |
| 25HFH-020A/SS | swinging arm, automatic, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/34 |
| 25HFH-020A/SS-B | swinging arm, automatic, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/35 |
| 25HFH-030A | swinging pipe, automatic, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/08 |
| 25HFH-030AB | swinging pipe, automatic, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/36 |
| 25HFH-030A/SS | swinging pipe, automatic, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/37 |
| 25HFH-030A/SS-B | swinging pipe, automatic, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/38 |
| 25HFH-040A | fixed, automatic, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/09 |
| 25HFH-040AB | fixed, automatic, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/39 |
| 25HFH-040A/SS | fixed, automatic, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/40 |
| 25HFH-040A/SS-B | fixed, automatic, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/41 |
| 25HFH-020M | swinging arm, manual, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/10 |
| 25HFH-020MB | swinging arm, manual, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/42 |
| 25HFH-020M/SS | swinging arm, manual, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/43 |
| 25HFH-020M/SS-B | swinging arm, manual, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/44 |
| 25HFH-030M | swinging pipe, manual, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/11 |
| 25HFH-030MB | swinging pipe, manual, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/45 |
| 25HFH-030M/SS | swinging pipe, manual, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/46 |
| 25HFH-030M/SS-B | swinging pipe, manual, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/47 |
| 25HFH-040M | fixed, manual, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/12 |
| 25HFH-040MB | fixed, manual, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 463d/48 |
| 25HFH-040M/SS | fixed, manual, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/49 |
| 25HFH-040M/SS-B | fixed, manual, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 463d/50 |

Note:

Hose reels approved for use with NLSV-25 Lock Shield Valve to BS 5154

Certificate No: 463d to EN 671-1

Cabinets

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| NF-SM-300 | Single cabinet, surface mounted, mild steel, solid door. | 463d/13 |
| NF-RM-300 | Single cabinet, recess mounted, mild steel, solid door. | |
| NF-SSB-300 | Single cabinet, surface mounted, brush finish stainless steel, solid door. | 463d/14 |
| NF-SSM-300 | Single cabinet, surface mounted, mirror finish stainless steel, solid door. | |
| NF-RSB-300 | Single cabinet, recess mounted, brush finish stainless steel, solid door. | |
| NF-RSM-300 | Single cabinet, recess mounted, mirror finish stainless steel, solid door. | |
| NF-SMK-300 | Single cabinet, surface mounted, mild steel, solid door, break glass and key. | |
| NF-RMK-300 | Single cabinet, recess mounted, mild steel, solid door, break glass and key. | |
| NF-SSBK-300 | Single cabinet, surface mounted, brush finish stainless steel, solid door, break glass and key. | |
| NF-SSMK-300 | Single cabinet, surface mounted, mirror finish stainless steel, solid door, break glass and key. | |
| NF-RSBK-300 | Single cabinet, recess mounted, brush finish stainless steel, solid door, break glass and key. | |
| NF-RSMK-300 | Single cabinet, recess mounted, mirror finish stainless steel, solid door, break glass and key. | |
| NF-SM-900 | Double vertical cabinet, surface mounted, mild steel, solid door. | 463d/14 |
| NF-RM-900 | Double vertical cabinet, recess mounted, mild steel, solid door. | |
| NF-SSB-900 | Double vertical cabinet, recess mounted, mild steel, solid door. | 463d/13 |
| NF-SSM-900 | Double vertical cabinet, surface mounted, mirror finish stainless steel, solid door. | |
| NF-RSB-900 | Double vertical cabinet, recess mounted, brush finish stainless steel, solid door. | |
| NF-RSM-900 | Double vertical cabinet, recess mounted, mirror finish stainless steel, solid door. | |
| NF-SMK-900 | Double vertical cabinet, surface mounted, mild steel, solid door, break glass and key. | |
| NF-RMK-900 | Double vertical cabinet, recess mounted, mild steel, solid door, break glass and key. | |
| NF-SSBK-900 | Double vertical cabinet, surface mounted, brush finish stainless steel, solid door, break glass and key. | |
| NF-SSMK-900 | Double vertical cabinet, surface mounted, mirror finish stainless steel, solid door, break glass and key. | |
| NF-RSBK-900 | Double vertical cabinet, recess mounted, brush finish stainless steel, solid door, break glass and key. | |
| NF-RSMK-900 | Double vertical cabinet, recess mounted, mirror finish stainless steel, solid door, break glass and key. | |
| NF-SMP-300 | Single cabinet, surface mounted, mild steel, solid door, piano hinge. | 463d/13 |
| NF-RMP-300 | Single cabinet, recess mounted, mild steel, solid door, piano hinge. | |
| NF-SMPK-300 | Single cabinet, surface mounted, mild steel, solid door, piano hinge, break glass and key. | 463d/14 |
| NF-RMPK-300 | Single cabinet, recess mounted, mild steel, solid door, piano hinge, break glass and key. | |
| NF-SMGK-900 | Double vertical cabinet, surface mounted, mild steel, glass door, break glass and key. | 463d/14 |
| NF-RMGK-900 | Double vertical cabinet, recess mounted, mild steel, glass door, break glass and key. | |
| NF-SSBGK-900 | Double vertical cabinet, surface mounted, brush finish stainless steel, glass door, break glass and key. | 463d/14 |
| NF-SSMGK-900 | Double vertical cabinet, surface mounted, mirror finish stainless steel, glass door, break glass and key. | |
| NF-RSBGK-900 | Double vertical cabinet, recess mounted, brush finish stainless steel, glass door, break glass and key. | |
| NF-RSMGK-900 | Double vertical cabinet, recess mounted, mirror finish stainless steel, glass door, break glass and key. | |
| NF-SMP-900 | Double vertical cabinet, surface mounted, mild steel, solid door, piano hinge. | |
| NF-RMP-900 | Double vertical cabinet, recess mounted, mild steel, solid door, piano hinge. | |
| NF-SMG-900 | Double vertical cabinet, surface mounted, mild steel, glass door, piano hinge. | |
| NF-RMG-900 | Double vertical cabinet, recess mounted, mild steel, glass door, piano hinge. | |
| NF-SSBG-900 | Double vertical cabinet, surface mounted, brush finish stainless steel, glass door, piano hinge. | |
| NF-SSMG-900 | Double vertical cabinet, surface mounted, mirror finish stainless steel, glass door, piano hinge. | |
| NF-RSBG-900 | Double vertical cabinet, recess mounted, brush finish stainless steel, glass door, piano hinge. | 463d/14 |
| NF-RSMG-900 | Double vertical cabinet, recess mounted, mirror finish stainless steel, glass door, piano hinge. | |
| NF-SMPK-900 | Double vertical cabinet, surface mounted, mild steel, solid door, piano hinge, break glass and key. | |
| NF-SMGP-900 | Double vertical cabinet, surface mounted, mild steel, glass door, piano hinge. | |
| NF-RMGP-900 | Double vertical cabinet, recess mounted, mild steel, glass door, piano hinge. | |
| NF-SMGPK-900 | Double vertical cabinet, surface mounted, mild steel, glass door, piano hinge, break glass and key. | |
| NF-RMGPK-900 | Double vertical cabinet, recess mounted, mild steel, glass door, piano hinge, break glass and key. | |

PART 2: SECTION 3

FIRE HOSE REELS

Nasr Awwadeh Factory for Fire Fighting & Safety Equipment

Building No. 7, Mohammed Al Khodary Street, P.O. Box 330339, Marka 11134, Amman, Jordan

Tel: +962 6 488 1999 • Fax: +962 6 488 8861

E-mail: info@naffire.com • Website: www.naffire.com

Certificate No: 1038AMa to EN 671-1:2012

'NAF' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| N-MS-25A | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AMa/02 |

National Factory for Security & Safety Equipment LLC

P.O.Box 129, Road No. 19, Ind. Estate, Al Rusayl PC 124, Sultanate of Oman

Tel: +968 2444 6268 • Fax: +968 2444 6227

E-mail: sales@amancoglobal.com • Website: www.amancoglobal.com

Certificate No: 1038Qa to EN 671-1

Amanco Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|--|-------------------------------|--------------------------------|--|----------------------|
| AFHR-21 | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Qa/03 |
| AFHR-19 | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Qa/04 |

Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Wu Che Yan, Yuyao City, Zhejiang Province, China

Tel: +86 574 62025710 • Fax: +86 574 62025711

E-mail: info@jintianfire.com • Website: www.jintianfire.com

Certificate No: 1153a to BS EN 671-1

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---------------------------------------|-------------------------------|--------------------------------|---------------------------|----------------------|
| KX06-172-00 | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153a/01 |
| KX06-173-00 | Manual, fixed, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153a/02 |
| KX06-172A-00 | Automatic, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153a/03 |
| KX06-173A-00 | Manual, fixed, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153a/04 |
| KX06-173B-00 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153a/05 |
| KX06-173C-00 | Manual, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153a/06 |
| KX06-216A-00 | Manual, fixed, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153a/07 |
| KX06-216-00 | Manual, fixed, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153a/08 |
| KX06-217A-00 | Manual, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153a/09 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---------------------------------------|------------------------|-------------------------|---------------------------|---------------|
| KX06-217-00 | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153a/10 |
| KX06-218A-00 | Automatic, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1153a/11 |
| KX06-218-00 | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1153a/12 |

NOHA Norway AS

Lagerveien 25, 4033 Stavanger, Norway

Tel: +47 51 81 60 00 • Fax: +47 51 81 60 01

E-mail: sales@noha.no • Website: www.noha.no

Certificate No: 1038Ta to EN 671-1:2012

Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| 2SW-C 19/30 | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ta/01 |
| 2SW-C 25/30 | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ta/02 |
| 2SWA-C 19/30 | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ta/03 |
| 2SWA-C 25/30 | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ta/04 |

NORD PROTECTION SARL

2 et 4 Boulevard Al Imam Allait Ibn Asaad, El Qods, Sidi Bernoussi, Casablanca 20610, Morocco

Tel: +212 522 76 52 40 • Fax: +212 522 76 52 44

E-mail: contact@nordprotection.ma • Website: www.nordprotection.ma

Certificate No: 1038Ya to EN 671-1:2012

NP Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| NP002C | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ya/02 |
| NP001 | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038Ya/05 |
| NP002 | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ya/10 |
| NP002A | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ya/12 |
| NP002B | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Ya/14 |

PART 2: SECTION 3

FIRE HOSE REELS

Power Saints Ltd.

Tianhua Industrial District, Langxia Street Scene, Yuyao City, Zhejiang 315480, China

Tel: 0086 (0)571 85772095 • Fax: 0086 (0)571 85772094

E-mail: jose@powersaints.com • Website: www.saintsea.com

Certificate No: 1127a to BS EN 671-1

'Krone' Fire Hose Reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|---|----------------------|
| SA10-314D-03S | Automatic, swinging arm, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated jet/spray | 1127a/01 |
| SA10-314D-02S | Manual, swinging arm, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated jet/spray | 1127a/02 |
| SA10-314D-14F | Manual, fixed, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated jet/spray | 1127a/03 |
| SA10-304D-03S | Automatic, swinging arm, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated jet/spray | 1127a/04 |
| SA10-304D-02S | Manual, swinging arm, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated jet/spray | 1127a/05 |
| SA10-304D-14F | Manual, fixed, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated jet/spray | 1127a/06 |
| PSHR3330SF | Manual, swinging arm, pillar or wall mounted | 33 | 30 | Rotary operated jet/spray or lever operated jet/spray | 1127a/07 |

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar

Tel: +974 4402 5888 • Fax: +974 4411 4630

E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346b to EN 671-1

Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle Type | LPCB Ref. No. |
|---------------------|--|-------------------------------|--------------------------------|--------------------|----------------------|
| 25NQFH-020A | swinging arm, automatic, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/01 |
| 25NQFH-020AB | swinging arm, automatic, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/02 |
| 25NQFH-20A/SS | swinging arm, automatic, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/03 |
| 25NQFH-20A/SS-B | swinging arm, automatic, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/04 |
| 25NQFH-030A | swinging pipe, automatic, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/05 |
| 25NQFH-030AB | swinging pipe, automatic, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/06 |
| 25NQFH-30A/SS | swinging pipe, automatic, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/07 |
| 25NQFH-30A/SS-B | swinging pipe, automatic, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/08 |
| 25NQFH-020M | swinging arm, manual, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/13 |
| 25NQFH-020MB | swinging arm, manual, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/14 |
| 25NQFH-20M/SS | swinging arm, manual, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/15 |
| 25NQFH-020M/SS-B | swinging arm, manual, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/16 |
| 25NQFH-030M | swinging pipe, manual, plastic rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/17 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle Type | LPCB Ref. No. |
|-----------------|---|------------------------|-------------------------|-------------|---------------|
| 25NQFH-030MB | swinging pipe, manual, brass rotary nozzle, mild steel reels | 25 | 30 | jet/spray | 1346b/18 |
| 25NQFH-30M/SS | swinging pipe, manual, plastic rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/19 |
| 25NQFH-30M/SS-B | swinging pipe, manual, brass rotary nozzle, stainless steel reels | 25 | 30 | jet/spray | 1346b/20 |

Note:

Hose Reel Approved for use with NLSV-25 Lock Shield Valve to BS 5154

Rapidrop Global Limited

Rutland Business Park, Newark Road, Peterborough PE1 5WA, United Kingdom

Tel: +44 (0)1733 847 510 • Fax: +44 (0)1733 553 958

E-mail: rapidrop@rapidrop.com • Website: www.rapidrop.com

Certificate No: 566g to EN 671-1:2012

'Rapidrop' Fire Hose Reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| Fig401 | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 566g/01 |
| Fig402 | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 566g/02 |
| Fig403 | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 566g/03 |
| Fig404 | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 566g/04 |
| Fig405 | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 566g/05 |

Ras Al Khaimah Fire Fighting Equipment Factory Fire King L.L.C

Wiz 07/12 Rakia Warehouse, Industrial Zone, Al Jazeera Al Hamra, Ras Al Khaimah, United Arab Emirates

Tel: +97172437050 • Fax: +97172437040

E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1092Fd to EN 671-1

FIRE KING Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|-----------------------------------|------------------------|-------------------------|-----------------------|---------------|
| FKSA19 | Swinging, automatic, wall mounted | 19 | 30 | Rotary operated spray | 1092Fd/03 |
| FKSM19 | Swinging, manual, wall mounted | 19 | 30 | Rotary operated spray | 1092Fd/04 |
| FKSA25 | Swinging, automatic, wall mounted | 25 | 30 | Rotary operated spray | 1092Fd/07 |
| FKSM25 | Swinging, manual, wall mounted | 25 | 30 | Rotary operated spray | 1092Fd/08 |

PART 2: SECTION 3

FIRE HOSE REELS

Sanal Srl

Viale Emilia 23, Catanzaro 88100, Italy

Tel: +39 0961 62404 • Fax: +39 0961 62404

E-mail: info@sanalitalia.com • Website: <http://www.sanalitalia.com/>

Certificate No: 1038Va to EN 671-1

S&L Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|--|-------------------------------|--------------------------------|--|----------------------|
| SNL30M-A | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Va/02 |
| SNL-10-B | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Va/03 |
| SNL-06-B | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Va/04 |
| SNL-01-B | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038Va/05 |
| SNL-04-B | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Va/14 |

Sentura Group (including FireDepot)

Sentura House, 3 Lands End Way, Oakham, Rutland LE15 6RB, United Kingdom

Tel: +44 (0)330 999 22 33 • Fax: +44 (0)1572 770133

E-mail: sales@firedepot.co.uk • Website: www.firedepot.co.uk

Certificate No: 1093d to EN 671-1:2012

FIRECHIEF REELMAX Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|-----------------------------------|-------------------------------|--------------------------------|-----------------------|----------------------|
| RMFA19 | Fixed, automatic, wall mounted | 19 | 30 | Rotary operated spray | 1093d/01 |
| RMFM19 | Fixed, manual, wall mounted | 19 | 30 | Rotary operated spray | 1093d/02 |
| RMSA19 | Swinging, automatic, wall mounted | 19 | 30 | Rotary operated spray | 1093d/03 |
| RMSM19 | Swinging, manual, wall mounted | 19 | 30 | Rotary operated spray | 1093d/04 |
| RMFA25 | Fixed, automatic, wall mounted | 25 | 30 | Rotary operated spray | 1093d/05 |
| RMFM25 | Fixed, manual, wall mounted | 25 | 30 | Rotary operated spray | 1093d/06 |
| RMSA25 | Swinging, automatic, wall mounted | 25 | 30 | Rotary operated spray | 1093d/07 |
| RMSM25 | Swinging, manual, wall mounted | 25 | 30 | Rotary operated spray | 1093d/08 |

Shanghai Huiying Industry Co Ltd

Room 1313, Tower A, 1088 New Jinqiao Road, 201206, Shanghai, China

Tel: +86 21 61681700 • Fax: +86 21 61681701

E-mail: sales@pike-fire.com • Website: www.pike-fire.com

Certificate No: 1038Fa to BS EN 671-1

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (mm) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|--------------------------|--|---------------|
| PKHR-001 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Fa/01 |
| PKHR-002 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Fa/02 |
| PKHR-003 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Fa/03 |
| PKHR-004 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Fa/04 |

Certificate No: 1038Na to BS EN 671-1

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| MOSHR-07 | Manual, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Na/02 |
| MOSHR-06 | Automatic, swinging arm, cabinet or wall mounted, lever and rotary operated nozzle variants. | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Na/04 |

Note:

Fire hose reels prefixed MOSHR are branded 'MOSAFE'

Shanghai Iron Man Fire Fighting Equipment Co., Ltd.

Room 716, 7F No. 100, Xiuyan Road, Shanghai 201315, China

Tel: +86-21-68062016 • Fax: +86-21-68062016-307

E-mail: sales@ironman-safety.com • Website: www.firefightingtool.com

Certificate No: 1038AFa to EN 671-1:2012

'IMSECUR' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| IMHR-08-A | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/01 |
| IMHR-07-B | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/02 |
| IMHR-10-B | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/03 |
| IMHR-06-B | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/04 |
| IMHR-01-B | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038AFa/05 |
| IMHR-02-A | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/06 |
| IMHR-02-B | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/07 |
| IMHR-12-A | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/08 |
| IMHR-13-A | Automatic, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/09 |
| IMHR-14-A | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/10 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| IMHR-15-A | Automatic, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/11 |
| IMHR-01-A | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/12 |
| IMHR-04-A | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/13 |
| IMHR-04-B | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AFa/14 |

Somati FIE NV

Industrielaan 19a, B-9320 Erembodegem, Belgium

Tel: +32 (0)53 85 22 22 • Fax: +32 (0)53 85 22 21

E-mail: info@somatifie.be • Website: <http://www.somatifie.be/>

Certificate No: 1038Za to EN 671-1:2012

SANILITE Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| SANILITE 20S | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Za/01 |
| SANILITE 30S | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Za/02 |
| SANILITE 20F | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Za/06 |
| SANILITE 30F | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038Za/07 |

Suzhou HLC Plastics Industry Co. Ltd

No. 103 Fengbeidang Road, Beiqiao Block, Xiangcheng District, Suzhou, China

Tel: +86 512 65366918 • Fax: +86 512 65360646

E-mail: info@suzhou-csj.com • Website: www.suzhou-csj.com

Certificate No: 1038a to EN 671-1

Fire hose reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|---------------------|---|-------------------------------|--------------------------------|--|----------------------|
| CSJR-08-A | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet / spray | 1038a/01 |
| CSJR-07-B | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet / spray | 1038a/02 |
| CSJR-10-B | Automatic, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet / spray | 1038a/03 |
| CSJR-06-B | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet / spray | 1038a/04 |
| CSJR-01-B | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038a/05 |
| CSJR-02-A | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/06 |
| CSJR-02-B | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/07 |
| CSJR-12-A | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/08 |
| CSJR-13-A | Automatic, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/09 |
| CSJR-14-A | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/10 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| CSJR-15-A | Automatic, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/11 |
| CSJR-01-A | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/12 |
| CSJR-04-A | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/13 |
| CSJR-04-B | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/14 |
| CSJR-02-C | Automatic, fixed, wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/17 |
| CSJR-04-D | Automatic, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038a/18 |

Certificate No: 1038a to EN 671-1

Fire Hose Reel Cabinets

| Product Name | Description | LPCB Ref. No. |
|-----------------|---|---------------|
| CSJC-01-B/C | Single glazed door, surface mounted hose reel cabinet | 1038a/15 |
| CSJC-02-B/C/D | Single door, surface mounted hose reel cabinet | |
| CSJC-04-A/B | Single glazed door, surface mounted hose reel cabinet | |
| CSJC-05-A/B/C/D | Single door, surface mounted hose reel cabinet | |
| CSJC-06-A/B/C/D | Single door, recessed hose reel cabinet | |

Certificate No: 1038a to EN 671-1

Fire Hose Reel Cabinets

| Product Name | Description | LPCB Ref. No. |
|---------------|--|---------------|
| CSJC-03-A/B | Double door, surface mounted hose reel cabinet | 1038a/16 |
| CSJC-09-A/B/C | Double door, surface mounted, vertical hose reel cabinet | |
| CSJC-10-A/B/C | Double door, recessed, vertical hose reel cabinet | |

Certificate No: 1038c to EN 671-1:2012

Fire Hose Reel

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|---------------------------|---------------|
| MBK-1925F | Manual, swinging door, cabinet mounted | 19 | 25 | Rotary operated jet/spray | 1038c/01 |
| MBK-1930F | Manual, swinging door, cabinet mounted | 19 | 30 | Rotary operated jet/spray | |

UNIFIRE MIDDLE EAST FZC

P.O. Box 514783, Saif Zone Sharjah, , United Arab Emirates

Tel: +971 562528557

E-mail: sales@unifire.me • Website: www.unifireme.com

Certificate No: 1038AKa to EN 671-1:2012

'UNIFIRE' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| UNFR-06-B | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AKa/04 |

PART 2: SECTION 3

FIRE HOSE REELS

Unisafe Fire Protection Specialists LLC

P.O.Box 117579, Ras Al Khor, Al Aweer Industrial Estate, Dubai, United Arab Emirates

Tel: +971 4 3339977 • Fax: +971 4 3339358

Website: www.unisafedxb.com

Certificate No: 1092Dd to EN 671-1

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|-----------------------|---------------|
| AHR19-01 | Fixed, automatic, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092Dd/01 |
| MHR19-01 | Fixed, manual, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092Dd/02 |
| AHR19-02 | Swinging, automatic, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092Dd/03 |
| MHR19-02 | Swinging, manual, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092Dd/04 |
| AHR25-01 | Fixed, automatic, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092Dd/05 |
| MHR25-01 | Fixed, manual, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092Dd/06 |
| AHR25-02 | Swinging, automatic, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092Dd/07 |
| MHR25-02 | Swinging, manual, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092Dd/08 |

VALMECA MAROC S.A.R.L.

6 Bd Al Imam Allait Ibn Saad, Al Quods, Sidi Bernoussi, Casablanca, Morocco

Tel: +212 6 65 07 57 52 • Fax: +212 5 22 75 62 62

E-mail: valmeca.maroc@gmail.com

Certificate No: 1038A1a to EN 671-1:2012

'VM' Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| VM002C | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038A1a/02 |
| VM001 | Manual, swinging arm, wall mounted | 33 | 30 | Rotary operated jet/spray | 1038A1a/05 |
| VM002 | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038A1a/10 |
| VM002A | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038A1a/12 |
| VM002B | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038A1a/14 |

Watania For Advanced Systems

7 Amin Abu Zeid Street, Saba Basha, Alexandria, , Egypt

Tel: +2 (03) 5857668 • Fax: +2 (03) 5857668

E-mail: info@adsystems.info • Website: <http://www.adsystems.info/>

Certificate No: 1038AEa to EN 671-1:2012

Advanced Systems Fire Hose Reel

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| ADSYS-5000 | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038AEa/02 |

Watania For Modern Industries

603 El Horreya Avenue, Zezenia, Alexandria, Egypt

Tel: +203 5758008 • Fax: +203 5758544

E-mail: watania@wataniagroup.com • Website: <http://www.wataniagroup.com/>

Certificate No: 1038ACa to EN 671-1:2012

WATANIA Fire Hose Reel

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|--|---------------|
| WMIFHR | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038ACa/02 |

Watex Pumps Industries

D8, New Industrial Area, Amman Street, Ajman, United Arab Emirates

Tel: +971 552148105

E-mail: info@watexindustries.com • Website: www.watexindustries.com

Certificate No: 1038ABa to EN 671-1:2012

WATEX Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| WMH-25MM | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038ABa/02 |
| WAH-25MM | Automatic, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1038ABa/04 |

Yuyao Tianbo Fire Fighting Equipment Co., Ltd.

Baishuicong Industrial Park, Lianglong Town, Yuyao City, Zhejiang, China

Tel: +86-21-61602389 • Fax: +86-21-61602389 ext. 805

E-mail: export@yitianbo.cn • Website: www.yitianbo.cn

Certificate No: 1092d to EN 671-1:2012

'TIANBO' Fire Hose Reels

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|-----------------------|---------------|
| FA19 | Fixed, automatic, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092d/01 |
| FM19 | Fixed, manual, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092d/02 |
| SA19 | Swinging, automatic, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092d/03 |
| SM19 | Swinging, manual, wall mounted, rotary operated nozzle | 19 | 30 | Rotary operated spray | 1092d/04 |
| FA25 | Fixed, automatic, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092d/05 |

PART 2: SECTION 3

FIRE HOSE REELS

| Product Name | Description | Hose nominal bore (mm) | Hose maximum length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---|------------------------|-------------------------|-----------------------|---------------|
| FM25 | Fixed, manual, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092d/06 |
| SA25 | Swinging, automatic, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092d/07 |
| SM25 | Swinging, manual, wall mounted, rotary operated nozzle | 25 | 30 | Rotary operated spray | 1092d/08 |

Yuyao Tianning Fire Control Equipment Co., Ltd.

Ganxuan Village, Liangnong Town, Yuyao City, China

Tel: 0086 13588574423 • Fax: 0086-574-62357038

E-mail: shanling@outlook.com; shanling1@foxmail.com • Website: www.tntqxf.com

Certificate No: 1364b to EN 671-1:2012

'TenNeed' Fire Hose Reels to EN 671-1:2012

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|--|------------------------|-------------------------|--|---------------|
| TN04-D-03B | Manual, swinging arm, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1364b/01 |
| TN04-D-03A | Manual, swinging arm, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1364b/02 |
| TN04-D-08B | Manual, swinging pipe, cabinet or wall mounted | 19 | 30 | Lever operated jet only or rotary operated jet/spray | 1364b/03 |
| TN04-D-08A | Manual, swinging pipe, cabinet or wall mounted | 25 | 30 | Lever operated jet only or rotary operated jet/spray | 1364b/04 |

Certificate No: 1364b to EN 671-1:2012

TenNeed' Fire Hose Reel Cabinets

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| TN04-C-02A | Single door, surface mounted hose reel cabinet | 1364b/05 |
| TN04-C-02B | Single door, surface mounted hose reel cabinet | |

Zener Security & Safety Equipments

Souq Najd Building, Entrance No. 5, 1st Floor, Doha, Qatar

Tel: +974 44370933 • Fax: +974 44370691

E-mail: info@zenerqatar.com • Website: http://www.zenerqatar.com/

Certificate No: 1153Ca to EN 671-1:2012

Zenér Fire Hose Reels

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|--------------|---------------------------------------|------------------------|-------------------------|--------------------------|---------------|
| ZS10-HRA-00 | Automatic, swinging arm, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Ca/01 |
| ZS10-HRM-00 | Manual, fixed, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Ca/02 |
| ZS10-HRA1-00 | Automatic, swinging arm, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Ca/03 |
| ZS10-HRM1-00 | Manual, fixed, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Ca/04 |
| ZS10-HRM2-00 | Manual, swinging arm, wall mounted | 25 | 30 | Lever operated jet/spray | 1153Ca/05 |
| ZS10-HRM3-00 | Manual, swinging arm, wall mounted | 19 | 30 | Lever operated jet/spray | 1153Ca/06 |

PART 2: SECTION 4

FIRE BLANKETS

Fire blankets can be used to suppress or extinguish small fires in kitchens, laboratories and workshops and are a useful means of protection.. They should be located in the vicinity of the fire hazard on which they are intended to be used and in a position where they can be safely accessed. Light duty blankets are suitable for kitchens and laboratory areas where fires tend to be smaller and contained, e.g. cooking oils.

EN 1869 specifies requirements for non re-usable fire blankets that are intended for use by one person. The standard applies to fire blankets primarily intended for extinguishing cooking oil type fires. The standard specifies several tests that a fire blanket must successfully undergo, which include: fire tests, a removal and unfolding test and an electrical resistance test.

The materials used in the manufacture of a fire blanket must be heat resisting and non-flammable yet flexible enough to maintain a seal with the vessel on fire so that the oxygen supply is removed. The heat resistance of the fire blanket must also be maintained whilst the heat source is turned off and the heat is allowed to lower with the vessel remaining in-situ until the vessel is safe to be removed.

It is recommended that the blanket has been regularly inspected as part of any risk assessment or safety inspections. A fire blanket notice should be placed near the blanket giving basic guidance on how to use the blanket in an emergency.

Always follow manufacturer's use, installation and servicing instructions and replace after use.

This section lists products approved in accordance with:

EN 1869:1997 *Fire blankets*

Changshu Jiangnan Glass Fiber Co., Ltd.

No. 19 Xiangyang Road, Haiyu Town, Changshu, Jiangsu 215519, China

Tel: +86-512-52560588 / +86-512-52561146 • Fax: +86-512-52565400

E-mail: zhi6739@jn-fiber.cn / zhang1146@jn-fiber.cn • Website: www.jn-grt.com

Certificate No: 1434a to EN 1869:1997

CS08 Fire Blanket

| Product Name | Dimensions (m) | LPCB Ref. No. |
|--------------------|----------------|---------------|
| CS08 (1.2m x 1.2m) | 1.2 x 1.2 | 1434a/01 |
| CS08 (1.2m x 1.8m) | 1.2 x 1.8 | |
| CS08 (1.5m x 1.8m) | 1.5 x 1.8 | |

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300 • Fax: +971 6 5340090

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 863b to BS EN 1869

Fire Blankets

| Product Name | Dimensions (m) | LPCB Ref. No. |
|--------------|----------------|---------------|
| FB4 | 1.2 x 1.2 | 863b/01 |
| FB6 | 1.2 x 1.8 | |

Eversafe Extinguisher Sdn Bhd

Lot 878, Jalan Subang 9, Taman Perindustrian Subang, 47500 Subang Jaya, Selangor Darul Ehsan, Malaysia

Tel: +603 8024 9898 • Fax: +603 8024 7878

E-mail: info@eversafe.net • Website: www.eversafe.net

Certificate No: 1434Ba to EN 1869:1997

Fire Blankets

| Product Name | Dimensions (m) | LPCB Ref. No. |
|--------------|----------------|---------------|
| FB22 | 1.2 x 1.2 | 1434Ba/01 |
| FB28 | 1.2 x 1.8 | |
| FB58 | 1.5 x 1.8 | |

Notes:

1. Available as brand name – 'EVERSAFE'
2. Available as brand name – 'FireSafe'
3. Available as brand name – 'Red Panther'

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111 • Fax: +971 48151222

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463c to EN 1869

Fire Blankets

| Product Name | Dimensions (m) | LPCB Ref. No. |
|---------------|----------------|---------------|
| Model NFB 1.2 | 1.1 x 1.1 | 463c/03 |
| Model NFB 1.4 | 1.2 x 1.2 | |
| Model NFB 2.1 | 1.2 x 1.8 | |

Note:

Material Ref: NF/MDS-FB/2016, Revision 05, dated 22 November 2016. Top and bottom push insert type container.

Ningbo Siterwell Electronics Co., Ltd.

76 Haichuan Road, Chuangye Zone B, Jiangbei, Ningbo, Zhejiang Province 315032, China

Tel: 0086-574-8307 6161 • Fax: 0086-574-8307 6652

E-mail: sales@china-siter.com • Website: www.china-siter.com

Certificate No: 1044b to EN 1869

| Product Name | Dimensions (m) | LPCB Ref. No. |
|--------------|----------------|---------------|
| GS409 | 1.1 x 1.1 | 1044b/01 |
| GS410 | 1.2 x 1.2 | |
| GS411 | 1.2 x 1.8 | |

PART 2: SECTION 4

FIRE BLANKETS

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar

Tel: +974 4402 5888 • Fax: +974 4411 4630

E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346c to EN 1869

Fire Blankets

| Product Name | Dimensions (m) | LPCB Ref. No. |
|---------------------|-----------------------|----------------------|
| Model NQFB 1.2 | 1.1 x 1.1 | 1346c/01 |
| Model NQFB 1.4 | 1.2 x 1.2 | 1346c/02 |
| Model NQFB 2.1 | 1.2 x 1.8 | 1346c/03 |

Note:

Material Ref: NF/MDS-FB/2016, Revision 05, dated 22 November 2016. Top and bottom push insert type container.

Wet Riser

A Wet Riser is a system of pipe-work and valves which is kept permanently 'charged' by a dedicated pump supplying clean water on demand on each floor of a building and is typically used on larger, high rise buildings. The system components must be regularly maintained to prevent leaks, corrosion and loss of adequate pressure. Landing valves that are used as part of a wet riser system are tested to BS 5041-1.

Dry Riser

A Dry Riser inlet is permanently connected to an 'uncharged' water pipe system that is installed within protected service 'riser' shaft within the building, often this is the protected escape staircase enclosures. The inlet breeching of a dry riser system is suitably located within a protective box or 'cabinet' for dry riser inlets on the ground floor to enable the fire and rescue service to connect layflat hose to a suitable water supply, allowing water to be pumped from the fire appliance pump up to higher floors or to where there are extensive distances from an entrance. Inlet breechings are tested to BS 5041-3 and the dry riser box for riser inlets are tested to BS 5041-5.

Underground Fire Hydrant

An underground fire hydrant is typically located within a surface box fitted with a cover. Underground fire hydrants and surface box frames and covers are tested to BS 750. The cover of the surface box is often but not always painted in a prominent colour to assist with fast location by fire service personnel. A notice identifying the location of the hydrant is also normally fitted in an adjacent position; in most jurisdictions it is illegal to park a car within a certain distance of a fire hydrant.

Pillar fire hydrants consist of one or more valves and connection outlets in a column shape, which emerges from below ground level, intended primarily to supply water for firefighting and also may be used by water utilities. Pillar fire hydrants are tested to EN 14384.

These hydrants are often provided by the owner/operator of larger developments and the responsibility for the supply of water rests with this organisations responsible person, whilst publicly located hydrants are provided and maintained by the civic authorities. Regular maintenance is required to remove dirt and debris, prevent seizure of the valve, to maintain a clean water supply and to ensure easy removal of the protective cover.

A layflat high pressure hose is attached to the hydrant via a standpipe installed after removal of the surface box cover and the water is delivered by turning a hydrant key which is connected to the hydrant by fire service personnel. The layflat hose connected to the standpipe may be used to supply water directly onto the fire by connecting further lengths of hose and using a branch or nozzle to control the water at the point of delivery. It may also be used to connect the water supply to a fire pump that is transported to the location by the fire service in order to increase the delivered water pressure further. The supply may be split into multiple hoses to distribute the water as required. This water supply can then be connected to a dry riser inlet(s) if required.

For guidance on design and installation of wet and dry riser systems, refer to BS 9990:2006 *Code of practice for non-automatic fire fighting systems in buildings*. This standard covers good practice in matters affecting the design, installation, testing and maintenance of non-automatic fire fighting systems in buildings. Further information is also available in BS 9999:2008 *Code of practice for fire safety in the design, management and use of buildings*.

This section lists products approved in accordance with:

| | |
|-----------------|--|
| BS 5041-1:1987 | <i>Fire hydrant systems equipment. Specification for landing valves for wet risers</i> |
| BS 5041-3:1975 | <i>Fire hydrant systems equipment. Specification for inlet breechings for dry riser inlets</i> |
| EN 694:2001 | <i>Requirements for Fire-fighting hoses - semi-rigid hoses for fixed systems</i> |
| BS 6391:2009 | <i>Requirements for non-percolating layflat delivery hoses and hose assemblies for fire fighting purposes.</i> |
| BS 5041-5: 1974 | <i>Fire hydrant systems equipment. Specification for boxes for foam inlets and dry riser inlets</i> |
| BS 750:2006 | <i>Specification for underground fire hydrants and surface box frames and covers</i> |
| EN 14384:2005 | <i>Pillar fire hydrants</i> |
| BS 336:2010 | <i>Specification for fire hose couplings and ancillary equipment</i> |

PART 2: SECTION 5.1

LANDING VALVES

Landing valves are listed as follows:-

Wet landing valves - Section 5.1.1

Dry landing valves - Section 5.1.2

Wet landing valves are located at discharge points, typically on the upper floors of a taller building, where the supply of water is via a permanently charged or 'wet riser' water supply. Layflat hoses are coupled into the valve to supply water to the location of the fire. The valve is normally located within an easily accessible, protective and approved box or 'cabinet' to prevent damage, dust and rubbish collection.

This section lists products approved in accordance with:

BS 5041-1:1987 *Fire hydrant systems equipment. Specification for landing valves for wet risers*

Dafoos Fire Protection Equipment Trading Est.

PO Box 50891, Warehouse No. 51, Al Quoz 4, Dubai, United Arab Emirates

Tel: +971-43402020 • Fax: +971-43471390

E-mail: dafoos@dafoos.com • Website: www.dafoos.com

Certificate No: 1153Ge to BS 5041-1:1987

'SPARTAN' Wet Landing Valves

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| DFP-LVL-F001 | DN65 flanged inlet, oblique type, low pressure | 1153Ge/02 |
| DFP-LVL-M001 | 2 ½" BSPT male threaded inlet, oblique type, low pressure | 1153Ge/04 |
| DFP-LVL-F002 | DN65 flanged inlet, bib nosed type, low pressure | 1153Ge/13 |

Notes:

The maximum working pressure is 15 bar for low pressure landing valves

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300 • Fax: +971 6 5340090

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 863e to BS 5041-1

| Product Name | Landing valve description | LPCB Ref. No. |
|--------------|--|---------------|
| APDR-65-ST | 2½" PN16, oblique, screwed inlet, low pressure | 863e/01 |
| APDR-65-FT | 2½" PN16, oblique, flanged inlet, low pressure | 863e/02 |

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building 738471, Singapore

Tel: +65 6759 4163 • Fax: +65 6758 7513

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501c to BS 5041-1

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| LV-DR25 | 2½" PN16, oblique, screwed inlet, low pressure | 501c/01 |
| LV-OF25 | 2½" PN16, oblique, flanged inlet, low pressure | 501c/02 |
| LV-RA25 | 2½" PN16, right angle, screwed inlet, low pressure | 501c/03 |
| LV-RAF25 | 2½" PN16, right angle, flanged inlet, low pressure | 501c/04 |
| LV-HS25 | 2½" PN16, horizontal, screwed inlet, low pressure | 501c/05 |
| LV-HF25 | 2½" PN16, horizontal, flanged inlet, low pressure | 501c/06 |
| LV-BNS25 | 2½" PN16, bib nosed, screwed inlet, low pressure | 501c/07 |

PART 2: SECTION 5.1.1

WET LANDING VALVES

| Product Name | Description | LPCB Ref. No. |
|---------------------|--|----------------------|
| LV-BNF25 | 2½" PN16, bib nosed, flanged inlet, low pressure | 501c/08 |
| DH6l screw | 2½", bib nosed, screwed inlet, high pressure | 501c/09 |
| DH6l flange | 2½", bib nosed, flange inlet, high pressure | 501c/10 |

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete 73136, Greece

Tel: +30 282 10 63222 • Fax: +30 282 10 66260

E-mail: sales@mobiak.gr • Website: <http://www.mobiak.gr>

Certificate No: 1153Ae to BS 5041-1:1987

'MOBIAK' Wet Landing Valves

| Product Name | Description | LPCB Ref. No. |
|---------------------|---|----------------------|
| MBK06-198A-00 | DN50 flanged inlet, oblique type, low pressure | 1153Ae/01 |
| MBK06-198A1-00 | DN65 flanged inlet, oblique type, low pressure | 1153Ae/02 |
| MBK06-198B-00 | 2 ½" BSP female threaded inlet, oblique type, low pressure | 1153Ae/03 |
| MBK06-198B1-00 | 2 ½" BSPT male threaded inlet, oblique type, low pressure | 1153Ae/04 |
| MBK06-198C-00 | DN50 flanged inlet, right angle type, low pressure | 1153Ae/05 |
| MBK06-198C1-00 | DN65 flanged inlet, right angle type, low pressure | 1153Ae/06 |
| MBK06-198D1-00 | 2 ½" BSPT male threaded inlet, right angle type, low pressure | 1153Ae/07 |
| MBK06-200A1-00 | 2 ½" BSPT male threaded inlet, horizontal type, low pressure | 1153Ae/08 |
| MBK06-200B-00 | DN50 flanged inlet, horizontal type, low pressure | 1153Ae/09 |
| MBK06-200B1-00 | DN65 flanged inlet, horizontal type, low pressure | 1153Ae/10 |
| MBK06-200C1-00 | 2 ½" BSPT male threaded inlet, bib nosed type, low pressure | 1153Ae/11 |
| MBK06-200D-00 | DN50 flanged inlet, bib nosed type, low pressure | 1153Ae/12 |
| MBK06-200D1-00 | DN65 flanged inlet, bib nosed type, low pressure | 1153Ae/13 |
| MBK06-199A-00 | DN50 flanged inlet, bib nosed type, high pressure | 1153Ae/14 |
| MBK06-199A1-00 | DN65 flanged inlet, bib nosed type, high pressure | 1153Ae/15 |
| MBK06-199B-00 | 2 ½" BSPT male threaded inlet, bib nosed type, high pressure | 1153Ae/16 |

Notes:

1. The maximum working pressure is 15 bar for low pressure landing valves
2. The maximum working pressure is 20 bar for high pressure landing valves

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111 • Fax: +971 48151222

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463e to BS 5041-1

| Product Name | Description | LPCB Ref. No. |
|---------------------|---|----------------------|
| NDR 098 | 2.5 inch wet landing valve, low pressure (1), oblique type with flanged inlet | 463e/01 |

Notes:

- 1) Maximum working pressure is 15 bar.

Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Wu Che Yan, Yuyao City, Zhejiang Province, China

Tel: +86 574 62025710 • Fax: +86 574 62025711

E-mail: info@jintianfire.com • Website: www.jintianfire.com

Certificate No: 1153e to BS 5041-1

Wet Landing Valves

| Product Name | Description | LPCB Ref. No. |
|---------------|---|---------------|
| KX06-198A-00 | DN50 flanged inlet, oblique type, low pressure | 1153e/01 |
| KX06-198A1-00 | DN65 flanged inlet, oblique type, low pressure | 1153e/02 |
| KX06-198B-00 | 2 ½" BSP female threaded inlet, oblique type, low pressure | 1153e/03 |
| KX06-198B1-00 | 2 ½" BSPT male threaded inlet, oblique type, low pressure | 1153e/04 |
| KX06-198C-00 | DN50 flanged inlet, right angle type, low pressure | 1153e/05 |
| KX06-198C1-00 | DN65 flanged inlet, right angle type, low pressure | 1153e/06 |
| KX06-198D1-00 | 2 ½" BSPT male threaded inlet, right angle type, low pressure | 1153e/07 |
| KX06-200A1-00 | 2 ½" BSPT male threaded inlet, horizontal type, low pressure | 1153e/08 |
| KX06-200B-00 | DN50 flanged inlet, horizontal type, low pressure | 1153e/09 |
| KX06-200B1-00 | DN65 flanged inlet, horizontal type, low pressure | 1153e/10 |
| KX06-200C1-00 | 2 ½" BSPT male threaded inlet, bib nosed type, low pressure | 1153e/11 |
| KX06-200D-00 | DN50 flanged inlet, bib nosed type, low pressure | 1153e/12 |
| KX06-200D1-00 | DN65 flanged inlet, bib nosed type, low pressure | 1153e/13 |
| KX06-199A-00 | DN50 flanged inlet, bib nosed type, high pressure | 1153e/14 |
| KX06-199A1-00 | DN65 flanged inlet, bib nosed type, high pressure | 1153e/15 |
| KX06-199B-00 | 2 ½" BSPT male threaded inlet, bib nosed type, high pressure | 1153e/16 |

Notes:

The maximum working pressure is 15 bar for low pressure landing valves
The maximum working pressure is 20 bar for high pressure landing valves

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar

Tel: +974 4402 5888 • Fax: +974 4411 4630

E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346f to BS 5041-1

Wet Landing Valves

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| NDR 098 | 2.5 inch wet landing valve, low pressure (1), oblique type with flanged inlet | 1346f/01 |

Note:

- 1) Maximum working pressure is 15 bar.

Shanghai Firetech Co. Ltd.

Room 401, Building No. 23, No. 1288 Pujian Road, Pudong District, Shanghai, China

Tel: +86 13917676168 • Fax: +86 21 68453005

E-mail: info@firetechsh.com • Website: www.firetechsh.com

Certificate No: 1153le to BS 5041-1:1987

'FIRETECH' Wet Landing Valves

| Product Name | Description | LPCB Ref. No. |
|---------------|---|---------------|
| FT06-198A-00 | DN50 flanged inlet, oblique type, low pressure | 1153le/01 |
| FT06-198A1-00 | DN65 flanged inlet, oblique type, low pressure | 1153le/02 |
| FT06-198B-00 | 2 ½" BSP female threaded inlet, oblique type, low pressure | 1153le/03 |
| FT06-198B1-00 | 2 ½" BSPT male threaded inlet, oblique type, low pressure | 1153le/04 |
| FT06-198C-00 | DN50 flanged inlet, right angle type, low pressure | 1153le/05 |
| FT06-198C1-00 | DN65 flanged inlet, right angle type, low pressure | 1153le/06 |
| FT06-198D1-00 | 2 ½" BSPT male threaded inlet, right angle type, low pressure | 1153le/07 |
| FT06-200A1-00 | 2 ½" BSPT male threaded inlet, horizontal type, low pressure | 1153le/08 |
| FT06-200B-00 | DN50 flanged inlet, horizontal type, low pressure | 1153le/09 |
| FT06-200B1-00 | DN65 flanged inlet, horizontal type, low pressure | 1153le/10 |
| FT06-200C1-00 | 2 ½" BSPT male threaded inlet, bib nosed type, low pressure | 1153le/11 |
| FT06-200D-00 | DN50 flanged inlet, bib nosed type, low pressure | 1153le/12 |
| FT06-200D1-00 | DN65 flanged inlet, bib nosed type, low pressure | 1153le/13 |

PART 2: SECTION 5.1.1

WET LANDING VALVES

| Product Name | Description | LPCB Ref. No. |
|---------------------|--|----------------------|
| FT06-199A-00 | DN50 flanged inlet, bib nosed type, high pressure | 1153le/14 |
| FT06-199A1-00 | DN65 flanged inlet, bib nosed type, high pressure | 1153le/15 |
| FT06-199B-00 | 2 ½" BSPT male threaded inlet, bib nosed type, high pressure | 1153le/16 |

Notes:

1. The maximum working pressure is 15 bar for low pressure landing valves
2. The maximum working pressure is 20 bar for high pressure landing valves

Shaoxing Jia Sheng Fire Fighting Equipment Co. Limited

No 30, Zijin Road, Tianjia Industrial Zone, Xiaoyue Town, Shangyu District, Shaoxing City, Zhejiang Province 312367, China

Tel: +86-575-82039618 • Fax: +86-575-82032872

E-mail: rachel.yan@jsfire.com.cn • Website: www.jsfire.com.cn

Certificate No: 1366a to BS 5041-1:1987

Wet Landing Valves

| Product Name | Description | LPCB Ref. No. |
|---------------------|--|----------------------|
| JS02.002.13Q | 2 ½" BSPT male screwed inlet, oblique type, low pressure | 1366a/01 |
| JS02.002.14Q | 2 ½" BSPT male screwed inlet, oblique type, low pressure | 1366a/02 |
| JS02.002.16Q | DN65 flanged inlet, oblique type, low pressure | 1366a/03 |
| JS02.002.18Q | DN65 flanged inlet, right-angle type, low pressure | 1366a/04 |
| JS02.002.19Q | DN65 flanged inlet, horizontal type, low pressure | 1366a/05 |
| JS02.002.56 | 2 ½" BSPT female screwed inlet, oblique type, low pressure | 1366a/06 |

Note:

The maximum working pressure is 15 bar

Dry landing valves comprise of a valve and outlet connection from a dry riser which are typically an uncharged pipe system installed within a building. The landing valves are located at discharge points typically on higher floors of buildings or harder to reach areas.

This section lists products approved in accordance with:

BS 5041-2:1987 *Fire hydrant systems equipment. Specification for landing valves for dry risers.*

PART 2: SECTION 5.2

INLET BREECHINGS

Dry riser inlets are permanently connected to 'uncharged' water pipe systems that are installed within protected service 'riser' shafts within the building. The inlet breeching is suitably located on the ground floor to enable the fire and rescue service to connect hoses to a suitable water supply allowing water to be pumped up to higher floors. Flexible hoses are connected to control valves located adjacent to the fire zone and valves are located on each upper floor providing a source of water adjacent to the fire risk location. Normal working pressure will be stated with the listing.

This section lists products approved in accordance with:

BS 5041-3:1975 *Fire hydrant systems equipment. Specification for inlet breechings for dry riser inlets*

Dafoos Fire Protection Equipment Trading Est.

PO Box 50891, Warehouse No. 51, Al Quoz 4, Dubai, United Arab Emirates

Tel: +971-43402020 • Fax: +971-43471390

E-mail: dafoos@dafoos.com • Website: www.dafoos.com

Certificate No: 1153Gd to BS 5041-3:1975

'SPARTAN' Inlet Breechings

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| DFP-BI-04 | 4 way inlet breeching, 150mm flanged outlet | 1153Gd/01 |
| DFP-BI-02 | 2 way inlet breeching, 100mm flanged outlet | 1153Gd/02 |

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300 • Fax: +971 6 5340090

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 863d to BS 5041-3

Inlet Breechings

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| APDR2-100-BI | 2 way inlet breeching, 100mm flanged outlet | 863d/01 |
| APDR4-150-BI | 4 way inlet breeching, 150mm flanged outlet | 863d/02 |

Note:

1. Normal working pressure is 16 bar

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building 738471, Singapore

Tel: +65 6759 4163 • Fax: +65 6758 7513

E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501d to BS 5041-3

Inlet Breechings

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| DR 095 | 2 way inlet breeching, 100 mm flanged outlet | 501d/01 |
| WR 115 | 4 way inlet breeching, 150 mm flanged outlet | 501d/02 |

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete 73136, Greece

Tel: +30 28210 63222 • Fax: +30 28210 66260

E-mail: sales@mobiak.gr • Website: http://www.mobiak.gr

Certificate No: 1153Ad to BS 5041-3:1975

'MOBIAK' Inlet Breechings

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| MBK08-203-00 | 4 way inlet breeching, 150mm flanged outlet | 1153Ad/01 |
| MBK08-202-00 | 2 way inlet breeching, 100mm flanged outlet | 1153Ad/02 |

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111 • Fax: +971 48151222

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463f to BS 5041-3

| Product Name | Description | LPCB Ref. No. |
|--------------|--------------------------------|---------------|
| NDR 095 | 4 inch x 2 way inlet breeching | 463f/01 |
| NWR 115 | 6 inch x 4 way inlet breeching | 463f/02 |
| NWRX 115 | 6 inch x 4 way inlet breeching | 463f/03 |

Notes:

1) Normal working pressure is 10 bar.

Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Wu Che Yan, Yuyao City, Zhejiang Province, China

Tel: +86 574 62025710 • Fax: +86 574 62025711

E-mail: info@jintianfire.com • Website: www.jintianfire.com

Certificate No: 1153d to BS 5041-3

Inlet breechings

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| KX08-203-00 | 4 way inlet breeching, 150mm flanged outlet | 1153d/01 |
| KX08-202-00 | 2 way inlet breeching, 100mm flanged outlet | 1153d/02 |

Note:

Rating PN 16

PART 2: SECTION 5.2

INLET BREECHINGS

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar

Tel: +974 4402 5888 • Fax: +974 4411 4630

E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346g to BS 5041-3

Inlet Breechings

| Product Name | Description | LPCB Ref. No. |
|---------------------|--------------------------------|----------------------|
| NDR 095 | 4 inch x 2 way inlet breeching | 1346g/01 |
| NWR 115 | 6 inch x 4 way inlet breeching | 1346g/02 |
| NWRX 115 | 6 inch x 4 way inlet breeching | 1346g/03 |

Note:

- 1) Nominal working pressure is 10 bar.

Shanghai Firetech Co. Ltd.

Room 401, Building No. 23, No. 1288 Pujian Road, Pudong District, Shanghai, China

Tel: +86 13917676168 • Fax: +86 21 68453005

E-mail: info@firetechsh.com • Website: www.firetechsh.com

Certificate No: 1153ld to BS 5041-3:1975

'FIRETECH' Inlet Breechings

| Product Name | Description | LPCB Ref. No. |
|---------------------|---|----------------------|
| FT08-203-00 | 4 way inlet breeching, 150mm flanged outlet | 1153ld/01 |
| FT08-202-00 | 2 way inlet breeching, 100mm flanged outlet | 1153ld/02 |

Shaoxing Jia Sheng Fire Fighting Equipment Co. Limited

No 30, Zijin Road, Tianjia Industrial Zone, Xiaoyue Town, Shangyu District, Shaoxing City, Zhejiang Province 312367, China

Tel: +86-575-82039618 • Fax: +86-575-82032872

E-mail: rachel.yan@jsfire.com.cn • Website: www.jsfire.com.cn

Certificate No: 1366b to BS 5041-3:1975

Inlet Breechings

| Product Name | Description | LPCB Ref. No. |
|---------------------|--|----------------------|
| JS06.002.01A | 2 way inlet breeching, 100 mm flanged outlet | 1366b/01 |
| JS06.002.02B | 4 way inlet breeching, 150 mm flanged outlet | 1366b/02 |

Semi-rigid hose is used as part of a hose reel system typically (but not exclusively) red in colour, round in section and 30 metres in length. The purpose of this type of hose is to provide a steady flow of water quickly as a first response in a fire situation without having to set up lengths of hose from another source. The semi-rigid construction helps to prevent kinks which would restrict supply, is durable and operates in a fairly wide temperature range.

This section lists products approved in accordance with:

EN 694:2001 *Requirements for Fire-fighting hoses - semi-rigid hoses for fixed systems.*

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates
 Tel: +971 4815111 • Fax: +971 48151222
 E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463h to BS EN 694

Semi rigid hoses

| Product Name | Model | LPCB Ref. No. |
|------------------------------------|-----------|---------------|
| Semi rigid hose, 19 mm, colour red | NF-RH-19R | 463h/01 |
| Semi rigid hose, 25mm, colour red | NF-RH-25R | 463h/02 |

Notes:

1) Maximum working pressure is 1.2 MPa

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar
 Tel: +974 4402 5888 • Fax: +974 4411 4630
 E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346i to EN 694

Semi Rigid Hoses

| Product Name | Description | LPCB Ref. No. |
|--------------|-----------------------------------|---------------|
| NQ-RH-25R | Semi rigid hose, 25mm, colour red | 1346i/01 |

Note:

1) Maximum working pressure is 1.2 MPa.

Shaoxing Hongrun Fire Control Equipment Co., Ltd.

No. 16 Zijin Road, Xiaoyue Industrial Zone, Shangyu District, Shaoxing City, Zhejiang Province, China
 Tel: +86-575-82716911 • Fax: +86-575-82713275
 E-mail: mkt-hongrun@hr-fire.com • Website: www.hr-fire.com

Certificate No: 1288a to EN 694:2014

HR Semi-rigid Hose

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| HR01-01-01 | 19mm inside diameter, type A, class 2, red PVC semi-rigid fire hose (1) | 1288a/01 |
| HR01-02-01 | 25mm inside diameter, type A, class 2, red PVC semi-rigid fire hose (1) | 1288a/02 |
| HR01-03-01 | 33mm inside diameter, type A, class 2, red PVC semi-rigid fire hose (2) | 1288a/03 |

PART 2: SECTION 5.3

SEMI RIGID HOSES

Notes:

1. Maximum working pressure is 1.2 MPa (12 bar)
2. Maximum working pressure is 0.7 MPa (7 bar)

Suzhou HLC Plastics Industry Co. Ltd

No. 103 Fengbeidang Road, Beiqiao Block, Xiangcheng District, Suzhou, China

Tel: +86 512 65366918 • Fax: +86 512 65360646

E-mail: info@suzhou-csj.com • Website: www.suzhou-csj.com

Certificate No: 1038b to BS EN 694:2014

CSJ Semi-Rigid Hose

| Product Name | Description | LPCB Ref. No. |
|---------------------|--|----------------------|
| 19mm Fire Hose (1) | Semi rigid hose, 19mm, colour red/black | 1038b/01 |
| 25mm Fire Hose (1) | Semi rigid hose, 25 mm, colour red/black | 1038b/02 |
| 33mm Fire Hose (2) | Semi rigid hose, 33 mm, colour red/black | 1038b/03 |

Notes:

- 1) Maximum working pressure is 1.2 MPa (12 bar)
- 2) Maximum working pressure is 0.7 MPa (7 bar)

Yuyao Tianning Fire Control Equipment Co., Ltd.

Ganxuan Village, Liangnong Town, Yuyao City, China

Tel: 0086 13588574423 • Fax: 0086-574-62357038

E-mail: shanling@outlook.com; shanling1@foxmail.com • Website: www.tntqxf.com

Certificate No: 1364a to EN 694:2014

'TN' Semi-Rigid Hose

| Product Name | Description | LPCB Ref. No. |
|---------------------|-----------------------------------|----------------------|
| TN04-D-08B-08 | Semi rigid hose, 19mm, colour red | 1364a/01 |
| TN04-D-08A-08 | Semi rigid hose, 25mm, colour red | 1364a/02 |

Notes:

1. Maximum working pressure is 1.2 MPa (12 bar)

Layflat hose is typically used by the fire service to convey large quantities of high pressure water to the fire. Lengths of hose may be connected together via couplings and the hose should be flexible, strong, resist kinking, watertight, rot-proof, impervious to chemicals and operate at high pressure and in varying extremes of temperature, the hose must not fail at a critical moment.

To achieve these requirements layflat hose comes in three types.

Type 1 hoses are those to which no external treatments have been applied to the reinforcement and may be liable to absorb liquids and need to be thoroughly dried after use. These types of fire hose are sometimes called conventional hoses.

Type 2 hoses are those to which an external elastomeric coating has been applied to the reinforcement to give some protection against the absorption of liquids and to improve resistance to abrasion of the reinforcement.

Type 3 hoses are those to which an external elastomeric coating or covering has been applied to, or been incorporated within the reinforcement to give the hoses very low absorption of liquids and high resistance to abrasion and heat.

In some countries layflat hose may also be concertinaed in a hanging rack adjacent to a dry riser in a fixed location within a building ensuring a fast and easily available source of large quantities of water. A branch (nozzle) is usually also supplied at this location.

This section lists products approved in accordance with:

BS 6391:2009 *Requirements for non-percolating layflat delivery hoses and hose assemblies for fire fighting purposes.*

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates
 Tel: +971 4815111 • Fax: +971 48151222
 E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463g to BS 6391

Layflat delivery hoses

| Product Name | Model | LPCB Ref. No. |
|--------------|--|---------------|
| NF-DH2 65R | 2.5" Layflat delivery hose , colour red | 463g/01 |
| NF-DH2 65W | 2.5" Layflat delivery hose, colour white | 463g/02 |

Notes:

1) Maximum working pressure is 15 bar.

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar
 Tel: +974 4402 5888 • Fax: +974 4411 4630
 E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346h to BS 6391

Layflat delivery hoses

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| NQF-DH2 65R | 2.5" Layflat delivery hose, colour red | 1346h/01 |
| NQF-DH2 65W | 2.5" Layflat delivery hose, colour white | 1346h/02 |

PART 2: SECTION 5.4

LAYFLAT HOSES

Note:

- 1) Maximum working pressure is 15 bar.

A Dry Riser is an un-charged system of pipe-work and valves installed within a building which enables the Fire Service to pump water to the upper floors of a building when a fire occurs. A dry riser box or cabinet provides protection to dry riser inlets from accidental damage, dirt, dust, vandalism and rubbish deposits and helps to ensure that the equipment inside stays in the best condition to ensure that a supply of water can be maintained in any fire incident. Regular inspection and maintenance of the box and equipment inside is required.

This section lists products approved in accordance with:

BS 5041-5 *Fire hydrant systems - Boxes for dry riser inlets.*

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111 • Fax: +971 48151222

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463j to BS 5041-5

Boxes for dry riser inlets

| Product Name | Model | Size W X H (mm) | LPCB Ref. No. |
|--------------|---------------|-----------------|---------------|
| 4" x 2 way | NF-2WDRIC-SM | 595 x 395 | 463j/01 |
| 6" x 4 way | NF-4WDRIC-SM | 595 x 595 | |
| 4" x 2 way | NF-2WDRIC-SMA | 395 x 595 | |
| 4" x 2 way | NF-2WDRIC-RT | 595 x 395 | |
| 6" x 4 way | NF-4WDRIC-RT | 595 X 595 | |
| 4" x 2 way | NF-2WDRIC-RTA | 395 X 595 | |

PART 2: SECTION 5.6

PILLAR FIRE HYDRANTS

The purpose of a fire hydrant installation is to provide a connection to the water main to which the fire fighter can connect firefighting equipment. Pillar fire hydrants consist of one or more valves and connection outlets in a column shape, which emerges from below ground level, intended primarily to supply water for firefighting and also may be used by water utilities. Pillar fire hydrants are tested to EN 14384.

These hydrants are often provided by the owner/operator of larger developments and the responsibility for the supply of water rests with this organisations responsible person, whilst publicly located hydrants are provided and maintained by the civic authorities. Regular maintenance is required to remove dirt and debris, prevent seizure of the valve, to maintain a clean water supply and to ensure easy removal of the protective cover.

This section lists products approved in accordance with:

EN 14384:2005 *Pillar fire hydrants*

Emirates Fire Fighting Equipment Factory L.L.C. (FIREX)

P.O.Box 22436, Industrial Area 13, Sharjah, United Arab Emirates

Tel: +971 6 5340300 • Fax: +971 6 5340090

E-mail: firex@emirates.net.ae • Website: www.firexuae.com

Certificate No: 1280Aa to EN 14384:2005

| Product Name | Inlet size | Hose outlet | Pumper | LPCB Ref. No. |
|---------------------|-------------------|--------------------|-------------------|----------------------|
| FX16-117S | 4 (DN 100) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Aa/01 |
| FX16-082S | 4 (DN 100) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Aa/02 |
| FX16-083S | 6 (DN 150) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Aa/03 |
| FX16-117T | 6 (DN 150) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Aa/04 |

Exon For Fire Protection Inc.

615 Remnor Ave, Ottawa, Ontario K2T 0A6, Canada

Tel: +613 276 7755

E-mail: ahmed.shalaby@exonfire.com • Website: www.exonfire.com

Certificate No: 1280Da to EN 14384:2005

EZULA Pillar Fire Hydrants

| Product Name | Inlet size | Hose outlet | Pumper | LPCB Ref. No. |
|---------------------|-------------------|--------------------|-------------------|----------------------|
| EX16-117S | 4 (DN 100) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Da/01 |
| EX16-082S | 4 (DN 100) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Da/02 |
| EX16-083S | 6 (DN 150) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Da/03 |
| EX16-117T | 6 (DN 150) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Da/04 |

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111 • Fax: +971 48151222

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463n to BS EN 14384

PART 2: SECTION 5.6

PILLAR FIRE HYDRANTS

Pillar Fire Hydrants

| Product Name | Inlet size | Hose Outlet | Pumper Outlet | LPCB Ref. No. |
|----------------------|------------|---|----------------|---------------|
| 100 NHC - 800 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/01 |
| 100 NHC - 1200 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/02 |
| 100 NFHV - 800 | 4 (DN 100) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4 (100mm) | 463n/03 |
| 100 NFHV - 1200 | 4 (DN 100) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4 (100mm) | 463n/04 |
| 150 NFHV - 800 | 6 (DN 150) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4 (100mm) | 463n/05 |
| 150 NFHV - 1200 | 6 (DN 150) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4 (100mm) | 463n/06 |
| 100 NFBHQ - 800 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/07 |
| 100 NFBHQ - 1200 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/08 |
| 150 NFBHQ - 800 | 6 (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/09 |
| 150 NFBHQ - 1200 | 6 (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/10 |
| 100 NFBHQC - 800 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/11 |
| 100 NFBHQC - 1200 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/12 |
| 150 NFBHQC - 800 | 6 (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/13 |
| 150 NFBHQC - 1200 | 6 (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/14 |
| 100 NFBHQS-CD - 800 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/15 |
| 100 NFBHQS-CD - 1200 | 4 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/16 |
| 150 NFBHQS-CD - 800 | 6 (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/17 |
| 150 NFBHQS-CD - 1200 | 6 (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4 (100mm) | 463n/18 |

National Factory for Security & Safety Equipment LLC

P.O.Box 129, Road No. 19, Ind. Estate, Al Rusayl PC 124, Sultanate of Oman

Tel: +968 2444 6268 • Fax: +968 2444 6227

E-mail: sales@amancoglobal.com • Website: www.amancoglobal.com

Certificate No: 1280Ca to EN 14384:2005

AMANCO Pillar Fire Hydrants

| Product Name | Inlet size | Hose outlet | Pumper | LPCB Ref. No. |
|--------------|------------|--------------------|-------------------|---------------|
| AFH4-DR | 4 (DN 100) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Ca/02 |
| AFH6-DR | 6 (DN 150) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Ca/03 |

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar

Tel: +974 4402 5888 • Fax: +974 4411 4630

E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346d to EN 14384

PART 2: SECTION 5.6

PILLAR FIRE HYDRANTS

Pillar Fire Hydrants

| Product Name | Inlet size | Hose Outlet | Pumper Outlet | LPCB Ref. No. |
|--------------------|-------------|---|-----------------|---------------|
| 100 NQHC-800 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/01 |
| 100 NQHC-1200 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/02 |
| 100 NQFHV-800 | 4" (DN 100) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4" (100mm) | 1346d/03 |
| 100 NQFHV-1200 | 4" (DN 100) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4" (100mm) | 1346d/04 |
| 150 NQFHV-800 | 6" (DN 150) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4" (100mm) | 1346d/05 |
| 150 NQFHV-1200 | 6" (DN 150) | 2 x 2½" straight landing valve with BS 336 quick coupling | 1 x G4" (100mm) | 1346d/06 |
| 100 NQFHQ-800 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/07 |
| 100 NQFHQ-1200 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/08 |
| 150 NQFHQ-800 | 6" (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/09 |
| 150 NQFHQ-1200 | 6" (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/10 |
| 100 NQFHQC-800 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/11 |
| 100 NQFHQC-1200 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/12 |
| 150 NQFHQC-800 | 6" (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/13 |
| 150 NQFHQC-1200 | 6" (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/14 |
| 100 NQFHQS-CD-800 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/15 |
| 100 NQFHQS-CD-1200 | 4" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/16 |
| 150 NQFHQS-CD-800 | 6" (DN 100) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/17 |
| 150 NQFHQS-CD-1200 | 6" (DN 150) | 2 x G2½" BS 336 quick coupling | 1 x G4" (100mm) | 1346d/18 |

Saudi Factory for Fire Equipment FZCO

S-10833, Jebel Ali Free Zone, Authority South 1, Dubai 261281, United Arab Emirates

Tel: +971 4 880 9890 • Fax: +971 4 880 9822

E-mail: info@sffecoglobal.com • Website: www.sffecoglobal.com

Certificate No: 1280Ba to EN 14384:2005

SFFECO Pillar Fire Hydrants

| Product Name | Inlet size | Hose outlet | Pumper | LPCB Ref. No. |
|-----------------|------------|--------------------|-------------------|---------------|
| 100SFH680-LPDIB | 4 (DN 100) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Ba/01 |
| 100SFH1325-LPDI | 4 (DN 100) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Ba/02 |
| 150SFH1080-LPDI | 6 (DN 150) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Ba/03 |
| 150SFH680-LPDIB | 6 (DN 150) | 2 x 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280Ba/04 |

The Viking Corporation

210 N Industrial Park, Hastings, Michigan 49058, USA

Tel: +1 269 945 9501 • Fax: +1 269 945 9599

E-mail: techsvcs@vikingcorp.com • Website: www.vikingcorp.com

Certificate No: 096w to EN 14384:2005

PART 2: SECTION 5.6

PILLAR FIRE HYDRANTS

Viking Corp Fireking Pillar Fire Hydrants

| Product Name | Inlet size | Hose outlet | Pumper | LPCB Ref. No. |
|--------------|------------|--------------------|-------------------|---------------|
| HYF5 | 4 (DN 100) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 096w/01 |
| HYF2 | 4 (DN 100) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 096w/02 |
| HYF3 | 6 (DN 150) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 096w/03 |
| HYF4 | 6 (DN 150) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 096w/04 |

Zhejiang Flametech Industries Co Limited

Tianjia Village, Xiaoyue Town, Shangyu City, Zhejiang, China

E-mail: hzl@flametech-co.com • Website: www.flametech-co.com

Certificate No: 1280a to EN 14384

Pillar fire hydrants

| Product Name | Inlet size | Hose outlet | Pumper | LPCB Ref. No. |
|--------------|------------|--|-------------------|---------------|
| FT16-117S | 4 (DN 100) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280a/01 |
| FT16-082S | 4 (DN 100) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280a/02 |
| FT16-083S | 6 (DN 150) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280a/03 |
| FT16-117T | 6 (DN 150) | 2 X 2.5 BSP (65mm) | 1 x 4 BSP (100mm) | 1280a/04 |
| FT16-082T | 4 (DN 100) | 2 X 2.5 BS 336 (delivery hose connector) | 1 x 4 BSP (100mm) | 1280a/05 |
| FT16-117U | 4 (DN 100) | 2 X 2.5 BS 336 (delivery hose connector) | 1 x 4 BSP (100mm) | 1280a/06 |
| FT16-083T | 6 (DN 150) | 2 X 2.5 BS 336 (delivery hose connector) | 1 x 4 BSP (100mm) | 1280a/07 |
| FT16-117V | 6 (DN 150) | 2 X 2.5 BS 336 (delivery hose connector) | 1 x 4 BSP (100mm) | 1280a/08 |

PART 2: SECTION 5.7

GATE VALVES

Copper alloy gate valves are for use in fixed firefighting applications such as risers and hydrant systems having flanged, threaded, capillary, compression or loose nut/union body ends.

These products are approved to BS 5154 - *Specification for Copper alloy globe, globe stop and check, check and gate valves*

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete 73136, Greece

Tel: +30 28210 63222 • Fax: +30 28210 66260

E-mail: sales@mobiak.gr • Website: <http://www.mobiak.gr>

Certificate No: 1153Ab to BS 5154:1991

'MOBIAK' Copper Alloy Gate Valves

| Product Name | Description | LPCB Ref. No. |
|---------------------|---|----------------------|
| MBK06-043A-00 | 1 Copper alloy gate valve with lockshield | 1153Ab/01 |
| MBK06-043A1-00 | 1 Copper alloy gate valve with handwheel | 1153Ab/02 |

Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Wu Che Yan, Yuyao City, Zhejiang Province, China

Tel: +86 574 62025710 • Fax: +86 574 62025711

E-mail: info@jintianfire.com • Website: www.jintianfire.com

Certificate No: 1153b to BS 5154:1991

'JINTIAN FIRE' Copper Alloy Gate Valves

| Product Name | Description | LPCB Ref. No. |
|---------------------|---|----------------------|
| KX06-043A-00 | 1 Copper alloy gate valve with lockshield | 1153b/01 |
| KX06-043A1-00 | 1 Copper alloy gate valve with handwheel | 1153b/02 |

Fire hose couplings and ancillary equipment are intended for fire service use, of delivery hose conforming to BS 6391, suction hose conforming to BS 3165 or EN ISO 14557, suitable for firefighting purposes up to a working pressure not exceeding 16 bar and other items of equipment associated with the use of firefighting hose.

Components covered in BS 336:

This section lists products approved in accordance with:

BS 336:2010 Specification for fire hose couplings and ancillary equipment.

Delivery hose couplings;

Are instantaneous pattern couplings, either male or female combined with a hose tail, fitted with pull-release or twist-release mechanism. Intended for fitment of a delivery hose of appropriate size, so enabling the delivery hose to connect to fire service equipment fitted with appropriate instantaneous pattern coupling or connector.

Standpipes;

Capable of engagement to an underground fire hydrant conforming to BS 750, enabling aboveground operation. Consisting of a shaft fitted with an instantaneous delivery hose coupling or a gland allowing continuous rotation of the swivel head. Swivel head containing outlet(s) fitted with instantaneous pattern female connector(s), anti-siphon facility fitted as necessary. Intended for fitment to delivery hose and fire service equipment with appropriate instantaneous pattern coupling.

Hydrant keys and bars;

Intended for use on underground hydrant valves conforming to BS 750, enabling above ground operation.

Note:

Unless otherwise specified by the purchaser, blank plugs for standpipes are non-vented. If venting is required it should be in accordance with BS 5041-1 and BS 5041-2.

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete 73136, Greece

Tel: +30 28210 63222 • Fax: +30 28210 66260

E-mail: sales@mobiak.gr • Website: <http://www.mobiak.gr>

Certificate No: 1153Af to BS 336:2010

'MOBIAK' Delivery Hose Couplings

| Product Name | Description | LPCB Ref. No. |
|----------------|--|---------------|
| MBK08-201A-00 | 2½" aluminium (LM25) delivery hose coupling with a 2¾" (70 mm) ribbed tails | 1153Af/01 |
| MBK08-201A1-00 | 2½" aluminium (LM25) delivery hose coupling with a 2½" (64 mm) ribbed tails | 1153Af/02 |
| MBK08-201A2-00 | 2½" aluminium (LM25) delivery hose coupling with a 2" (51 mm) ribbed tails | 1153Af/03 |
| MBK08-201A3-00 | 2½" aluminium (LM25) delivery hose coupling with a 1¾" (45 mm) ribbed tails | 1153Af/04 |
| MBK08-201A4-00 | 2½" aluminium (LM25) delivery hose coupling with a 1½" (38 mm) ribbed tails | 1153Af/05 |
| MBK08-201B-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 2¾" (70 mm) ribbed tails | 1153Af/06 |
| MBK08-201B1-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 2½" (64 mm) ribbed tails | 1153Af/07 |
| MBK08-201B2-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 2" (51 mm) ribbed tails | 1153Af/08 |
| MBK08-201B3-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 1¾" (45 mm) ribbed tails | 1153Af/09 |
| MBK08-201B4-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 1½" (38 mm) ribbed tails | 1153Af/10 |
| MBK08-201C-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 2¾" (70 mm) ribbed tails | 1153Af/11 |
| MBK08-201C1-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 2½" (64 mm) ribbed tails | 1153Af/12 |
| MBK08-201C2-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 2" (51 mm) ribbed tails | 1153Af/13 |
| MBK08-201C3-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 1¾" (45 mm) ribbed tails | 1153Af/14 |
| MBK08-201C4-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 1½" (38 mm) ribbed tails | 1153Af/15 |

PART 2: SECTION 5.8

FIRE HOSE COUPLINGS AND ANCILLARY EQUIPMENT

Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Wu Che Yan, Yuyao City, Zhejiang Province, China

Tel: +86 574 62025710 • Fax: +86 574 62025711

E-mail: info@jintianfire.com • Website: www.jintianfire.com

Certificate No: 1153f to BS 336:2010

Delivery hose couplings

| Product Name | Description | LPCB Ref. No. |
|---------------------|--|----------------------|
| KX08-201A-00 | 2½" aluminium (LM25) delivery hose coupling with a 2¾" (70 mm) ribbed tails | 1153f/01 |
| KX08-201A1-00 | 2½" aluminium (LM25) delivery hose coupling with a 2½" (64 mm) ribbed tails | 1153f/02 |
| KX08-201A2-00 | 2½" aluminium (LM25) delivery hose coupling with a 2" (51 mm) ribbed tails | 1153f/03 |
| KX08-201A3-00 | 2½" aluminium (LM25) delivery hose coupling with a 1¾" (45 mm) ribbed tails | 1153f/04 |
| KX08-201A4-00 | 2½" aluminium (LM25) delivery hose coupling with a 1½" (38 mm) ribbed tails | 1153f/05 |
| KX08-201B-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 2¾" (70 mm) ribbed tails | 1153f/06 |
| KX08-201B1-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 2½" (64 mm) ribbed tails | 1153f/07 |
| KX08-201B2-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 2" (51 mm) ribbed tails | 1153f/08 |
| KX08-201B3-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 1¾" (45 mm) ribbed tails | 1153f/09 |
| KX08-201B4-00 | 2½" copper alloy (CC491K) delivery hose coupling with a 1½" (38 mm) ribbed tails | 1153f/10 |
| KX08-201C-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 2¾" (70 mm) ribbed tails | 1153f/11 |
| KX08-201C1-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 2½" (64 mm) ribbed tails | 1153f/12 |
| KX08-201C2-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 2" (51 mm) ribbed tails | 1153f/13 |
| KX08-201C3-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 1¾" (45 mm) ribbed tails | 1153f/14 |
| KX08-201C4-00 | 2½" copper alloy (CW617N) delivery hose coupling with a 1½" (38 mm) ribbed tails | 1153f/15 |

Certificate No: 1153g to BS 336:2010

Standpipes

| Product Name | Description | LPCB Ref. No. |
|---------------------|-----------------------------------|----------------------|
| Model KX08-058-00 | Single outlet aluminium standpipe | 1153g/16 |
| Model KX08-059-00 | Double outlet aluminium standpipe | 1153g/17 |

Third party approval of the mobile fire extinguisher will help to ensure that they will function correctly if properly maintained, it will also demonstrate due diligence in supporting risk assessment based legislation. LPCB approval also helps ensure the mobile fire extinguishers meet and continue to meet appropriate standards.

Mobile fire extinguishers are manufactured and tested to a class B type fire but also cover class A fire if necessary with powder and water based extinguishing media tested in accordance with EN 3-7.

EN 1866 applies to mobile fire extinguishers with a total mass above 20kg for powder, water based and CO₂ extinguishers and manoeuvred by an operator on foot only. This standard does not cover fire tests for class C and class F fires but the extinguishing media can be effective on these types of fire. Class D fires are considered to be very specialist application and are not included.

Caution: To be sure of reliable, proven, performance of the fire extinguisher in fire condition, the extinguisher should carry independent proof of performance, such as the LPCB mark, and if it is to be supplied into the EU the additional CE mark will also be required as defined by PED.

Always follow manufacturers use, installation and servicing instruction and replace after use.

Abbreviations used for LPCB listing of mobile fire extinguishers

LPCB use the following abbreviations in the Red Book listings for mobile fire extinguishers.

| | |
|------------------------|--|
| Extinguishing Agent | |
| W - Water | WB - Water based (water plus additive) |
| ABC or BC - Dry powder | CO ₂ - Carbon Dioxide |

| | |
|--------------------------------|------------------------------|
| Method of Actuation | |
| SP - Stored pressure actuation | GC - Gas cartridge actuation |

| | |
|-------------------|-----------|
| Units or Capacity | |
| kg - Kilogram | l - litre |

Labelling

A requirement of EN 1866 is that each mobile fire extinguisher must be clearly labelled to identify the classes of fire for which they have demonstrated satisfactory performance as defined in BS EN 1866. In summary:

Class A: for use on flammable solid materials, for example wood, paper, coal, straw, cloth etc.

Class B: for use on fires involving flammable liquids or liquefiable solids.

Class C: for fires involving gases.

Class D: for fires involving metals for example magnesium, sodium, cadmium, manganese.

Class F: for use on cooking oil fires.

PART 2: SECTION 6

MOBILE FIRE EXTINGUISHERS

Colour Coding

EN 1866 permits a zone of colour of up to 10% of the external area of the extinguisher body to be used to identify the extinguishing agent in accordance with national specifications.

CE Marking

CE marking may be found on a mobile fire extinguisher as required by the European Union - Pressure Equipment Directive (PED) but should not be confused with LPCB approval. This directive has been published for products that are to be sold within the European Union (EU) and it requires proof of safety of the pressure vessel. The CE mark placed on a fire extinguisher demonstrates conformance with this pressure safety requirement. Performance testing and fire testing is not carried out as part of this directive.

Marine Equipment Directive

The Marine Equipment Directive (MED) was adopted into UK Law and became mandatory on the 5 August 1999. The MED covers any ship (or lifeboat) flying a flag of an EEA member state. The MED covers a vast array of equipment, covering all aspects of a ship's safety, including mobile fire extinguishers. Conformity assessment is through a Notified Body, such as LPCB, and the compliance mark is the Wheel-mark.

This section lists products approved in accordance with:

EN 1866-1:2007 - Mobile fire extinguishers

Associated Enterprises (S) Pte Ltd.

Block 28, Sin Ming Drive, #01-173 575702, Singapore

Tel: +65-64550555 • Fax: +65-64550505

E-mail: enquiry@aespl.com.sg • Website: www.aespl.com.sg

Certificate No: 1092Ac to BS EN 1866-1

PROTEC Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|------------------------------|-----------|-------------|---------------|
| PRO-10-CD | CO ₂ | 10 kg | 144 B | 1092Ac/01 |
| PRO-20-CD | CO ₂ | 20 kg | 183 B | 1092Ac/02 |
| PRO-30-CD | CO ₂ | 30 kg | 183 B | 1092Ac/03 |
| PRO-50-MF | Foam (Stored Pressure) | 50 litre | IV B | 1092Ac/04 |
| PRO-100-MF | Foam (Stored Pressure) | 100 litre | IV B | 1092Ac/05 |
| PRO-25-MDC | ABC Powder (Stored Pressure) | 25 kg | II B | 1092Ac/06 |
| PRO-50-MDC | ABC Powder (Stored Pressure) | 50 kg | IV B | 1092Ac/07 |
| PRO-100-MDC | ABC Powder (Stored Pressure) | 100 kg | IV B | 1092Ac/08 |

COFFCO

PO Box 5, Pincode - 678002, India

Tel: +914912908940 • Fax: +914912554695

E-mail: coffco@eth.net • Website: www.coffcofire.com

Certificate No: 1092Hc to EN 1866-1

COFFCO Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|---------------------------------|-----------|-------------|---------------|
| CFCO10 | CO ₂ | 10 kg | 144 B | 1092Hc/01 |
| CFCO20 | CO ₂ | 20 kg | 183 B | 1092Hc/02 |
| CFCO30 | CO ₂ | 30 kg | 183 B | 1092Hc/03 |
| CFF50 | Foam (Stored Pressure) | 50 litre | IV B | 1092Hc/04 |
| CFF100 | Foam (Stored Pressure) | 100 litre | IV B | 1092Hc/05 |
| CFDP25 | ABC Powder (Stored Pressure) | 25 kg | II B | 1092Hc/06 |

PART 2: SECTION 6**MOBILE FIRE EXTINGUISHERS**

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|---------------------------------|----------|-------------|---------------|
| CFDP50 | ABC Powder (Stored Pressure) | 50 kg | IV B | 1092Hc/07 |
| CFDP100 | ABC Powder (Stored Pressure) | 100 kg | IV B | 1092Hc/08 |

EUROFEU

12 Rue Albert Remy, Senonches 28250, France
 Tel: +33 82090 1818 • Fax: +33 23737 9196
 Website: www.eurofeu.fr

Certificate No: 1092Jc to EN 1866-1:2007

'eurofeu' Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|------------------------------|-----------|-------------|---------------|
| GT010 CO2 | CO ₂ | 10 kg | 144 B | 1092Jc/01 |
| GT020 CO2 | CO ₂ | 20 kg | 183 B | 1092Jc/02 |
| GT030 CO2 | CO ₂ | 30 kg | 183 B | 1092Jc/03 |
| GT050 EPA | Foam (Stored Pressure) | 50 litre | IV B | 1092Jc/04 |
| GT0100 EPA | Foam (Stored Pressure) | 100 litre | IV B | 1092Jc/05 |
| GT025 ABC | ABC Powder (Stored Pressure) | 25 kg | II B | 1092Jc/06 |
| GT050 ABC | ABC Powder (Stored Pressure) | 50 kg | IV B | 1092Jc/07 |
| GT0100 ABC | ABC Powder (Stored Pressure) | 100 kg | IV B | 1092Jc/08 |

Firekill LLP

14 Hanover Street, London W1S 1YH, United Kingdom
 Tel: +44 (0)207 3170 663 • Fax: +44 (0)207 3170 610
 E-mail: firekill@firekill.uk.com • Website: www.firekill.uk.com

Certificate No: 867Hc to EN 1866-1:2007

FireKill Mobile Fire Extinguisher

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|---------------------------------|----------|-------------|---------------|
| FK-P50TG | ABC Powder (Stored Pressure) | 50 kg | IV B | 867Hc/02 |

Lingjack Engineering Works PTE Ltd

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building 738471, Singapore
 Tel: +65 6759 4163 • Fax: +65 6758 7513
 E-mail: combat@lingjack.com • Website: www.combat.com.sg

Certificate No: 501f to BS EN 1866-1

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|------------------------------|-----------|-------------|---------------|
| C-20C | CO ₂ | 20 kg | 89 B | 501f/01 |
| C-30C | CO ₂ | 30 kg | 113 B | 501f/02 |
| C-50FTC | Foam (Cartridge Operated) | 50 litre | IV B | 501f/03 |
| C-100FTC | Foam (Cartridge Operated) | 100 litre | IV B | 501f/04 |
| C-135FTC | Foam (Cartridge Operated) | 135 litre | IV B | 501f/05 |
| C-25FTP | Foam (Stored Pressure) | 25 litre | II B | 501f/06 |

PART 2: SECTION 6

MOBILE FIRE EXTINGUISHERS

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|---|-----------------|--------------------|----------------------|
| C-50FTP | Foam (Stored Pressure) | 50 litre | II B | 501f/07 |
| C-50ATC | ABC Powder (Cartridge Operated) | 50 kg | IV B | 501f/08 |
| C-100ATC | ABC Powder (Cartridge Operated) | 100 kg | IV B | 501f/09 |
| C-150ATC | ABC Powder (Cartridge Operated) | 150 kg | IV B | 501f/10 |
| C-25ATP | ABC Powder (Stored Pressure) | 25 kg | II B | 501f/11 |
| C-50ATP | ABC Powder (Stored Pressure) | 50 kg | II B | 501f/12 |
| C-50PTC | Purple K Powder (Cartridge Operated) | 50 kg | IV B | 501f/13 |
| C-100PTC | Purple K Powder (Cartridge Operated) | 100 kg | IV B | 501f/14 |
| C-150PTC | Purple K Powder (Cartridge Operated) | 150 kg | IV B | 501f/15 |
| C-25PTP | Purple K Powder (Stored Pressure) | 25 kg | II B | 501f/16 |
| C-50PTP | Purple K Powder (Stored Pressure) | 50 kg | II B | 501f/17 |
| C-25MTC | Monnex Powder (Cartridge Operated) | 25 kg | III B | 501f/18 |
| C-50MTC | Monnex Powder (Cartridge Operated) | 50 kg | III B | 501f/19 |
| C-100MTC | Monnex Powder (Cartridge Operated) | 100 kg | III B | 501f/20 |

Certificate No: 501g to Technical Approval based upon BS EN 1866-1

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|---|-----------------|--------------------|----------------------|
| C-75ATC | ABC Powder (Cartridge operated) | 75 kg | IVB | 501g/02 |
| C-75PTC | Purple K Powder (Cartridge operated) | 75 kg | IVB | 501g/03 |

Note: 75kg CO₂ is not a nominal charge specified in EN 1866-1 clause 6.2.1 - Nominal Charges

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, United Arab Emirates

Tel: +971 4815111 • Fax: +971 48151222

E-mail: natfire@emirates.net.ae • Website: www.naffco.com

Certificate No: 463m to BS EN 1866-1

Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|---------------------|-----------------|-----------------|--------------------|----------------------|
| NTFC50X | AFFF foam (GC) | 50 litre | IV B | 463m/01 |
| NTFC100X | AFFF foam (GC) | 100 litre | IV B | 463m/02 |
| NTFC135X | AFFF foam (GC) | 135 litre | IV B | 463m/03 |
| NTP25 | ABC Powder (SP) | 25 kg | II B | 463m/07 |
| NTP50 | ABC Powder (SP) | 50 kg | IV B | 463m/08 |
| NTP100 | ABC Powder (SP) | 100 kg | IV B | 463m/09 |

Nasr Awwadeh Factory for Fire Fighting & Safety Equipment

Building No. 7, Mohammed Al Khodary Street, P.O. Box 330339, Marka 11134, Amman, Jordan
Tel: +962 6 488 1999 • Fax: +962 6 488 8861
E-mail: info@naffire.com • Website: www.naffire.com

Certificate No: 1092lc to EN 1866-1:2007

'NAF' Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|------------------------------|----------|-------------|---------------|
| NFM50 | Foam (Stored Pressure) | 50 litre | IV B | 1092lc/04 |
| NPD50 | ABC Powder (Stored Pressure) | 50 kg | IV B | 1092lc/07 |

Qatar Factory for Fire Fighting Equipment & Safety Systems - NAFFCO

New Industrial Area, Street No 41, PO Box 55644, Doha, Qatar
Tel: +974 4402 5888 • Fax: +974 4411 4630
E-mail: info@qatarfactory.qa • Website: www.qatarfactory.qa

Certificate No: 1346j to EN 1866-1

Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|-----------------|-----------|-------------|---------------|
| NQTFC50X | AFFF foam (GC) | 50 litre | IV B | 1346j/01 |
| NQTFC100X | AFFF foam (GC) | 100 litre | IV B | 1346j/02 |
| NQTFC135X | AFFF foam (GC) | 135 litre | IV B | 1346j/03 |
| NQTP25 | ABC Powder (SP) | 25 kg | II B | 1346j/07 |
| NQTP50 | ABC Powder(SP) | 50 kg | IV B | 1346j/08 |
| NQTP100 | ABC Powder (SP) | 100 kg | IV B | 1346j/09 |

Ras Al Khaimah Fire Fighting Equipment Factory Fire King L.L.C

Wiz 07/12 Rakia Warehouse, Industrial Zone, Al Jazeera Al Hamra, Ras Al Khaimah, United Arab Emirates
Tel: +97172437050 • Fax: +97172437040
E-mail: info@fireking.ae • Website: www.fireking.ae

Certificate No: 1092Fc to EN 1866-1

FIRE KING Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire Rating | LPCB Ref. No. |
|--------------|---------------------------------|-----------|-------------|---------------|
| FKCD10 | CO ₂ | 10 kg | 144 B | 1092Fc/01 |
| FKCD20 | CO ₂ | 20 kg | 183 B | 1092Fc/02 |
| FKCD30 | CO ₂ | 30 kg | 183 B | 1092Fc/03 |
| FKFM50 | Foam | 50 litre | IV B | 1092Fc/04 |
| FKFM100 | (Stored Pressure) Foam | 100 litre | IV B | 1092Fc/05 |
| FKPD25 | (Stored Pressure) ABC Powder | 25 kg | II B | 1092Fc/06 |
| FKPD50 | (Stored Pressure) ABC Powder | 50 kg | IV B | 1092Fc/07 |
| FKPD100 | (Stored Pressure) ABC Powder | 100 kg | IV B | 1092Fc/08 |

PART 2: SECTION 6

MOBILE FIRE EXTINGUISHERS

Sentura Group (including FireDepot)

Sentura House, 3 Lands End Way, Oakham, Rutland LE15 6RB, United Kingdom

Tel: +44 (0)330 999 22 33 • Fax: +44 (0)1572 770133

E-mail: sales@firedepot.co.uk • Website: www.firedepot.co.uk

Certificate No: 1093c to EN 1866-1

FIRECHIEF XTR Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-----------------|-----------|-------------|---------------|
| FXC10 | CO ₂ | 10 kg | 144 B | 1093c/01 |
| FXC20 | CO ₂ | 20 kg | 183 B | 1093c/02 |
| FXC30 | CO ₂ | 30 kg | 183 B | 1093c/03 |
| FXF50 | Foam (SP) | 50 litre | IV B | 1093c/04 |
| FXF100 | Foam (SP) | 100 litre | IV B | 1093c/05 |
| FXP25 | ABC Powder (SP) | 25 kg | II B | 1093c/06 |
| FXP50 | ABC Powder (SP) | 50 kg | IV B | 1093c/07 |
| FXP100 | ABC Powder (SP) | 100 kg | IV B | 1093c/08 |

Unisafe Fire Protection Specialists LLC

P.O.Box 117579, Ras Al Khor, Al Aweer Industrial Estate, Dubai, United Arab Emirates

Tel: +971 4 3339977 • Fax: +971 4 3339358

Website: www.unisafedxb.com

Certificate No: 1092Dc to BS EN 1866-1

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|------------------------------|-----------|-------------|---------------|
| UCME10 | CO ₂ | 10 kg | 144 B | 1092Dc/01 |
| UCME20 | CO ₂ | 20 kg | 183 B | 1092Dc/02 |
| UCME30 | CO ₂ | 30 kg | 183 B | 1092Dc/03 |
| UFME50 | Foam (Stored Pressure) | 50 litre | IV B | 1092Dc/04 |
| UFME100 | Foam (Stored Pressure) | 100 litre | IV B | 1092Dc/05 |
| UPME25 | ABC Powder (Stored Pressure) | 25 kg | II B | 1092Dc/06 |
| UPME50 | ABC Powder (Stored Pressure) | 50 kg | IV B | 1092Dc/07 |
| UPME100 | ABC Powder (Stored Pressure) | 100 kg | IV B | 1092Dc/08 |

Yuyao Tianbo Fire Fighting Equipment Co., Ltd.

Baishuicong Industrial Park, Lianglong Town, Yuyao City, Zhejiang, China

Tel: +86-21-61602389 • Fax: +86-21-61602389 ext. 805

E-mail: export@yytianbo.cn • Website: www.yytianbo.cn

Certificate No: 1092c to EN 1866-1:2007

Mobile Fire Extinguishers

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|-----------------------------------|-----------|-------------|---------------|
| TMCD10 | CO ₂ (Stored Pressure) | 10 kg | 144 B | 1092c/01 |
| TMCD20 | CO ₂ (Stored Pressure) | 20 kg | 183 B | 1092c/02 |
| TMCD30 | CO ₂ (Stored Pressure) | 30 kg | 183 B | 1092c/03 |
| TMFM50 | Foam (Stored Pressure) | 50 litre | IV B | 1092c/04 |
| TMFM100 | Foam (Stored Pressure) | 100 litre | IV B | 1092c/05 |
| TMPD25 | ABC Powder (Stored Pressure) | 25 kg | II B | 1092c/06 |
| TMPD50 | ABC Powder (Stored Pressure) | 50 kg | IV B | 1092c/07 |
| TMPD100 | ABC Powder (Stored Pressure) | 100 kg | IV B | 1092c/08 |

Notes:

1. Available as brand name – 'TIANBO'

2. Available as brand name – 'MEGA SAFETY'

Zhejiang Ruihua Machinery Co. Ltd

No. 1 Fengqixi Road, Western Industrial Zone, Linshan Town, Yuyao, Zhejiang 315460, China

Tel: 0086 1350 578 4280 • Fax: 0086 574 6200 3570

E-mail: jingxingli@ruihuafire.com

Certificate No: 867c to EN 1866-1

| Product Name | Type | Capacity | Fire rating | LPCB Ref. No. |
|--------------|---------------------------------|----------|-------------|---------------|
| P25TG | ABC Powder (Stored Pressure) | 25 kg | II B | 867c/01 |
| P50TG | ABC Powder (Stored Pressure) | 50 kg | IV B | 867c/02 |

PART 2: SECTION 7

HAND-HELD BRANCHPIPES

Hand-held branchpipes are intended for fire service use with water only as the intended media. The hand-held branchpipes have a combination of components that connect to a water supply via a hose and coupling and projects water according to the operators requirements. A hand-held branchpipe is comprised of at least the following components: fitting system; gripping device; open and shut-off device, one or more jet/spray system(s) and a flow adjustment system (if applicable).

Branchpipes are defined in accordance with EN 15182-1 Annex A and using the spray types defined by Annex C.



Key

- 1 hollow cone spray
- 2 full cone spray
- 3 hollow/full cone spray alternatively
- 4 hollow cone spray combined with narrow spray jet
- 5 hollow cone spray combined with full jet

The hand-held branchpipes shall be used in accordance with the manufacturer's instructions for use and maintenance.

This section lists products approved in accordance with:

EN 15182-1 Hand-held branchpipes for fire service use - Part 1: Common requirements

EN 15182-2 Hand-held branchpipes for fire service use - Part 2: Combination branchpipes PN16

EN 15182-3 Hand-held branchpipes for fire service use - Part 3: Smooth bore jet and/or one fixed spray jet angle branchpipes PN16

EN 15182-4 Hand-held branchpipes for fire service use - Part 4: High pressure branchpipes PN40

Exceptions:

The standards do not apply to branchpipes covered by EN 671, foam branchpipes, powder branchpipes or branchpipes with a maximum working pressure above 40 bar.

Note:

Branchpipes covered by EN 15182-3 offer no or inadequate protection for firefighters when the spray angle is less than 30° and therefore, should not be used in high risk firefighting situations such as internal attack. They should also not be used when fighting fire in or near electrical installations when the spray angle is less than 30° without written authorisation from the manufacturer in the manual. This authorisation from the manufacturer should include safety distances.

MOBIAK S.A.

96-98 M. Mpotsari St, Chania, Crete 73136, Greece

Tel: +30 282 10 63222 • Fax: +30 282 10 66260

E-mail: sales@mobiak.gr • Website: <http://www.mobiak.gr>

Certificate No: 1153Ac to EN 15182-1:2007+A1:2009 and EN 15182-3:2007+A1:2009

'MOBIAK' Hand-Held Branchpipes

| Product Name | Description | LPCB Ref. No. |
|---------------|--|---------------|
| MBK07-108C-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2 BSP threaded male inlet, hand-held branchpipe | 1153Ac/01 |
| MBK07-108A-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M56 x 4 threaded female inlet, hand-held branchpipe | 1153Ac/02 |
| MBK07-127F-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe | 1153Ac/03 |
| MBK07-108D-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2 BSP threaded male inlet, hand-held branchpipe | 1153Ac/04 |
| MBK07-108B-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M56 x 4 threaded female inlet, hand-held branchpipe | 1153Ac/05 |
| MBK07-127E-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe | 1153Ac/06 |
| MBK07-107C-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2½" BSP threaded male inlet, hand-held branchpipe | 1153Ac/07 |
| MBK07-107A-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M85*6*6H threaded female inlet, hand-held branchpipe | 1153Ac/08 |
| MBK07-107D-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2½" BSP threaded male inlet, hand-held branchpipe | 1153Ac/09 |
| MBK07-107B-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M85*6*6H threaded female inlet, hand-held branchpipe | 1153Ac/10 |

Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Wu Che Yan, Yuyao City, Zhejiang Province, China

Tel: +86 574 62025710 • Fax: +86 574 62025711

E-mail: info@jintianfire.com • Website: www.jintianfire.com

Certificate No: 1153c to EN 15182-1:2007+A1:2009 and EN 15182-3:2007+A1:2009

'JINTIAN FIRE' Hand-Held Branchpipes

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| KX07-108C-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2 BSP threaded male inlet, hand-held branchpipe | 1153c/01 |
| KX07-108A-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M56 x 4 threaded female inlet, hand-held branchpipe | 1153c/02 |
| KX07-127F-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe | 1153c/03 |
| KX07-108D-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2 BSP threaded male inlet, hand-held branchpipe | 1153c/04 |
| KX07-108B-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M56 x 4 threaded female inlet, hand-held branchpipe | 1153c/05 |
| KX07-127E-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe | 1153c/06 |
| KX07-107C-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2½" BSP threaded male inlet, hand-held branchpipe | 1153c/07 |

PART 2: SECTION 7

HAND-HELD BRANCHPIPES

| Product Name | Description | LPCB Ref. No. |
|---------------------|--|----------------------|
| KX07-107A-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M85*6*6H threaded female inlet, hand-held branchpipe | 1153c/08 |
| KX07-107D-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2½" BSP threaded male inlet, hand-held branchpipe | 1153c/09 |
| KX07-107B-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M85*6*6H threaded female inlet, hand-held branchpipe | 1153c/10 |